

平成26年度 排ガス中のばい煙濃度等

| 10月 | ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準:100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値:20ppm以下 | | | 塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下 | | |
|-----|---|----|------|---------------------------------|----|------|--|----|------|-----------------------------|----|-----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0.01 | 0 | 0 | 27 | 11 | 18.5 | 39 | 2 | 25.5 | 4 | 0 | 0.5 | 12 | 3 | 6 |
| 2 | 0.01 | 0 | 0.01 | 27 | 8 | 20 | 41 | 0 | 27.5 | 1 | 0 | 0 | 9 | 2 | 5 |
| 3 | 0.01 | 0 | 0.01 | 28 | 7 | 19.5 | 65 | 20 | 36 | 2 | 0 | 0 | 5 | 2 | 3 |
| 4 | 0.01 | 0 | 0 | 26 | 1 | 16.5 | 39 | 0 | 29 | 1 | 0 | 0 | 4 | 0 | 3 |
| 5 | 0.01 | 0 | 0 | 27 | 5 | 16.5 | 51 | 13 | 29 | 2 | 0 | 0 | 7 | 2 | 3.5 |
| 6 | 0.01 | 0 | 0 | 22 | 2 | 11.5 | 42 | 9 | 31.5 | 1 | 0 | 0 | 6 | 2 | 3 |
| 7 | 0 | 0 | 0 | 21 | 2 | 12.5 | 45 | 18 | 35 | 1 | 0 | 0 | 5 | 2 | 3 |
| 8 | 0 | 0 | 0 | 21 | 1 | 12 | 44 | 1 | 31 | 1 | 0 | 0 | 3 | 2 | 2.5 |
| 9 | 0.01 | 0 | 0 | 21 | 3 | 14.5 | 40 | 16 | 31.5 | 1 | 0 | 0 | 7 | 0 | 2.5 |
| 10 | 0.01 | 0 | 0 | 27 | 5 | 14.5 | 50 | 4 | 30 | 3 | 0 | 0.5 | 7 | 2 | 3.5 |
| 11 | 0 | 0 | 0 | 24 | 4 | 17 | 43 | 7 | 33 | 1 | 0 | 0 | 7 | 2 | 4 |
| 12 | 0 | 0 | 0 | 27 | 10 | 17 | 38 | 8 | 30.5 | 1 | 0 | 0 | 6 | 1 | 4 |
| 13 | 0.01 | 0 | 0 | 27 | 1 | 15 | 38 | 18 | 30.5 | 2 | 0 | 0 | 6 | 1 | 3 |
| 14 | 0 | 0 | 0 | 19 | 2 | 10 | 41 | 17 | 33 | 1 | 0 | 0 | 3 | 1 | 2 |
| 15 | 0 | 0 | 0 | 26 | 5 | 15.5 | 38 | 11 | 31 | 3 | 0 | 0.5 | 7 | 2 | 4 |
| 16 | 0 | 0 | 0 | 27 | 1 | 15 | 42 | 5 | 28.5 | 3 | 0 | 0.5 | 10 | 2 | 4.5 |
| 17 | 0 | 0 | 0 | 21 | 0 | 11.5 | 42 | 8 | 33 | 3 | 0 | 0.5 | 3 | 0 | 1.5 |
| 18 | 0 | 0 | 0 | 22 | 7 | 15 | 41 | 15 | 32.5 | 4 | 0 | 0.5 | 6 | 1 | 3 |
| 19 | 0 | 0 | 0 | 23 | 3 | 12 | 39 | 9 | 30 | 1 | 0 | 0 | 7 | 2 | 4 |
| 20 | 0 | 0 | 0 | 21 | 8 | 13.5 | 44 | 1 | 28.5 | 2 | 0 | 0 | 5 | 2 | 2.5 |
| 21 | 0.01 | 0 | 0 | 23 | 1 | 14.5 | 47 | 12 | 34.5 | 2 | 0 | 0 | 9 | 2 | 4 |
| 22 | 0 | 0 | 0 | 22 | 2 | 13 | 55 | 4 | 30 | 2 | 0 | 0 | 7 | 1 | 3.5 |
| 23 | 0 | 0 | 0 | 23 | 3 | 11 | 45 | 2 | 32.5 | 1 | 0 | 0 | 6 | 1 | 3.5 |
| 24 | 0 | 0 | 0 | 24 | 7 | 15.5 | 51 | 10 | 35.5 | 4 | 0 | 0.5 | 6 | 0 | 3 |
| 25 | 0 | 0 | 0 | 20 | 3 | 13 | 51 | 14 | 35 | 2 | 0 | 0 | 5 | 1 | 3 |
| 26 | 0 | 0 | 0 | 23 | 6 | 14 | 48 | 14 | 34.5 | 1 | 0 | 0 | 5 | 2 | 3.5 |
| 27 | 0 | 0 | 0 | 27 | 2 | 14 | 52 | 11 | 35 | 4 | 0 | 0.5 | 7 | 1 | 3 |
| 28 | 0 | 0 | 0 | 20 | 2 | 11 | 64 | 13 | 38.5 | 1 | 0 | 0 | 5 | 1 | 3 |
| 29 | 0 | 0 | 0 | 21 | 5 | 10.5 | 58 | 0 | 29 | 4 | 0 | 0.5 | 6 | 1 | 3.5 |
| 30 | 0 | 0 | 0 | 22 | 5 | 14 | 47 | 6 | 32 | 1 | 0 | 0 | 5 | 0 | 2 |
| 31 | 0 | 0 | 0 | 17 | 3 | 9 | 61 | 12 | 38 | 0 | 0 | 0 | 4 | 0 | 1 |

平成26年度 排ガス中のばい煙濃度等

| 11月 | ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準:100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値:20ppm以下 | | | 塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下 | | |
|-----|---|----|----|---------------------------------|----|------|--|----|------|-----------------------------|----|-----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 27 | 5 | 21 | 46 | 7 | 26 | 1 | 0 | 0 | 6 | 2 | 4 |
| 2 | 0 | 0 | 0 | 25 | 10 | 19 | 45 | 7 | 30 | 2 | 0 | 0 | 10 | 5 | 8 |
| 3 | 0 | 0 | 0 | 23 | 8 | 14 | 48 | 9 | 31 | 2 | 0 | 0 | 8 | 3 | 5 |
| 4 | 0 | 0 | 0 | 13 | 2 | 8 | 55 | 10 | 33 | 1 | 0 | 0 | 4 | 2 | 3 |
| 5 | 0 | 0 | 0 | 25 | 7 | 14 | 50 | 10 | 31 | 2 | 0 | 0 | 6 | 2 | 4 |
| 6 | 0 | 0 | 0 | 22 | 4 | 11 | 50 | 21 | 37 | 0 | 0 | 0 | 8 | 3 | 5 |
| 7 | 0 | 0 | 0 | 15 | 2 | 8 | 59 | 5 | 38 | 0 | 0 | 0 | 4 | 1 | 3 |
| 8 | 0 | 0 | 0 | 20 | 10 | 15 | 61 | 15 | 37 | 0 | 0 | 0 | 4 | 0 | 3 |
| 9 | 0 | 0 | 0 | 22 | 8 | 15 | 52 | 19 | 35 | 0 | 0 | 0 | 5 | 3 | 4 |
| 10 | 0 | 0 | 0 | 20 | 6 | 14 | 55 | 21 | 39 | 1 | 0 | 0 | 5 | 2 | 3 |
| 11 | 0 | 0 | 0 | 24 | 3 | 10 | 65 | 0 | 37 | 1 | 0 | 0 | 4 | 0 | 2 |
| 12 | 0 | 0 | 0 | 19 | 4 | 10 | 64 | 6 | 37.5 | 2 | 0 | 0 | 4 | 2 | 3 |
| 13 | 0 | 0 | 0 | 20 | 0 | 12.5 | 64 | 0 | 34.5 | 6 | 0 | 0.5 | 4 | 1 | 2.5 |
| 14 | 0 | 0 | 0 | 25 | 4 | 10.5 | 63 | 12 | 37 | 5 | 0 | 0.5 | 7 | 2 | 3.5 |
| 15 | 0 | 0 | 0 | 24 | 2 | 15 | 59 | 3 | 36.5 | 1 | 0 | 0 | 5 | 0 | 3.5 |
| 16 | 0 | 0 | 0 | 23 | 6 | 18 | 62 | 3 | 36 | 0 | 0 | 0 | 6 | 2 | 4 |
| 17 | 0 | 0 | 0 | 22 | 2 | 13 | 67 | 4 | 38 | 0 | 0 | 0 | 6 | 3 | 3 |
| 18 | 0 | 0 | 0 | 19 | 3 | 9 | 60 | 13 | 35 | 0 | 0 | 0 | 5 | 3 | 3 |
| 19 | 0 | 0 | 0 | 19 | 4 | 10 | 57 | 2 | 30 | 1 | 0 | 0 | 5 | 3 | 3 |
| 20 | 0 | 0 | 0 | 14 | 3 | 8 | 55 | 4 | 34 | 0 | 0 | 0 | 5 | 2 | 3 |
| 21 | 0 | 0 | 0 | 13 | 2 | 7 | 51 | 2 | 29 | 0 | 0 | 0 | 4 | 2 | 3 |
| 22 | 0 | 0 | 0 | 20 | 1 | 10 | 48 | 7 | 29 | 0 | 0 | 0 | 5 | 2 | 4 |
| 23 | 0 | 0 | 0 | 22 | 6 | 15 | 49 | 19 | 33 | 0 | 0 | 0 | 6 | 3 | 4 |
| 24 | 0 | 0 | 0 | 24 | 6 | 13 | 49 | 11 | 32 | 3 | 0 | 0 | 5 | 3 | 3 |
| 25 | 0 | 0 | 0 | 21 | 7 | 15 | 60 | 14 | 38 | 0 | 0 | 0 | 6 | 3 | 4 |
| 26 | 0 | 0 | 0 | 20 | 4 | 12 | 47 | 1 | 25 | 0 | 0 | 0 | 5 | 0 | 3 |
| 27 | 0 | 0 | 0 | 21 | 1 | 11 | 48 | 6 | 30 | 2 | 0 | 0 | 5 | 2 | 4 |
| 28 | 0 | 0 | 0 | 16 | 1 | 6 | 64 | 3 | 36 | 0 | 0 | 0 | 3 | 2 | 3 |
| 29 | 0.01 | 0 | 0 | 25 | 2 | 13.5 | 55 | 3 | 29 | 2 | 0 | 0.5 | 6 | 0 | 3 |
| 30 | 0 | 0 | 0 | 28 | 4 | 16.5 | 45 | 7 | 31.5 | 3 | 0 | 1 | 7 | 3 | 4.5 |

平成26年度 排ガス中のばい煙濃度等

| 1月 | ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準:100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値:20ppm以下 | | | 塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下 | | |
|----|---|----|----|---------------------------------|----|------|--|----|------|-----------------------------|----|----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 2 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 3 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 4 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 5 | 0 | 0 | 0 | 26 | 7 | 18 | 55 | 17 | 33 | 4 | 0 | 0 | 5 | 2 | 3 |
| 6 | 0 | 0 | 0 | 24 | 8 | 15 | 39 | 14 | 31 | 0 | 0 | 0 | 3 | 1 | 2 |
| 7 | 0 | 0 | 0 | 23 | 13 | 17 | 40 | 17 | 33 | 0 | 0 | 0 | 2 | 1 | 2 |
| 8 | 0 | 0 | 0 | 27 | 10 | 17 | 40 | 1 | 31 | 1 | 0 | 0 | 4 | 1 | 3 |
| 9 | 0 | 0 | 0 | 21 | 4 | 11 | 54 | 13 | 33.5 | 0 | 0 | 0 | 3 | 1 | 2.5 |
| 10 | 0 | 0 | 0 | 26 | 8 | 17 | 43 | 8 | 32.5 | 2 | 0 | 0 | 4 | 0 | 2.5 |
| 11 | 0 | 0 | 0 | 22 | 3 | 16 | 41 | 0 | 32.5 | 0 | 0 | 0 | 4 | 1 | 2.5 |
| 12 | 0 | 0 | 0 | 19 | 7 | 14 | 46 | 6 | 36.5 | 0 | 0 | 0 | 4 | 1 | 2 |
| 13 | 0 | 0 | 0 | 27 | 7 | 14 | 47 | 13 | 37.5 | 0 | 0 | 0 | 5 | 1 | 2 |
| 14 | 0 | 0 | 0 | 22 | 2 | 14.5 | 62 | 3 | 36.5 | 1 | 0 | 0 | 3 | 0 | 1.5 |
| 15 | 0 | 0 | 0 | 22 | 3 | 13 | 44 | 0 | 30 | 0 | 0 | 0 | 3 | 1 | 1.5 |
| 16 | 0 | 0 | 0 | 17 | 3 | 7.5 | 43 | 11 | 32.5 | 1 | 0 | 0 | 5 | 1 | 1.5 |
| 17 | 0 | 0 | 0 | 22 | 5 | 14 | 44 | 9 | 35 | 0 | 0 | 0 | 5 | 2 | 3 |
| 18 | 0 | 0 | 0 | 22 | 0 | 14 | 43 | 0 | 35 | 0 | 0 | 0 | 6 | 1 | 3.5 |
| 19 | 0 | 0 | 0 | 24 | 6 | 13 | 44 | 22 | 36.5 | 0 | 0 | 0 | 5 | 1 | 3 |
| 20 | 0 | 0 | 0 | 17 | 3 | 8.5 | 48 | 11 | 36 | 0 | 0 | 0 | 4 | 1 | 2.5 |
| 21 | 0 | 0 | 0 | 24 | 3 | 13 | 45 | 4 | 31.5 | 0 | 0 | 0 | 5 | 2 | 3 |
| 22 | 0 | 0 | 0 | 21 | 4 | 12.5 | 43 | 14 | 34 | 0 | 0 | 0 | 5 | 0 | 2 |
| 23 | 0 | 0 | 0 | 18 | 1 | 8.5 | 44 | 2 | 32.5 | 1 | 0 | 0 | 4 | 0 | 2 |
| 24 | 0 | 0 | 0 | 22 | 3 | 13.5 | 43 | 16 | 33 | 3 | 0 | 0 | 4 | 1 | 3 |
| 25 | 0 | 0 | 0 | 25 | 8 | 17 | 41 | 8 | 33.5 | 2 | 0 | 0 | 7 | 2 | 3.5 |
| 26 | 0 | 0 | 0 | 26 | 4 | 17 | 40 | 21 | 32.5 | 2 | 0 | 0 | 8 | 3 | 4.5 |
| 27 | 0 | 0 | 0 | 15 | 1 | 8 | 40 | 4 | 28 | 1 | 0 | 0 | 4 | 1 | 3 |
| 28 | 0 | 0 | 0 | 22 | 4 | 12 | 41 | 2 | 27 | 4 | 0 | 0 | 4 | 2 | 3 |
| 29 | 0 | 0 | 0 | 9 | 3 | 5 | 37 | 16 | 29 | 1 | 0 | 0 | 4 | 3 | 3 |
| 30 | 0 | 0 | 0 | 16 | 4 | 9 | 65 | 18 | 32 | 3 | 0 | 0 | 4 | 2 | 3 |
| 31 | 0 | 0 | 0 | 16 | 4 | 10 | 46 | 22 | 32 | 4 | 0 | 0 | 4 | 2 | 3 |

平成26年度 排ガス中のばい煙濃度等

| 2月 | ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準:100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値:20ppm以下 | | | 塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下 | | |
|----|---|----|----|---------------------------------|----|------|--|----|------|-----------------------------|----|----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 18 | 5 | 11 | 40 | 17 | 31 | 1 | 0 | 0 | 4 | 3 | 4 |
| 2 | 0 | 0 | 0 | 20 | 3 | 10 | 36 | 25 | 32 | 1 | 0 | 0 | 5 | 2 | 3 |
| 3 | 0 | 0 | 0 | 13 | 2 | 7 | 40 | 10 | 30 | 1 | 0 | 0 | 4 | 2 | 3 |
| 4 | 0 | 0 | 0 | 18 | 3 | 10 | 37 | 13 | 27 | 2 | 0 | 0 | 4 | 2 | 3 |
| 5 | 0 | 0 | 0 | 14 | 3 | 8 | 38 | 5 | 28 | 1 | 0 | 0 | 4 | 2 | 3 |
| 6 | 0 | 0 | 0 | 25 | 2 | 10 | 40 | 10 | 29 | 7 | 0 | 1 | 6 | 2 | 3 |
| 7 | 0 | 0 | 0 | 16 | 3 | 10 | 40 | 6 | 27 | 1 | 0 | 0 | 4 | 3 | 3 |
| 8 | 0 | 0 | 0 | 18 | 4 | 10 | 41 | 12 | 34 | 2 | 0 | 0 | 5 | 3 | 3 |
| 9 | 0 | 0 | 0 | 13 | 2 | 6 | 42 | 30 | 36 | 1 | 0 | 0 | 4 | 1 | 3 |
| 10 | 0 | 0 | 0 | 16 | 2 | 9 | 44 | 11 | 32 | 3 | 0 | 0 | 6 | 2 | 4 |
| 11 | 0 | 0 | 0 | 9 | 1 | 7 | 40 | 3 | 31 | 0 | 0 | 0 | 4 | 0 | 3 |
| 12 | 0 | 0 | 0 | 18 | 4 | 10 | 37 | 10 | 28 | 4 | 0 | 1 | 5 | 2 | 3 |
| 13 | 0 | 0 | 0 | 18 | 3 | 10 | 38 | 9 | 26 | 5 | 0 | 0 | 5 | 3 | 4 |
| 14 | 0 | 0 | 0 | 19 | 4 | 10 | 39 | 18 | 31 | 1 | 0 | 0 | 6 | 2 | 4 |
| 15 | 0 | 0 | 0 | 18 | 4 | 10 | 43 | 29 | 37 | 1 | 0 | 0 | 5 | 2 | 3 |
| 16 | 0 | 0 | 0 | 20 | 2 | 10 | 46 | 6 | 29.5 | 1 | 0 | 0 | 4 | 0 | 2 |
| 17 | 0 | 0 | 0 | 19 | 3 | 11.5 | 44 | 8 | 30.5 | 1 | 0 | 0 | 4 | 1 | 2.5 |
| 18 | 0 | 0 | 0 | 23 | 1 | 13 | 47 | 0 | 29.5 | 2 | 0 | 0 | 12 | 1 | 3.5 |
| 19 | 0 | 0 | 0 | 24 | 5 | 14.5 | 44 | 9 | 31.5 | 3 | 0 | 0 | 8 | 2 | 4.5 |
| 20 | 0 | 0 | 0 | 21 | 3 | 10.5 | 44 | 11 | 33.5 | 1 | 0 | 0 | 5 | 1 | 3 |
| 21 | 0 | 0 | 0 | 21 | 5 | 13 | 44 | 6 | 29 | 1 | 0 | 0 | 5 | 2 | 4 |
| 22 | 0 | 0 | 0 | 21 | 6 | 14 | 62 | 10 | 37 | 2 | 0 | 0 | 6 | 3 | 5 |
| 23 | 0 | 0 | 0 | 25 | 6 | 13 | 41 | 0 | 27 | 1 | 0 | 0 | 6 | 2 | 4 |
| 24 | 0 | 0 | 0 | 20 | 3 | 10 | 43 | 16 | 28 | 1 | 0 | 0 | 5 | 2 | 3 |
| 25 | 0 | 0 | 0 | 19 | 2 | 10 | 45 | 4 | 31 | 1 | 0 | 0 | 4 | 1 | 3 |
| 26 | 0 | 0 | 0 | 21 | 3 | 11 | 40 | 7 | 27 | 2 | 0 | 0 | 6 | 2 | 3 |
| 27 | 0 | 0 | 0 | 19 | 4 | 9 | 36 | 10 | 26 | 0 | 0 | 0 | 4 | 2 | 3 |
| 28 | 0 | 0 | 0 | 12 | 3 | 7 | 40 | 19 | 31 | 0 | 0 | 0 | 4 | 2 | 3 |

平成26年度 排ガス中のばい煙濃度等

| 3月 | ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準:100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値:20ppm以下 | | | 塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下 | | |
|----|---|----|----|---------------------------------|----|------|--|----|------|-----------------------------|----|-----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 27 | 1 | 12.5 | 45 | 2 | 33 | 0 | 0 | 0 | 4 | 0 | 2 |
| 2 | 0 | 0 | 0 | 28 | 5 | 13.5 | 47 | 3 | 30 | 0 | 0 | 0 | 5 | 1 | 2.5 |
| 3 | 0 | 0 | 0 | 19 | 5 | 12 | 39 | 4 | 30 | 0 | 0 | 0 | 4 | 2 | 3 |
| 4 | 0 | 0 | 0 | 22 | 3 | 13 | 44 | 8 | 26 | 0 | 0 | 0 | 3 | 1 | 2 |
| 5 | 0 | 0 | 0 | 24 | 6 | 14 | 40 | 14 | 30 | 0 | 0 | 0 | 3 | 2 | 2 |
| 6 | 0 | 0 | 0 | 19 | 5 | 13 | 43 | 23 | 34 | 0 | 0 | 0 | 3 | 2 | 3 |
| 7 | 0 | 0 | 0 | 23 | 11 | 17 | 41 | 25 | 34 | 0 | 0 | 0 | 5 | 2 | 4 |
| 8 | 0 | 0 | 0 | 23 | 2 | 15 | 49 | 3 | 33 | 0 | 0 | 0 | 6 | 0 | 2 |
| 9 | 0 | 0 | 0 | 24 | 9 | 15 | 40 | 22 | 33 | 0 | 0 | 0 | 5 | 1 | 2 |
| 10 | 0 | 0 | 0 | 19 | 6 | 11 | 41 | 20 | 34 | 0 | 0 | 0 | 4 | 2 | 3 |
| 11 | 0 | 0 | 0 | 23 | 2 | 12.5 | 41 | 0 | 29 | 0 | 0 | 0 | 4 | 1 | 3 |
| 12 | 0 | 0 | 0 | 27 | 3 | 13.5 | 51 | 15 | 32 | 4 | 0 | 0 | 4 | 2 | 2.5 |
| 13 | 0 | 0 | 0 | 20 | 3 | 10 | 43 | 2 | 28 | 0 | 0 | 0 | 5 | 1 | 3.5 |
| 14 | 0 | 0 | 0 | 24 | 5 | 13 | 46 | 12 | 31.5 | 4 | 0 | 0 | 4 | 2 | 2.5 |
| 15 | 0 | 0 | 0 | 25 | 6 | 15 | 41 | 7 | 31.5 | 3 | 0 | 0 | 8 | 2 | 4 |
| 16 | 0 | 0 | 0 | 26 | 5 | 12.5 | 43 | 19 | 33 | 1 | 0 | 0 | 5 | 1 | 2.5 |
| 17 | 0.01 | 0 | 0 | 22 | 6 | 12 | 59 | 16 | 36.5 | 2 | 0 | 0 | 5 | 2 | 3.5 |
| 18 | 0.01 | 0 | 0 | 24 | 2 | 13.5 | 43 | 3 | 27 | 2 | 0 | 0 | 5 | 1 | 3.5 |
| 19 | 0 | 0 | 0 | 22 | 5 | 14 | 40 | 15 | 29 | 2 | 0 | 0 | 6 | 2 | 3.5 |
| 20 | 0 | 0 | 0 | 20 | 3 | 10.5 | 50 | 7 | 32 | 1 | 0 | 0 | 5 | 2 | 3.5 |
| 21 | 0 | 0 | 0 | 23 | 5 | 15 | 40 | 9 | 29.5 | 0 | 0 | 0 | 6 | 2 | 4 |
| 22 | 0 | 0 | 0 | 22 | 7 | 14.5 | 42 | 14 | 33 | 1 | 0 | 0 | 5 | 3 | 3.5 |
| 23 | 0 | 0 | 0 | 20 | 1 | 13.5 | 40 | 18 | 32 | 1 | 0 | 0 | 6 | 2 | 3.5 |
| 24 | 0 | 0 | 0 | 18 | 3 | 10.5 | 44 | 0 | 28 | 1 | 0 | 0 | 5 | 1 | 3 |
| 25 | 0 | 0 | 0 | 22 | 3 | 12 | 38 | 5 | 25.5 | 3 | 0 | 0.5 | 5 | 1 | 3 |
| 26 | 0 | 0 | 0 | 22 | 5 | 13 | 37 | 10 | 30 | 1 | 0 | 0 | 6 | 1 | 3 |
| 27 | 0 | 0 | 0 | 23 | 6 | 13.5 | 43 | 3 | 27.5 | 3 | 0 | 0 | 6 | 2 | 3 |
| 28 | 0 | 0 | 0 | 24 | 5 | 15.5 | 39 | 2 | 28.5 | 2 | 0 | 0 | 6 | 2 | 3 |
| 29 | 0 | 0 | 0 | 21 | 5 | 15 | 38 | 6 | 26 | 1 | 0 | 0 | 6 | 2 | 3 |
| 30 | 0 | 0 | 0 | 28 | 6 | 16 | 36 | 4 | 24 | 2 | 0 | 0 | 8 | 2 | 3 |
| 31 | 0 | 0 | 0 | 21 | 1 | 13 | 40 | 1 | 25 | 1 | 0 | 0 | 4 | 1 | 2.5 |