

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成26年 ※1時間ごとの平均値。空白部分はごみの供給停止中。

(単位:℃)

10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1,001	953	914	890	906	895	906	882	872	786	899	934	930	899	901	906	911	909	904	904	936	907	936	922	9:10~9:44給じん停止
	2号炉	888	923	874	861	887	873	884	865	896	864	868	935	903	888	897	894	889	869	883	877	906	864	869	932	
2	1号炉	964	978	969	944	950	936	964	970	926	963	970	944	946	965	923	894	894	909	1,027	935	906	906	941	941	
	2号炉	909	924	903	873	906	909	910	890	859	895	910	900	892	902	909	865	849	848	879	867	855	881	836	882	
3	1号炉	964	945	898	875	864	928	906	904	918	972	1,035	968	922	913	898	921	988	935	846	894	889	926	912	896	
	2号炉	887	877	938	870	855	880	907	864	877	913	957	921	932	955	903	912	873	921	845	855	874	859	873	876	
4	1号炉	883	933	950	931	939	922	898	908	927	967	941	870	918	932	865	871	899	908	920	891	900	838			
	2号炉	872	879	880	864	884	899	890	892	895	886	877	880	875	900	871	861	877	846		896	856	850	873	895	
5	1号炉	886	880	889	887	901	870	885	869	872	899	888	868	865	883	903	892	911	867	891	891	883	873	865	868	
	2号炉	872	853	859	863	878	883	885	903	915	887	879	883	863	889	891	890	881	872	869	869	884	886	886	873	
6	1号炉	859	860	896	885	907	935	895	879	912	897	878	875	909	918	873	862	945	874	885	895	884	858	886	876	
	2号炉	880	879	847	859	854	874	863	850	873	864	865	835	873	863	895	858	855	853	853	863	878	869	889	870	
7	1号炉	876	887	885	907	899	897	903	862	874	907	889	848	882	893	855	840	844	871	884	908	895	886	890	879	
	2号炉	873	928	917	896	908	922	910	902	930	978	962	874	878	894	911	900	893	924	912	915	919	909	894	896	
8	1号炉	916	879	889	880	882	875	880	872	880	786	883	864	834	902	970	893	891	880	895	877	898	900	910	920	9:04~9:40給じん停止
	2号炉	889	903	937	893	855	875	875	904	894	747	874	911	916	885	933	909	872	875	906	901	904	909	926	919	9:24~10:02給じん停止
9	1号炉	885	871	892	878	899	949	875	912	891	888	913	866	898	910	875	904	881	924	851	886	858	853	844	896	
	2号炉	898	894	898	974	911	871	898	899	886	901	905	897	846	899	880	911	917	908	903	870	863	848	854	900	
10	1号炉	887	870	866	892	860	878	866	897	901	941	929	906	935	935	911	890	902	904	910	880	892	875	895	876	
	2号炉	933	898	878	919	884	851	864	894	949	1,026	931	846	879	839	847	887	906	881	858	873	872	858	950	904	
11	1号炉	862	888	897	892	918	940	892	890	889	828	867	892	880	871	866	883	892	905	918	885	885	882	930	907	
	2号炉	883	887	925	907	952	977	916	900	870	877	884	883	905	880	885	908	894	892	908	911				873	
12	1号炉	902	877	890	895	879	874	904	896	878	899	909	909	875	912	910	888	888	869	859	877	901	876	883	878	
	2号炉	921	896	882	884	900	880	881	868	895	878	914	885	888	873	915	915	918	883	922	872	892	901	912	892	
13	1号炉	878	882	894	859	863	890	912	922	884	951	934	884	918	896	878	891	885	874	844	870	888	874	884	832	
	2号炉	886	916	983	914	906	898	911	902	891	881	899	906	923	905	901	887	881	881	868	864	880	904	886	884	
14	1号炉	860	882	950	954	899	862	890	884	874	856	856	844	879	866	862	879	881	891	874	888	886	875	877	910	
	2号炉	882	879	875	878	876	875	892	888	871	948	905	906	888	864	872	887	846	896	884	912	893	879	882	917	
15	1号炉	926	880	858	859	879	898	949	921	868	858	914	960	1,026	1,032	893	931	874	898	879	888	860	872	907	902	
	2号炉	925	890	865	860	853	889	947	913	872	764	917	883	909	948	962	892	840	911	959	877	877	866	967	957	9:12~9:50給じん停止

10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	921	897	930	920	941	915	891	900	885	922	889	903	891	913	876	895	892	874	876	881	887	876	887	865	
	2号炉	949	907	976	959	1,000	944	873	927	926	941	969	913	876	951	869	841	853	873	877	893	869	894	871	895	
17	1号炉	883	860					879	870	880	868	857	851	860	843	822	838	892	870	885	875	875	916	882	865	
	2号炉	889	910	902	877	859	878	941	934	908	886	901	878	866	869	874	869	885	887	904	903	961	914	883	878	
18	1号炉	888	956	900	916	916	885	873	861	881	877	869	886	883	866	884	876	873	876	899	910	891	881	883	874	
	2号炉	928	965	955	881	903	908	1,008	965	898	899	879	904	897	882	886	886	881	886	909	925	896	881	879	910	
19	1号炉	873	896	938	875	887	909	897	881	886	882	862	858	872	866	856	890	881	891	874	870	872	878	866	879	
	2号炉	886	902	936	868	895	892	874	890	885	866	862	874	872	886	892	904	907	878	877	878					
20	1号炉	872	908	881	883	875	884	881	887	892	933	915	937	943	915	888	868	889	895	907	882	865	882	909	873	
	2号炉	803	887	899	909	871	884	852	892	885	930	935	890	874	977	914	922	841	864	889	872	856	897	903	903	
21	1号炉	865	886	915	886	899	908	944	907	914	915	896	940	937	843	832	884	881	885	919	904	891	866	880	900	
	2号炉	884	871	885	890	909	905	885	902	881	900	872	896	838	862	864	884	875	861	906	896	875	856	883	909	
22	1号炉	886	874	865	885	902	893	896	891	887	774	869	922	886	871	865	894	866	899	877	878	888	903	906	889	9:02~9:41給じん停止
	2号炉	869	876	892	898	917	902	913	864	936	735	857	872	894	884	905	873	866	873	855			905	904	862	9:23~10:06給じん停止
23	1号炉	904	901	892	886	882	913	902	907	915	965	978	924	909	921	872	897	907	899	915	825	713		859	901	20:23~22:03給じん停止
	2号炉	859	880	879	880	886	886	884	902	886	870	904	909	874	890	885	895	862	855	863	832	848	909	883	850	
24	1号炉	875	887	871	890	887	938	975	891	904	917	886	882	930	889	941	861	978	872	881	899	865	858	872	879	
	2号炉	893	878	867	869	857	892	884	933	901	940	914	900	881	926	869	935	947	882	898	902	867	852	881	875	
25	1号炉	853	856	867	857	872	856	885	870	855	890	887	881	861	877	870	878	872	890	859	871	871	862	881	861	
	2号炉	878	852	842	854	898	911	881	873	880	913	866	872	882	879	876	875	875	886	859	875	873	899	879	883	
26	1号炉	863	841			888	894	866	885	883	878	880	880	874	875	848	896	888	878	871	849	880	867	872	867	
	2号炉	869	873	877	867	891	855	853	914	863	922	905	918	906	890	919	867	902	872	873	882	862	861	853	862	
27	1号炉	867	869	921	939	933	908	879	866	866	904	892	867	873	864	854	867	848	872	879	875	866	880	896	871	
	2号炉	885	882	879	925	936	948	950	920	894	929	867	860	879	876	890	890	876	888	850	884	877	868	905	877	
28	1号炉	887	860	874	878	861	893	907	886	883	887	897	880	874	867	906	857	870	866	899	865	883	865	889	852	
	2号炉	863	870	882	867	857	857	882	901	886	909	902	851	889	865	872	865	881	864	891	902	870	867	883	899	
29	1号炉	865	856	870	873	861	862	876	899	867	825	1,021	851													定常運転~立ち下げ
	2号炉	892	883	806	865	855	865	859	858	868	757	866	895	880	874	881	888	891	918	652	1,005	928	963	1,035	920	9:22~10:08、18:03~19:05給じん停止
30	1号炉																									休炉
	2号炉	909	912	896	910	876	883	908	909	922	938	930	929	989	879	893	901	923	841	865	897	907	906	925	866	
31	1号炉																									休炉
	2号炉	871	890	851	898	869	867	862	860	877	868	873	885	876	902	920	896	899	891	866	892	911	921			



11月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	916	920	910	886	900	900	921	914			831	863	879	864	854	837	847	888	889	883	906	880	882	868	
	2号炉																									
17	1号炉	888	866	852	885	855	859	871	870	864	872	871	890	866	845	894	844	855	856	866	852	869	857	882	883	
	2号炉																									
18	1号炉	858	854	853	870	874	872	861	866	875	874	889	860	859	839	889	853	883	885	869	878	892	886	886	826	
	2号炉																									
19	1号炉	863	858	857	865	849	857	853	851	848	791	861	888	915	897	877	939	899	879	866	885	846	876	867	883	9:02～9:35給じん停止
	2号炉																									
20	1号炉	857	851	846	865	835	869	844	860	862	859	885	865	864	891	880	874	875	887	878	838	846	855	868	871	
	2号炉																									
21	1号炉	861	851	838	866	848	848	841	858	873	897	846	894	864	856	829	829	837	853	887					872	819
	2号炉																									
22	1号炉	844	823	828	839	849	856	844	821	847	854	853	850	852	860	890	871	863	885	847	859	857	818		843	
	2号炉																									
23	1号炉	861	875	882	855	873	862	862	864	864	830	820	862	889	872	869	874	872	846	887	868	867	870	865	868	
	2号炉																									
24	1号炉	852	856	854	851	876	869	870	866	867	854	853	838	847	856	871	883	853	856	860	930	892	877	864	850	
	2号炉																									
25	1号炉	831	872	838	871	829	842	852	849	861	863	843	854	845	854	861	854	825	865	865	854	885	899	857	884	
	2号炉																									
26	1号炉	842	887	908	859	862	879	866	879	856	764	869	867	918	904	874	886	905	861	841	876	850	866	860	883	8:58～9:33給じん停止
	2号炉																									
27	1号炉	877	859	863	868	868	873	862	862	855	874	872	861	883	956	883	869	950	839	830	834	824	818	810	844	
	2号炉																									
28	1号炉	847	832	891	874	865	844	836	859	852	842	859	834	841	847	815	806	842	850	836	874	868	870	886	872	
	2号炉																									
29	1号炉	861	860	864	877	864	879	844	876	878	861	861	859	749	873	863	869	839	864	884	881	844	863	885	872	12:05～12:45給じん停止
	2号炉					806	821	871	871	877	910	900	923	868	858	892	913	924	956	926	901	910	885	909	885	立ち上げ～定常運転
30	1号炉	862	888	844	889	842	882	872	867	861	874	897	845	852	867	861	860	845	868	887	861	853	857	851	870	
	2号炉	932	973	939	918	898	909	898	893	873	899	929	913	902	920	948	935	934	961	995	960	951	946	965	929	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成26年 ※1時間ごとの平均値。空白部分はごみの供給停止中。

(単位:℃)

12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	861	866	863	885	798		934	859	849	876	879	860	849	827	834	842	850	817	855	859	872	861	867	881	4:33~6:55給じん停止
	2号炉	966	917	942	929	872	908	882	895	902	940	1,026	972	885	870	875	882	871	902	924	891	930	919	944	903	
2	1号炉	856	874	870	869	861	872	863	857	867	864	887	901	907	847	827	830	836	861	857	854	840	879	877	858	
	2号炉	892	903	890	898	894	886	922	899	875	900	937	903	953	919	956	904	906	869			908	954	906	965	
3	1号炉	901	867	842	849	818	858	862	856	874	730	855	832	879	919	900	938	948	892	910	883	912	909	862	876	8:58~9:44給じん停止
	2号炉	953	962	910	894	888	893	886	879	905	796	939	976	936	926	925	927	926	910	926	938	922	915	898	885	9:20~10:00給じん停止
4	1号炉	858	887	884	870	852	870	856	864	870	951	936	911	932	897	922	929	902	864	869	858	860	870	882	869	
	2号炉	893	918	909	912	870	904	912	848	927	939	907	866	948	940	902	951	915	878	864	856	879	891	890	887	
5	1号炉	873	865	892	856				851	875	908	881	878	882	880	876	844	846	847	865	868	837	854	848	843	
	2号炉	905	875	882	875	928	911	863	915	967	990	997	941	884	891	911	993	881	893	878	935	883	885	889	879	
6	1号炉	861	873	885	872	851	869	894	902	891	877	869	866	861	871	870	880	880	877	874	895	872	862	884	880	
	2号炉	882	905	893	970	946	955	933	923	940	940	913	942	891	896	928	922	944	939	932	921	935	913	897	895	
7	1号炉	861	873	934	898	899	865	863	875	863	864	861	898	865	855	878	859	911	907	867	864	884	873	871	871	
	2号炉	918	917	916	916	948	925	963	979	944	954	924	932	904	873	848	845	868	853	909	881	889	883	898	879	
8	1号炉	878	882	876	896	868	861	857	906										1,104	943	871	870	855	871	867	
	2号炉	896	893	895	886	875	916	988	909	954	922	886	896	872	866	901	856	887	883	883	881	882	868	870	875	
9	1号炉	870	873	857	877	865	899	905	872	859	885	884	885	884	893	880	866	871	848	851	846	872	870	868	872	
	2号炉	880	871	868	884	879	903	874	888	882	894	886	871	890	902	902	922	871	852	839	857	865	855	868	875	
10	1号炉	868	868	815	847	847	862	860	864	873	814	910	937	945	921	912	926	942	910	907	914	909	879	905	999	
	2号炉	859	837	855	848	870	865	862	860	875	693	852	889	910	902	885	880	914	900	882	877	888	883	882	900	9:12~10:05給じん停止
11	1号炉	952	878	871	853	909	892	889	871	877	886	882	895	897	914	929	947	940	924	864	884	849	847	863	878	
	2号炉	907	879	880	850	856	889	933	857	901	931	907	917	869	866	869	882	887	867	869	877	845	841	830	848	
12	1号炉	852	878	874	868	883	865	903	889	904	918	905	860	920	876	914	956	904	908	896	912	914	900	863	891	
	2号炉	843	843	848	867	857	843	838	906	901	931	885	929	865	927	880	859	909	890	886	873		894	873	876	
13	1号炉	911	897	913	877	880	862	898	896	873	890	877	867	863	876	896	910	882	930	909					911	
	2号炉	854	876	897	883	892	847	877	871	866	886	877	877	853	881	871	911	873	895	902	866	859	884	859	886	
14	1号炉	909	871	858	850	874	887	892	864	873	895	872	882	890	886	883	916	868	913	964	887	886	890	861	882	
	2号炉	851	884	908	854	874	876	890	876	869	865	880	897	879	879	885	889	851	878	888	891	888	881	861	866	
15	1号炉	880	866	878	873	864	865	897	881	898	890	859	914	888	871	898	869	881	876	881	873	846	895	868	1,000	
	2号炉	881	873	865	854	848	831	856	884	843	882	834	866	860	843	865	854	874	879	897	868	877	872	872	868	



燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉																									休炉
2	1号炉																									休炉
	2号炉																									休炉
3	1号炉																									休炉
	2号炉																									休炉
4	1号炉																									休炉
	2号炉																									休炉
5	1号炉																									休炉
	2号炉								895	889	909	911	923	879	864	844	846	904	872	882	1,001	1,062	953	915	立ち上げ～定常運転	
6	1号炉																									休炉
	2号炉	923	897	886	930	975	909	896	903	950	948	908	936	963	882	928	945	900	962	977	924	951	950	952	928	
7	1号炉																									休炉
	2号炉	941	934	943	906	951	937	935	959	940	941	921	942	921	986	902	956	927	919	965	934	939	927	958	841	
8	1号炉																									休炉
	2号炉	903	935	892	886	905	946	939	908	942	959	958	1,012	1,067	947	965	953	909	951	925	852	845	888	866	835	
9	1号炉						939	823	824	613	570	847	829	852	865	840	850	880	885	892	847	894	927	950	立ち上げ～定常運転 9:22～10:55給じん停止	
	2号炉	840	864	888	843	866	862	844	850	850	826	837	813	853	830	837	835	842	840	862	863	870	884	872	892	
10	1号炉	918	895	918	955	964	933	962	919	967	943	990	969	897	928	938	939	977	933	965	971	931	938	961	965	
	2号炉	919	943	904	931	941	964	937	875	949	948	921	903	894	896	935	931	919	907	906	914	901	914	918	859	
11	1号炉	953	971	948	994	995	955	981	964	952	952	812	810	837	890	957	911	898	862	918	934	935	957	938	807	
	2号炉	890	950	885	896	907	883	900	901	915	894	901	901	900	885	922	912	888	900	884	895	887	900	897	914	
12	1号炉	846	943	931	983	929	963	936	940	940	905	903	912	900	941	962	964	938	936	973	942	921	933	941	950	
	2号炉	911	897	903	916	877	883	906	890	898	857	873	852	881	855	907	878	870	870	874	884	841	872	900	887	
13	1号炉	905	902	913	933	945	920	939	957	945	985	986	1,008	930	981	948	925	953	933	889	922	911	947	976	960	
	2号炉	868	882	884	857	871	877	821	871	891	987	965	912	898	912	986	908	866	915	903	885	889	881	892	893	
14	1号炉	1,004	990	973	991	976	927	960	932	935	865	888	928	959	955	1,000	993	962	1,003	941	897	915	917	928	942	
	2号炉	902	854					889	865	849	724	890	886	863	881	862	898	862	857	880	848	854	852	861	864	9:11～9:54給じん停止
15	1号炉	902	854	895	908	901	993	956	927	947	1,004	906	946	1,038	944	971	995	1,001	988	914	912	915	901	888	878	
	2号炉	838	845	861	839	854	877	858	880	846	852	872	862	884	825			841	871	866	827	860	823	824	819	









燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

3月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	875	854	865	864	872	893	897	855	878	874	862	868	874	875	858	858	875	844	849	857	882	863	960	927	
	2号炉			803	817	836	851	868	872	874	890	870	895	903	894	883	900	882	875	878	898	906	928	962	964	
2	1号炉	946	866	724																						定常運転～立ち下げ
	2号炉	995	918		860	895	876	911	918	897	929	933	874	862	884	875	886	890	897	872	879	865	865	872	863	
3	1号炉																									休炉
	2号炉	861	862	867	863	878	870	865	868	866	805	894	953	906	975	994	970	961	910	884	870	881	870	873	874	
4	1号炉																									休炉
	2号炉	869	884	898	1,007	887				862	828	842	843	892	896	890	903	890	894	941	916	928	935	926	920	
5	1号炉																									休炉
	2号炉	926	1,014	974	935	903	927	884	898	930	1,034	972	900	875	897	911	889	903	886	882	884	870	879	877	879	
6	1号炉																									休炉
	2号炉	869	875	894	898	848	937	934	938	930	902	896	894	911	927	978	944	900	935	873	872	875	863	862	875	
7	1号炉																									休炉
	2号炉	883	929	888	918	934	866	879	894	934	892	868	940	969	952	985	967	956	955	919	879	897	984	944	864	
8	1号炉																									休炉
	2号炉	887	917	887	962	937	897	892	899	929			883	911	849	869	862	938	874	872	872	875	872	896		
9	1号炉																									休炉
	2号炉	865	932	958	920	884	903	923	926	927	901	904	867	907	966	933	919	902	875	896	895	941	902	870	916	
10	1号炉																									休炉
	2号炉	885	921	911	905	911	904	875	919	924	930	923	876	940	933	910	913	942	958	967	915	915	922	921	933	
11	1号炉						821	863	893	872	881	854	877	850	857	864	892	883	851	854	868	840	846	900		立ち上げ～定常運転
	2号炉	923	891	882	866	883	892	890	886	903	783	1,057	1,004	978	957	969	928	942	994	947	925	949	881			9:00～9:40給じん停止
12	1号炉	873	870	870	870	882	878	884	864	891	903	922	965	948	965	920	911	878	890	881	884	838	874	880	900	
	2号炉			873	873	886	861	866	871	903	925	986	1,020	965	965	941	967	896	945	910	927	858	913	922	918	
13	1号炉	902	868	896	902	896	879	903	887	910	908	900	887	869	799	802	813	879	914	924	859	857	890	874	890	
	2号炉	914	877	904	870	864	875	902	874	910	925	926	887	827	823	819	857	932	917	894	868	891	886	868	875	
14	1号炉	892	907	915	926	861	902	893	861	919	895	852	853	907	891	907	884	899	874	898	920	913	886	887	851	
	2号炉	880	945	967	933	930	917	878	908	890	884	875	932	935	961	967	912	911	872	931	938	928	929	937	903	
15	1号炉	899	895	875	963	948	926	916	905	856	854	873	873	900	879	899	924	894	894	926	932	898	901	895	888	
	2号炉	927	882	899	960	1,009	977	960	957	933	906	908	903	892	900	889	883	914	925	969	903	914	926	892	902	

3月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	882	897	935	913	847	869	928	888	885	883	952	912	911	879	849	864	881	898	859	871	866	853	876	886	
	2号炉	920	879	972	908	932	917	955	921	945	1,003	994	1,003	968	937	908	894	892	906	925	897	916	905	899	877	
17	1号炉	902	866	859	890	853	848	862	891	900	881	944	876	898	896	925	905	941	887	880	886	879	891	884	883	
	2号炉	903	962	921	932	886	913	916	909	983	1,017	989	955	897	941	947	919	904	878	874	869	868	885	880	867	
18	1号炉	876	856	888	891	906	884	916	936	918	827	927	942	959	884	916	983	939	901	871	866	849	866	897	857	
	2号炉	874	841					919	851	931	790	935	941	921	922	903	1,001	943	885	897	882	873	908	920	908	9:20～9:54給じん停止
19	1号炉	902	831	830	814	816	871	901	877	889	926	932	952	876	842	837	843	849	855	862	842	878	840	855	865	
	2号炉	926	909	874	882	921	914	928	908	914	924	943	979	954	917	923	899	901	919	971	925	924	929	938	941	
20	1号炉	818	835	849	863	898	909	902	891	880	993	960	911	876	874	910	877	926	863	894	860	885	826	834	902	
	2号炉	852	922	903	901	909	924	911	943	868	952	945	918	893	867	896	877	888	883	889	909	922	953	910	933	
21	1号炉	877	853	825	893	833	893	912	880	899	878	934	902	893	907	940	943	970	925	934	924	935	938	900	917	
	2号炉	898	893	887	862	811	879	930	910	914	893	916	913	917	897	932	939	928	941	916	975	940	934	947	940	
22	1号炉	928	905	913	921	904	926	908	884	871	900	917	901	894	915	960	923	898	888	928	894	905	930	929	927	
	2号炉	929	885	893	919	902	946	917	893	875	898	933	928	908	942	949	915	900	928	960	920	901	913	948	921	
23	1号炉	916	937	946	948	899	930	915	905	908	928	914	905	912	915	879	878	887	862						835	
	2号炉	917	916	920	948	903	896	942	923	913	939	991	933	850	883	884	868	908	865	911	918	921	936	910	914	
24	1号炉	881	867	857	863	862	832	848	860	876	908	879	930	955	924	832	879	906	856	841	859	867	856	866	872	
	2号炉	900	928	877	878	887	877	868	875	859	870	912	927	891	870	872								805	861	
25	1号炉	867	867	860	882	869	898	864	868	921	729	895	913	866	915	902	909	856	838	877	855	890	882	887	913	9:00～9:42給じん停止
	2号炉	864	846	871	899	881	879	870	854	874	764	909	954	899	909	858	873	913	870	898	915	923	900	931	940	9:26～10:07給じん停止
26	1号炉	901	868	871	901	924	903	824	860	868	915	908	946	855	834	884	863	874	842	843	860	807	880	883	863	
	2号炉	921	910	890	894	914	913	848	857	910	903	885	927	886	859	851	858	867	862	853	874	871	869	881	873	
27	1号炉	866	892	843	845	880	845	862	833	898	876	889	901	856	869	871	846	879	874	863	863	852	865	871	876	
	2号炉	862	906	886	896	892	884	937	888	913	939	966	896	871	887	881	899	861	880	894	790	895	856	859	863	19:00～19:45給じん停止
28	1号炉	860	889	924	898	837	737	820	836	898	796	906	885	875	859	887	889	900	852	909	873	898	879	892	873	5:44～5:58給じん停止、9:00～10:00熱電対接触不良
	2号炉	856	921	935	928	860	878	908	900	902	916	871	878	875	893	911	905	912	928	872	854	863	868	909	874	
29	1号炉	876	903	868	927	870	904	878	762	904	962	858	902	884	890	939	876	933	930	861	872	864	853	861	857	7:05～7:50給じん停止
	2号炉	871	902	897	936	872	883	910	880	878	905	898	897	858	934	865	887	937	932	794	872	878	857	863	878	18:10～18:50給じん停止
30	1号炉	874	859	904	869	834	873	901	793	846	864	870	898	841	815	809	825	839	872	810	824	815	859	826	828	7:12～7:42給じん停止
	2号炉	854	890	880	850	887	926	992	800	831	913	860	882	882	874	892	850	874	838	926	888	875	869	876	868	
31	1号炉	833	808	858	839	839	838	863	874	891	931	912	912	889	904	907	817	905	890	854	930	885	893	886	883	
	2号炉	863	849					856	884	880	894	898	881	871	889	871	890	915	893	885	869	899	882	924	922	