

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成29年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	951	988	967	980	978	976	990	992	983	972	941	998	980	935	959	966	936	936	971	974	965	961	1,005	1,016	
	2号炉	932					878	948	927	939	926	907	878	932	924	923	858	936	920	896	896	928	913	929	922	
2	1号炉	947	960	955	963	915	956	990	943	1,013	964	920	965	952	940	938	886	934	961	981	979	942	940	947	927	
	2号炉	951	910	928	931	931	901	937	941	917	911	933	934	945	913	906	909	939	909	927	919	941	942	928	943	
3	1号炉	966	967	972	916	942	945	942	923	963			935	944	902	924	906	934	924	911	908	912	954	964	953	
	2号炉	939	935	944	918	926	910	922	919	930	965	974	972	931	904	937	936	929	915		935	886	914	926	957	
4	1号炉	964	964	959	961	939	938	858	896	938	836	954	940	932	945	947	937	944	929	916	893	917	903	935	921	
	2号炉	919	925	955	915	934	945	949	910	951	847	946	961	977	936	934	918	935	973	899	913	945	917	943	907	
5	1号炉	895	957	964	924	916	946	956	951	973	995	968	929	954	956	953	972	972	954	940	953	920	915	891	914	
	2号炉	900	902	906	949	910	933	933	939	933	982	963	921	933	941	931	957	962	867	895	910	878	914	888	914	
6	1号炉	947	939	914	914	946	936	965	937	915	965	954	984	921	944	828	778	911	931	943	940	949	934	922	908	14:30~15:25給じん停止
	2号炉	944	889	757	870	906	911	907	931	906	902	916	902	909	947	946	914	914	883	896	900	927	888	853	855	1:34~2:10、 2:47~3:11給じん停止
7	1号炉	893	921	948	972	960	921	986	934	937	936	961	970	909	984	942	965	920	1,006	937	934	910	939			
	2号炉	886	851	893	907	939	853	874	928	903	931	913	833	884	949	930	959	926	899	892	890	901	897	873	892	
8	1号炉	898	922	902	918	922	905	904	906	917	918	901	906	860	896	909	957	970	877	900	898	944	913	965	947	
	2号炉	888	826	902	887	907	866	902	859	865	847	874	873	894	886	905	904	892	871	878	892	885	866	886	900	
9	1号炉	925	940	957	973	958	911	923	939	934	954	934	913	914	891	909	919	933	949	978	941	917	947	921	922	
	2号炉	877	826	902	862	909	905	900	929	836	911	865	930	942	868	897	934	958	934	924	947	890	898	932	933	
10	1号炉	893	905	904	917	919	924	906	927	921		950	895	930	944	964	954	962	951	896	915	899	911	940	907	
	2号炉	871	913	941	896	859	830	847	860	895	919	943	974	968	915	945	974	945	909				901	933	920	
11	1号炉	881	873	911	914	916	892	912	922	983	987	998	980	993	997	990	966	960	954	958	977	936	1,027	960	954	
	2号炉	867	874	766	870	894	893	889	881	901	778	919	950	961	924	915	924	975	951	979	967	990	947	910	907	1:37~2:49、 9:14~9:41給じん停止
12	1号炉	969	919	919	888	888	909	867	869	913	827	964	880	964	919	953	953	958	962	949	934	926	930	916	918	
	2号炉	947	917	885	899	920	883	889	898	920	850	844	876	964	1,010	973	936	982	936	914	913	844	936	938	918	
13	1号炉	943	921	925	922	944	952	938	952	907	932	937	944	945	945	927	944	929	851	953	922	933	948	940	909	
	2号炉	936	896	933	908	896	941	879	930	924	939	960	956	979	902	939	930	974	927	929	916	946	930	875	905	
14	1号炉	939	921	935	921	969	956	951	967	957	953	932	936	928	937	970	1,005	980	962	932	962	945	948	948	909	
	2号炉	928	925	923	930	945	1,000	1,011	872	894	889	903	913	918	915	942	967	965	922	940	916	921	898	904	956	
15	1号炉	978	1,017	981	994	944	950	900	987	965	953	975	973	977	979	976	970	1,031	899	975	941	967	922		915	
	2号炉	929	964	913	975	904	930	878	901	929	895	906	904	884	878	910	918	922	855	882	859	866	880		871	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成29年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉					945	888	900	835	857	890	941	943	942	946	989	943	963	963	988	937	918	975	991		
	2号炉																									休炉
2	1号炉	930	930	944	954	957	936	964	929	902	948	934	919	899	937	930	926	939	915	916	919	905	916	936	951	
	2号炉																									休炉
3	1号炉	922	919	913	921	911	916	960	919	921	944	893	950		951	972	965	956	965	965	902	931	882	902		
	2号炉																									休炉
4	1号炉	880	888	883	879	897	907	935	947	949	940	939	955	890	958	915	933	944	927	920	940	918	912	966	919	
	2号炉											822	928	929	921	944	966	960	954	924	894	881	909	922	898	立ち上げ～定常運転
5	1号炉	924	959	1,005	992	952	920	959	971	999	965	939	928	943	970	948	989	956	950	914	978	945	936	963	984	
	2号炉	964	954	969	943	1,051	989	984	973	1,002	966	978	979	956	989	1,002	990	825	943	959	911	945	991	998	1,052	
6	1号炉	971	948	933	984	958	959	974	1,000	973	953	965	998	999	994	986	916	990	982	983	933	929	877	869	914	
	2号炉	1,015	1,037	917	1,002	1,029	1,076	1,046	968	991	1,112	914	1,019	929	1,003	1,030	867	970	1,009	930	941	1,012	979	955	925	
7	1号炉	912	969	972	985	986	925	916	967	947			989	930	942	953	947	939	919	951	912	902	893	894	911	
	2号炉	901	983	930	1,024	1,028	918	954	1,000	1,025	958	927	996	1,058	1,095	900	964	950	1,072	1,024	960	961	916	889	900	
8	1号炉	904	2,001	922	860	874	936	938	928	954	838	934	959	969	989	960	982	975	1,020	947	997	981	934	914	887	2:00熱電対故障
	2号炉	888	911	920	975	968	1,027	971	976	998	858	987	968	987	997	1,076	1,077	1,059	988	951	1,036	1,021	997	912	919	
9	1号炉	889	907	907	899	933	929	926	909	931	960	973	1,004	1,000	949	985	985	990	993	998	949	964	953	957	919	
	2号炉	965	970	947	1,011	1,006	996	980	991	991	982	1,004	978	1,032	1,000	1,068	1,026	1,064	962	878	960	993	1,010	969	975	
10	1号炉	941	952	920	914	918	939	912	920	947	944	958	978	969	1,000	1,003	989	986	950	952	954	949	924	1,020	933	
	2号炉	1,020	1,011	978	949	1,012	965	961	959	1,001	1,022	986	993	975	997	1,002	969	986	984	1,017	976	1,047	1,022	965	970	
11	1号炉	1,017	977	883	833	886	874	905	935	889	925	952	963	948	920	947	937	898	921	884	847	975	921	903	885	
	2号炉	1,025	1,003	1,054	993	964	1,007	973	1,004	995	990	1,034	1,004	1,019	996	1,004	1,008	1,004	1,048	1,018	1,013	972	1,048	1,004	1,008	
12	1号炉	936	933	912	921	915	899	884	901	896	919	917	916	897	893	931	914	933	947	921	939	887	944	926	960	
	2号炉	1,011	1,010	946	1,012	1,024	982	991	991	1,031	1,054	970	969	971	1,025	1,038	1,005	970	983	1,049	1,047	1,006	975	995	975	
13	1号炉	890	900	950	932	930	939	934	921	962	940	943	913	916	928	936	939	908	861	897	905	902	896	908	904	
	2号炉	1,035	1,025	1,022	950	1,031	1,049	1,036	1,005	1,018	988	970	1,019	1,078	934	921	1,075	1,093	972	966	984	989	975	1,015	980	
14	1号炉	885	822	845	886	890	903	865	845	846			899	856	859	878	852	875	900	916	901	882	890	898	880	
	2号炉	985	973	987	997	940	961	1,002	947	998	982	1,002	982	970	993	1,023	991	1,006	996					979	975	
15	1号炉	881	860	886	888	960	910	874	887	888	885	866	905	937	922	851	940	884	934	910	927	896	924	905	912	
	2号炉	964	966	971	957	1,017	1,054	1,010	972	978	892	940	1,028	1,088	1,051	1,019	1,031	944	1,047	1,010	941	968	1,026	949	1,024	

11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	946	930	988	928	897	909	915	932	925	934	926	868	849	896	897	916	913	957	948	958	949	940	902	922	
	2号炉	927	980	1,074	1,007	974	955	1,036	980	1,000	1,054	1,050	977	966	979	934	949	971	1,021	951	1,004	944	986	999	1,018	
17	1号炉	918	940	922	925	954	909	906	914	943																定常運転～立ち下げ
	2号炉	963	968	1,005	967	1,036	959	981	980	967	957	1,010	936	989	1,018	1,016	995	1,027	1,013	960	943	1,008	969	994	1,016	
18	1号炉																									休炉
	2号炉	954	1,048	1,038	995	1,035	1,034	979	955	929	1,037	951	1,009	1,023	1,012	970	939	1,028	998	981		994	981	1,003	1,003	
19	1号炉																									休炉
	2号炉	1,055	1,039	940	974	999	1,071	971	993	987	1,026	967	1,014	1,008	973	957	957	989	891	970	997	973	983	955	942	
20	1号炉																									休炉
	2号炉	952	962	961	944	1,001	1,015	989	1,023	980	967	862	892	1,045	983	978	997	958	1,003	980	1,013	949	934	962	942	
21	1号炉																									休炉
	2号炉	991	1,014	1,002	973	955	952	932	836				816	785	997	1,075	1,025	917						990	973	11:45～12:49給じん停止
22	1号炉																									休炉
	2号炉	980	934	951	963	992	898	894	916	960	766	946	1,018	992	1,001	1,005	965	1,017	992	1,010	1,007	1,057	936	962	976	9:01～9:31給じん停止
23	1号炉																									休炉
	2号炉	1,002	979	987	976	1,006	961	991	976	1,046	1,012	1,049	997	988	925	896	937	1,043	950	967	1,036	1,020	984	1,012	973	
24	1号炉																									休炉
	2号炉	1,022	994	1,006	1,049	1,086	951	894	960	942	953	1,045	1,022	1,081	1,080	1,036	954	996	986	928	1,033	974	983	1,007	1,024	
25	1号炉																									休炉
	2号炉	1,034	1,021	1,008	1,009	1,072	1,054	1,023	1,032	1,029	994	940	922	946	985	966	978	932	938	969	949	945	1,019	955	977	
26	1号炉																									休炉
	2号炉	930	1,010	982	1,025	1,020	985	981	959	1,006	985	932	974	977	999	981	987	1,005	951	1,030	995	922	984	937	986	
27	1号炉																									休炉
	2号炉	1,052	944	941	991	1,000	995	979	963	1,026	988	1,011	1,002	1,049	987	963	978	973	996	947	984	947	1,016	999	990	
28	1号炉																									休炉
	2号炉	934	969	973	1,030	950	982	976	952	977	986	931	948	942	984	955	988	939	984			1,027	954	942	943	
29	1号炉																									休炉
	2号炉	962	993	959	957	969	949	905	991	944	810	979	945	955	982	964	983	991	975	948	976	949	965	985	962	
30	1号炉																									休炉
	2号炉	962	938	902	960	948	973	1,014	962	940	900	957	989	951	958	991	955	1,020	1,016	1,013	976	926	909	936	971	

12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	978	919	941	900	973	942	980	936	973	915	959	938	938	987	958	960	966	986	989	934	965	988	991	966	
	2号炉																									休炉
17	1号炉	957	1,004	1,014	927	1,008	1,025	968	1,012	965	981	973	946	989	1,005	979	991	987	1,037	1,061	969	1,004	1,030	1,056	970	
	2号炉																									休炉
18	1号炉	923	1,032	1,025	1,072	1,049	1,045	999	1,005	997	930	933	958	991	1,005	989	980	932	971	979	956	944	995	957	969	
	2号炉																									休炉
19	1号炉	954	1,018	984	994	979	969	990	972	958	938	927	912	983	1,002	998	984	976	872				964	910	911	
	2号炉																									休炉
20	1号炉	899	919	972	960	948	931	944	944	950	855	948	921	943	1,017	1,037	1,041	995	958	933	934	980	973	955	918	
	2号炉																									休炉
21	1号炉	1,003	973	934	922	911	939	967	980	981	960	985	967	1,010	961	947	960	958	951	948	955	1,022	985	994	987	
	2号炉																									休炉
22	1号炉	1,005	1,003	977	958	963	983	967	935	914	999	999	948	965	962	1,039	1,036	943	998	1,010	1,039	983	953	1,015	1,021	
	2号炉																									休炉
23	1号炉	966	989	949	957	989	925	899	899	916	946	973	920	949	963	969	958	960	931	972	962	1,013	996	970	1,003	
	2号炉																									休炉
24	1号炉	950	960	958	993	957	950	948	912	907	938	952	934	906	946	967	987	971	971	989	1,008	1,007	986	986	992	
	2号炉																									休炉
25	1号炉	995	1,008	1,024	960	963	936	976	907	902	936	986	954	961	934	919	922	954	973	951	947	918	952	957	918	
	2号炉															806	974	924	831	826	926	944	906	941	897	立ち上げ～定常運転
26	1号炉	950	933	888	867	863	881	945	922	907						800	1,008	954	927	925	939	982	950	928		
	2号炉	939	948	926	899	892	915	916	960	838	954	988	973	974	942	946	933	965	923	911	916	932	917	953	929	
27	1号炉	973	1,017	1,026	1,000	1,003	996	1,020	1,012	981	862	1,007	992	1,005	1,035	979	1,022	1,014	988	992	969	1,020	935	994	981	
	2号炉	1,008	982	978	936	899	969	1,027	995	960	914	913	947	915	971	989	961	927	944	969	911	1,011	947	966	927	
28	1号炉	896	1,009	1,084	1,017	972	965	1,004	1,008	1,030	977	953	961	978	1,002	983	970	989	976	935	920	936	948	898	885	
	2号炉	899	978	977	969	979	889	925	973	965	901	952	942	940	921	903	913	945	938	907	902	950	894	1,013	922	
29	1号炉	881	923	927	920	935	986	894	1,009	963	982	983	961	1,000	983	997	852	991	1,007	1,012	995	1,005	938	976	953	
	2号炉	921	960	938	936	930	988	978	978	941	913	955	922	930	957	963	868	937	927	924	952	957	960	919	895	
30	1号炉	881	989	893	945	932	971	940	983	1,013	1,011	1,074	1,056	848		566	1,074	733	878	918	977	937	959	920	904	12:11～14:55、 16:02～17:24給じん停止
	2号炉	889	995	1,006	963	958	971	957	949	974	951	892	890	1,119	1,079	878	907	1,116	936	1,022	967	1,063	982	991	966	
31	1号炉	905	975	968	977	954	938	964	912	983	981	1,000	897	904	901	987	989	966	895	947	897	894	915	983	932	
	2号炉	978	968	995	1,058	995	996	1,023	978	959	981	986	937	927	983	999	1,017	1,001	920	1,026	991	996	1,022	1,045	972	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成30年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	943	922	952	952	988	946	974	982	979	986	1,019	952	943	986	1,006	1,030	970	955	969	1,001	965	936	1,018	1,013	
	2号炉	1,029	994	992	990	1,016	1,011	1,069	988	1,021	1,027	1,050	983	969	1,017	1,024	1,040	997	931	1,021	1,053	977	1,016	1,051	1,055	
2	1号炉	1,000	1,008	928	942	916	917	949	936	951									841	965	912	934	876	873	925	
	2号炉	1,047	1,066	933	939	948	1,044	996	1,023	1,008	1,006	982	968	1,009	1,017	982	939	960	905				1,020	956	956	
3	1号炉	881	928	882	966	947	960	916	983	910	805					983	987	929	975	1,018	961	985	927	942		
	2号炉	942	966	962	990	972	1,047	945	1,048	911	892	976	923	967	1,008	1,031	950	1,024	1,009	1,017	1,058	996	968	952	983	
4	1号炉	935	934	897	981	955	923	960	866	962	890	896	902	948	984	1,000	932	990	1,004	889	936	1,003	925	981	970	
	2号炉	1,021	998	984	1,010	986	1,008	1,022	977	977	952	981	1,016	1,024	1,045	1,014	932	1,076	1,004	1,019	1,022	1,080	1,006	1,060	1,055	
5	1号炉	881	880	950	987	923	947	939	949	900	916	918	893	946	940	903	923	967	920	897	863	973	961	958	946	
	2号炉	931	956	1,011	1,035	979	994	1,020	996	962	967	1,028	1,047	1,015	1,002	1,060	1,048	952	979	998	998	1,021	1,010	1,005	1,040	
6	1号炉	941	956	944	971	998	941	975	966	978	935	934	950	973	993	924	986	1,016	1,019	1,058	916	946	985	977	924	
	2号炉	986	995	1,053	1,008	939	987	1,032	1,020	944	993	974	1,037	948	972	1,042	1,008	960	1,024	996	1,025	984	954	1,038	957	
7	1号炉	962	993	1,032	929	957	940	1,023	978	1,053	955	964	942	930	980	971	941	910	966	823	958	942	970	1,013	947	
	2号炉	992	1,033	945	968	957	978	1,044	998	1,032	942	993	992	981	982	1,004	985	955	1,015	1,011	975	965	1,020	985	985	
8	1号炉	927	937	965	966	930	913	868	978	999	1,071	926	961	964	940	977	952	925	938	953	934	897	914	925	900	
	2号炉	968	1,032	998	941	959	987	1,033	966	1,027	1,026	999	965	1,014	960	974	942	942	1,023	966	949	958	976	1,002	988	
9	1号炉	918	903	885	910	927	925	927	921	899						677	860	1,053	971	935	945	923	987	977	959	8:35~14:43給じん停止
	2号炉	980	976	909	985	960	1,023	1,024	937	997	995	1,036	972	998	999	981	980	981	985				1,008	1,031	922	
10	1号炉	959	985	965	988	938	1,004	1,016	1,040	951	1,005	998	1,011	987	935	954	990	887	902	650						定常運転~立ち下げ
	2号炉	895	980	969	962	938	974	1,009	1,033	953	943	1,021	1,036	1,067	1,052	1,062	1,036	940	983	1,027	1,002	999	947	1,009	917	
11	1号炉																									休炉
	2号炉	975	991	916	881	908	924	912	1,021	1,018	1,046	1,021	899	926	934	917	916	948	985	1,000	1,023	973	973	976	941	
12	1号炉																									休炉
	2号炉	956	1,013	941	937	960	931	928	988	959	921	920	963	995	1,079	1,021	1,051	1,005	1,004	994	1,007	1,028	1,016	996	1,043	
13	1号炉																									休炉
	2号炉	1,058	1,015	988	1,032	1,014	1,021	1,046	1,020	1,036	1,075	1,022	1,015	968	955	985	1,041	1,023	1,055	1,047	955	1,014	1,049	1,029	1,046	
14	1号炉																									休炉
	2号炉	1,024	1,049	1,000	1,050	1,055	1,002	991	969	1,030	1,028	1,040	1,029	1,002	1,044	984	1,060	991	1,023	1,017	1,016	1,073	991	1,025	1,024	
15	1号炉																									休炉
	2号炉	1,047	1,006	1,036	1,017	986	1,048	1,038	1,007	1,003	972	965	916	933	963	954	968	982	885	1,034	939	1,007	1,067	979	1,038	

1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉																									休炉
	2号炉	1,028	1,013	949	1,033	1,007	1,039	1,030	977	1,033	994	1,011	1,024	983	968	1,042	1,053	1,072	1,025				1,010	1,022	987	
17	1号炉																									休炉
	2号炉	993	1,001	993	1,014	967	1,018	1,008	997	1,006	840	988	1,030	981	936	983	996	1,058	967	992	987	1,004	1,032	1,041	1,024	
18	1号炉																									休炉
	2号炉	1,020	985	979	1,015	1,010	1,027	921	1,018	989	939	984	953	1,039	1,084	1,081	1,067	1,077	979	955	1,024	1,022	959	973	1,007	
19	1号炉																									休炉
	2号炉	970	1,025	1,046	1,009	1,020	1,057	944	971	1,055	985	972	962	956	953	950	960	982	1,032	991	965	1,005	979	987	995	
20	1号炉																									休炉
	2号炉	977	1,017	1,030	984	1,004	1,044	987	999	964	1,013	1,038	986	968	986	1,017	1,021	994	1,001	812	992	941	958	971	974	
21	1号炉																					756	942	932	881	立ち上げ～定常運転
	2号炉	999	1,003	991	1,002	999	985	962	976	979	953	934	952	978	1,027	985	965	931	935	990	966	918	953	943	957	
22	1号炉	779	949	889	867	864	889	909	901	911	873	872	863	891	886	885	888	878	909	882	865	879	891	916	940	前日23:53～0:42給じん停止
	2号炉	930	963	978	951	906	917	994	923	935	972	931	969	992	1,065	1,068	916	963	918	925	953	899	894	904	832	
23	1号炉	882	942	908	938	961	993	1,003	940	919	910	949	927	949	917	917	913	922	981	922	909	939	976	954	867	
	2号炉	886	911	906	844	959	958	945	942	896	984	1,004	954	873	878	920	893	956	862				942	910	929	
24	1号炉	866	929	888	908	896	933	923	937	947	927	930	1,003	998	994	923	927	973	975	966	926	947	910	949	975	
	2号炉	954	1,016	985	935	959	987	948	925	937	837	991	981	1,016	998	978	1,011	1,051	1,037	977	964	973	976	1,016		
25	1号炉	967	929	940	943	955	961	962	929	1,000	937	898	887	901	921	919	957	957	924	1,001	943	900	882	931	912	
	2号炉	1,007	1,045	967	989	979	954	989	977	1,000	1,037	953	921	946	899	997	987	964	953	953	958	917	949	936	923	
26	1号炉	928	930	909	921	908	977	922	940	937	856	863	866	860	901	885	877	889	924	871	862	892	897	950	993	
	2号炉	943	968	891	949	954	977	994	937	939	955	990	983	924	944	866				777	891	933	979	977	912	14:37～18:24給じん停止
27	1号炉	1,023	992	908	920	912	982	1,000	990	931	954	958	961	976	952	963	962	953	938	927	944	937	902	949	988	
	2号炉	990	1,012	901	942	954	971	904	923	953	1,028	948	965	968	939	997	978	945	965	1,000	973	1,007	968	920	935	
28	1号炉	1,076	962	1,027	987	986	998	1,031	941	935	973	947	936	932	962	962	963	940	1,000	974	971	993	945	953	985	
	2号炉	1,064	1,080	1,063	1,046	959	1,012	977	991	995	1,022	944	987	977	990	1,002	949	940	933	940	995	1,035	1,003	975	972	
29	1号炉	923	932	920	935	985	890	942	1,004	941	979	958	971	914	887	942	909	932	920	975	932	979	939	937	968	
	2号炉	952	958	955	968	976	1,033	1,036	981	964	842	901	934	945	953	970	1,021	948	994	981	1,033	1,027	941	981	977	
30	1号炉	929	937	921	960	918	894	955	924	898							893	909	915	902	906	987	993	931	932	
	2号炉	984	1,042	1,053	944	932	999	1,018	957	1,017	932	992	949	970	961	962	993	1,001	943			991	962	964	935	
31	1号炉	932	979	1,009	914	930	943	972	992	1,003					909	917	932	1,024	959	965	995	984	941	917	913	
	2号炉	946	956	984	946	965	981	976	1,033	1,043	875	1,140	1,061	980	997	989	998	986	1,027	1,051	996	1,025	965	1,005	997	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成30年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	943	951	917	928	914	927	925	934	939	894	918	889	898	891	909	905	926	943	931	985	961	950	940	942	
	2号炉	1,024	974	1,029	1,027	1,001	1,014	1,024	1,028	1,038	1,000	979	967	984	1,006	1,045	1,034	1,074	1,071	1,029	951	1,047	1,060	1,074	1,072	
2	1号炉	971	926	961	944	930	956	972	1,022	1,007	957	941	944	930	957	945	988	957	944	1,007	964	957	900	931	986	
	2号炉	1,079	896	996	1,008	1,008	1,031	1,016	1,027	1,055	1,088	993	951	970	963	932	950	930	982	1,054	941	1,011	978	1,005	947	
3	1号炉	945	944	919	914	945	964	959	964	964	941	1,008	990	966	1,022	998	925	963	927	943	913	895	903	1,005	966	
	2号炉	1,013	1,008	948	947	970	1,030	940	1,029	1,017	1,022	998	1,015	1,023	1,003	1,052	1,011	981	1,005	987	1,039	1,025	1,013	987	1,021	
4	1号炉	969	989	933	930	905	906	922	924	950	958	926	951	930	884	854	878	901	961	913	928	911	915	893	896	
	2号炉	899	1,013	961	971	995	918	951	940	966	963	973	974	943	949	908	952	950	965	1,042	969	1,000	972	981	906	
5	1号炉	882	887	890	888	905	903	900	921	915	884	880	886	897	854	883	887	882	884	879	889	889	949	926	896	
	2号炉	987	900	897	945	979	939	954	963	907	960	955	973	1,029	1,007	982	991	1,043	1,009	919	950	971	937	978	970	
6	1号炉	894	880	895	886	901	895	913	963	839								822	924	988	930	884	891	856	902	
	2号炉	967	963	983	978	970	1,001	996	1,032	1,102	738				689	992	983	980	888			1,009	952	962	907	9:25~13:25給じん停止
7	1号炉	898	869	901	859	902	887	867	866	958	867	945	938	898	910	920	915	927	905	906	916	901	990	947	959	
	2号炉	952	985	993	983	1,018	973	1,025	1,015	954	752	913	971	990	1,001	913	956	948	990	992	967	972	1,055	962	991	9:07~9:36給じん停止
8	1号炉	987	983	960	1,016	1,027	1,016	981	1,002	939	931	915	902	912	913	944	908	879	957	889	917	906	884	862	925	
	2号炉	1,008	1,043	1,052	1,017	1,069	976	1,017	1,016	1,017	1,070	1,094	1,004	1,009	1,024	982	933	940	1,018	951	1,024	1,008	977	933	995	
9	1号炉	907	897	875	902	920	880	914	925	897	888	886	890	899	877	890	886	909	889	906	928	925	931	907	929	
	2号炉	935	891	801	1,004	942	967	983	971	1,000	905	949	916	912	891	908	896	897	918	884	860	879	834	926	889	
10	1号炉	879	984	886	986	954	960	957	940	966	949	936	901	884	910	939	924	919	950	928	943	958	931	916	919	
	2号炉	860	932			931	1,002	957	813	919	985	976	957	757					943	929	957	1,008	998	955	952	12:01~17:01給じん停止
11	1号炉	900	902	908	780	925	908	949	896	924	947	976	1,033	978	986	917	951	945	932	923	921	919	897	933	894	2:49~3:25給じん停止
	2号炉	925	917	968	943	978	745	906	923	958	973	1,060	1,056	946	998	947	947	945	976	993	945	961	950	933	962	5:13~6:11給じん停止
12	1号炉	944	847	877	918	928	888	905	885	899	884	880	894	860	869	897	894	885	885	901	960	922	679			21:15~翌日1:05給じん停止
	2号炉	950	952	950	927	937	939	908	914	913	914	897	910	897	911	929	770	866	919	938	892	894	902	846	852	15:10~15:55給じん停止
13	1号炉		843	853	871	863	913	979	906	875	898	880	871	901	858	871	899	909	955	960	879		817	860	865	
	2号炉	863	854	888	868	854	895	934	913	879	917	899	894	894	862	903	901	906	909	797	785	942	892	910	932	18:07~19:44給じん停止
14	1号炉	892	877	847	885	899	933	908	887	866						913	905	902	936	870	872	881	895	847	956	
	2号炉	1,008	988	990	1,012	1,001	976	923	936	901	914	941	982	952	940	915	940	939	985			756	967	930	919	17:11~20:37給じん停止
15	1号炉	835	868	873	873	877	864	874	898	884	911	814	881	876	861	887	875	872	877	870	894	877	929	894	930	
	2号炉	964	936	992	941	935	941	998	954	970	954	825	1,006	938	860	861	940	936	949	979	935	931	922	879	932	

3月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考		
16	1号炉																										休炉	
	2号炉																											休炉
17	1号炉																											休炉
	2号炉																											休炉
18	1号炉																											休炉
	2号炉																											休炉
19	1号炉																								964	905	立ち上げ～定常運転	
	2号炉																											休炉
20	1号炉	914	904	921	912	920	926	915	895	922	943	939	932	922	922	895	919	897	896	927	957	927	903	907	895			
	2号炉																											休炉
21	1号炉	928	922	927	919	928	878	897	940	953	917	916	945	934	956	977	942	966	948	976	989	1,006	963	995	998			
	2号炉																											休炉
22	1号炉	1,007	978	1,006	957	973	977	930	950	969	965	1,011	887	990	913	903	906	935	982	966	965	973	985	1,002	967			
	2号炉																											休炉
23	1号炉	962	962	970	1,019	999	932	953	942	947	998	945	955	933	911	892	904	901	915	922	896	936	969	958	982			
	2号炉								873	923	995	917	937	938	915	956	965	955	898	912	898	896	882	892	933		立ち上げ～定常運転	
24	1号炉	930	946	988	981	929	893	932	903	923	988	973	961	972	965	943	1,025	929	944	1,037	1,024	1,012	967	1,019	1,018			
	2号炉	939	918	907	932	926	879	888	892	914	924	921	890	957	924	979	989	991	972	935	913	965	1,000	980	952			
25	1号炉	1,019	1,133	1,102	985	917	948	919	939	952	889	916	928	937	918	953	948	931	952	983	946	923	965	1,002	944			
	2号炉	918	947	975	959	975	942	965	1,007	950	909	925	930	965	939	903	931	946	960	947	921	916	988	936	942			
26	1号炉	940	1,002	984	957	947	945	941	894	894	974	984	993	998	1,010	982	978	1,003	1,026	1,118	1,094	975	857	969	914			
	2号炉	905	989	1,009	1,000	953	1,023	973	919	916	997	997	1,010	992	942	1,004	979	1,034	993	1,137	1,057	1,046	872	974	968			
27	1号炉	915	936	994	949	964	924	905	961	901			911	917	933	902	929	963	980	956	967	971	944	923	953			
	2号炉	949	932	1,026	940	952	936	954	998	980	922	964	942	942	981	976	988	1,004	1,016	1,000	942	954	975	904	878			
28	1号炉	987	937	933	890	902	929	916	958	951	925		868	975	1,019	983	905	909	971	941	949	936	927	974	1,011			
	2号炉	1,014	956	964	931	948	892	870	943	959	931	975	921	958	982	980	921	910	959	961	945	938	939	986	1,025			
29	1号炉	969	917	981	900	930	926	936	983	935	911	922	931	878	886	932	928	911	911	903	859	927	947	952	891			
	2号炉	924	984	913	913	928	927	913	923	896	928	900	893	886	919	914	927	921	923	973	928	932	981	983	900			
30	1号炉	890	930	906	958	920	987	962	896	947	921	977	1,022	1,035	942	972	940	1,008	961	925	989	924	926	923	939			
	2号炉	923	946	1,005	890	937	1,016	999	978	986					877	867	874	886	949	885	934	992	988	956	950			
31	1号炉	1,000	975	1,003	996	924	1,024	1,004	981	950	913	1,000	1,017	1,018	1,004	958	1,017	1,010	1,033	898	988	1,013	1,074	898	873			
	2号炉	973	983	964	937	942	979	900	945	924	954	891	945	915	911	859	905	920	935	935	986	987	1,030	901	876			