

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成30年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	960	914	938	969	986	981	909	927	942	914	1,008	911	992	981	975	925	959	992	948	875	909	910	896	956	
	2号炉	915	895	945	997	971	921	862	869	931	918	962	985	936	912	949	926	950	1,013	990	1,012	927	900	865		
2	1号炉	1,024	974	1,009	1,010	954	930	962	926	956	948	1,025	925	1,022	931	977	964	989	937	929	909	899	956	989	1,084	
	2号炉	812	897	1,014	1,003	961	842	948	890	943	1,002	933	908	941	975	898	889	974	934	779		709	927	953	992	18:01~20:35給じん停止
3	1号炉	1082	976	927	901	910	886	932	888	940	1,003	1,011	1,081	1,007	984	979	971	974				960	962	954	958	
	2号炉	980	932	886	874	927	922	897	858	876	1,075				930	977	994	962	979	1,005	962	968	965	967	940	
4	1号炉	973	1041	996	958	918	1,004	961	955	944	858	961	1,005	1,043	1,019	1,027	995	985	1,079	923	822	989	996	1,016	925	
	2号炉	943	977	945	937	907	959	927	991	959	740	948	970	979	987	948	936	926	986	935	940	904	969	949	894	9:05~9:44給じん停止
5	1号炉	941	978	943	1,011	1,030	908	982	1,035	1,005	932	988	937	935	952	958	994	962	954	970	949	780	845	928	988	19:49~20:37給じん停止
	2号炉	908	947	969	1,011	970	938	948	934	924	938	967	902	900	934	919	882	900	952	883	1,011	975	987	991	956	
6	1号炉	957	975	934	960	987	968	1,019	922	983	968	969	964	993	1,007	975	1,022	1,075	1,095	929	880	862	921	915	941	
	2号炉	979	997	1,000	963	988	989	989	959	963	1,007	969	1,014	975	1,033	995	993	1,032	1,075	997	941	894	908	930	906	
7	1号炉	909	930	1,100	986	940	934	901	1,003	983	1,048	939	922	925	1,045	1,030	992	1,000	991	1,039	966	960	949	984	1,017	
	2号炉	893	948	1,032	979	979	898	907	930	926	1,030	1,011	939	1,007	1,040	1,049	941	990	978	969	945	924	946	952	970	
8	1号炉	1,013	974	882	979	1,064	1,015	938	1,027	996	1,007	1,004	984	993	993	999	1,025	1,018	909	962	945	966	982	1,006	980	
	2号炉	932	904	924	1,005	1,039	1,012	911	1,007	953	972	964	979	948	945	965	982	971	946	958	937	917	930	934	945	
9	1号炉	972	994	990	961	973	1,046	1,055	985	980	1,001	969	955	1,001	956	989	937	969	970	991	1,006	981	969	1,009	952	
	2号炉	932	924	919	925	925	997	1,013	980	965	948	984	940	938	910	943	934	943	919	945	951	913	941	946	950	
10	1号炉	972	1,035	957	967	1,020	1,022	945	963	929			970	930	938	987	1,016	979	1,012	909	942	921	960	958	941	
	2号炉	921	917	903	906	917	959	912	922	916	950	981	970	923	886	887	916	907	880				903	896	877	
11	1号炉	965	981	949	926	930	938	915	918	953	810	935	923	920	938	956	1,010	960	899	910	1,013	936	1,011	935	927	
	2号炉	891	890	907	945	929	928	894	901	942	851	998	967	942	953	943	965	997	937	972	990	924	936	909	931	
12	1号炉	964	972	974	985	939	986	970	904	976	1,027	997	900	947	875	940	971	966	992	973	963	960	955	977	967	
	2号炉	931	892	923	875	895	915	870	891	924	957	954	922	942	911	984	948	997	939	944	948	981	890	972	950	
13	1号炉	941	957	808	947	920	926	1,025	970	1,028	982	697	563	917	930	949	1,005	977	955	925	909	938	955	972	987	10:27~11:51給じん停止
	2号炉	959	926	971	908	920	918	913	945	1,008	960	917	924	921	887	917	953	975	1,035	983	927	925	907	909	913	
14	1号炉	985	991	975	933	970	1,010	1,010	971	988	1,028	927	946	987	1,028	954	929	960	974	1,009	1,030	1,030	1,074	1,027	1,002	
	2号炉	937	978	953	934	917	942	951	973	963	947	913	880	889	951	956	888	958	913	1,030	1,044	1,023	1,025	1,010	961	
15	1号炉	1,001	942	964	1,019	1,013	959	1,000	1,037	987	976	949	953	933	945	944	904	952	919	947	918	916	964	932	930	
	2号炉	923	909	916	915	948	971	955	944	987	1,037	938	954	953	928	944	888	904	935	933	965	909	919	959	947	

4月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	969	1,005	966	969	991	972	1,006	985	1,005	1,009	964	966	944	951	953	911	930	1,017	970	934	938	940	1,001	964	
	2号炉	977	1,014	924	953	947	994	955	915	987	936	948	950	967	982	898	882	968	956	946	871	886	868	931	893	
17	1号炉	996	1,029	1,013	958	970	953	946	970	977				919	959	989	931	988	953	937	934	940	915	894	907	
	2号炉	924	957	932	906	922	925	879	917	942	961	875	924	921	895	920	862	872	832			980	884	902	900	
18	1号炉	918	958	956	957	955	979	973	1,001	933	879	975	965	974	1,004	998	996	979	983	941	954	934	937	904	881	
	2号炉	932	969	1,008	966	970	980	1,012	969	978	777	987	966	998	1,069	1,030	1,004	983	1,022	991	973	951	950	931	967	9:07~9:35給じん停止
19	1号炉	911	925	937	948	1,001	971	968	987	975	1,004	977	960	1,003	1,017	988	957	954	995	998	993	1,028	1,013	921	920	
	2号炉	954	962	1,007	997	988	952	939	939	956	909	972	969	1,012	982	943	1,044	980	999	959	998	1,039	1,042	931	994	
20	1号炉	1,005	1,033	835		938	906	954	951	956	988	934	972	963	945	997	875	968	956	926	943	916	912	977	1,075	
	2号炉	965	1,092	901	837	986	930	1,033	981	950	963	939	957	966	995	978	953	1,000	988	940	952	959	986	1,011	992	
21	1号炉	954	958	944	993	938	964	876	910	906	946	967	984	955	945	975	902	955	967	977	1,013	931	929	988	974	
	2号炉	992	1,032	961	962	865	981	982	941	893	993	943	902	1,033	990	968	909	982	984	937	1,033	997	1,003	997	955	
22	1号炉	931	907	845	866	861	889	957	916	929	902	962	962	983	961	917	924	936	969	937	1,016	960	1,005	966	989	
	2号炉	980	930	930	991	927	957	998	1,001	995	962		956	940	919	941	925	917	965	952	1,008	1,006	982	980	927	
23	1号炉	941	929	911	931	994	1,009	969	908	942	955	939	886	879	888	878	872	878	900	948	984	997	934	912	928	
	2号炉	906	1,049	952	975	998	1,008	1,002	980	988	976	962	981	957	973	920	952	963	950	901	1,028	1,057	962	920	921	
24	1号炉	899	936	971	905	890	892	873	903	861	889	923	953	888	925	906	861	895	907	902	895	890	903	921	924	
	2号炉	890	898	957	977	933	930	946	931	891			966	932	986	947	979	992	994	940	949	924	929	950	967	
25	1号炉	904	899	927	903	920	974	951	820	803	915	943	870	894	873	924	934	949	845	870	893	933	930	919	948	
	2号炉	907	899	922	913	919	922	941	903	939	874	1,005	917	941	931	905	957	967	896	909	863	886	885	934	943	
26	1号炉	957	882		902	924	916	986	933	985	914	930	953	905	907	898	844	872	886	897	1,025	981	921	907	927	
	2号炉	957	990	934	898	950	887	889	1,017	935	1,002	971	927	919	914	915	904	943	914	924	912	927	876	902	936	
27	1号炉	888	888	901	913	977	958	982	916	860																定常運転~立ち下げ
	2号炉	851	874	912	879	914	1,024	963	944	1,009	917	1,009	899	891	864	908	907	917	908	986	951	941	946	982	972	
28	1号炉																									休炉
	2号炉	998	998	828	842	962	950	903	949	888	892	934	941	929	888	866	852	888	872	899	923	921	915	864	896	
29	1号炉																									休炉
	2号炉	914	914		976	889	870	908	886	920	939	968	944	989	907	906	968	891	967	998	939	935	973	963	919	
30	1号炉																									休炉
	2号炉	939	973	960	956	924	942	945	925	911	929	948	873	917	894	893	874	913	979	971	990	970	1,037	948	933	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成30年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	942	918	946	949	956	954	912	932	918	962	962	980	961	937	953	947	958	954			904	916	945	965	
2	1号炉																									休炉
	2号炉	995	936	895	943	850	891	920	971	974	789	1,008	1,003	1,044	1,006	1,005	991	914	992	1,004	1,009	978	961	994	989	8:54~9:24給じん停止
3	1号炉																									休炉
	2号炉	963	953	1,026	962	907	901	947	894	967	924	996	976	974	949	920	944	944	986	988	984	987	994	959	928	
4	1号炉																									休炉
	2号炉	957	812	1,072	964	912	941	940	955	927	950	944	874	917	980	1,036	1,003	965	1,016	1,017	968	956	984	970	1,003	
5	1号炉																									休炉
	2号炉	1,005	915	922	935	1,010	946	940	968	996	997	1,005	970	890	961	942	1,027	999	1,007	964	1,000	1,028	965	940	975	
6	1号炉																									休炉
	2号炉	1,055	963	969	946	1,004	1,033	961	1,035	975			962	949	967	959	917	961	1,001	1,002	999	1,016	1,021	972	1,001	
7	1号炉																									休炉
	2号炉	967	933	953	938	994	979	1,001	939	904	961	959	947	907	968	971	970	920	914	936	931	929	921	994	922	
8	1号炉																									休炉
	2号炉	893	886	937	903	886	927	919	879	944	920	922	921	950	937	935	899	932	923		960	933	901	891	929	
9	1号炉																									休炉
	2号炉	913	915	883	885	886	886	887	894	945	822	943	922	946	964	953	958	948	926	945	928	911	892	942	948	
10	1号炉																									休炉
	2号炉	957	941	929	930	934	912	878	914	931	932	941	930	911	916	930	932	908	963	966	925	881	909	879	949	
11	1号炉																									休炉
	2号炉	927	916	881	903	916	932	950	928	939	926	960	938	945	942	918	891	973	969	932	920	881	905	902	966	
12	1号炉																									休炉
	2号炉	909	910	932	929	964	930	903	959	938	932	920	898	970	1,010	957	987	1,001	1,002	986	940	968	1,011	1,010	1,001	
13	1号炉																									休炉
	2号炉	999	942	1,041	927	934	969	979	915	953	905	941	901	881	967	899	930	912	900	914	893	913	923	951	910	
14	1号炉	886	891	881	897	883	912	951	947	935	958	917	952	935	926	901	868	881	893	952	1,005	1,017	940	917	1,016	立ち上げ~定常運転
	2号炉	899	947	864	902	930	895	928	1,004	975	974	991	958	1,055	1,015	939	916	984	975	1,047	1,010	983	984	968	1,022	
15	1号炉	958	947	863	873	884	883	931	976	976	863	897	972	942	950	962	923	898	915	930	921	939	963	969	911	
	2号炉	1,005	846	977	938	944	918	923	1,006	1,018	961	971	971	967	1,035	997	964	973	958	896	915	930	1,006	939	969	

5月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	926	948	906	897	912	953	903	958	972	982	974	937	963	893	768	891	913	907	932	946	948	1,001	1,011	986	13:40~14:44 14:46~15:04 給じん停止
	2号炉	936	915	939	901	933	968	939	975	994	1,053	1,013	1,010	987	989	927		834	959	970	1,003	959	981	983	934	
17	1号炉	910	955	936	939	876	945	953	900	902	916	900	883	927	930	955	969	955	928	910	932	905	890	920	939	
	2号炉	902	897	960	987	952	1,002	1,005	946	832	941	986	1,011	1,058	1,049	1,018	922	1,036	1,041	958	939	947	896	943	978	
18	1号炉	952	963	961	906	923	943	914	883	910	974	1017	990	928	927	914	901	921	927	944	915	922	920	888	902	定常運転~立ち下げ
	2号炉	957	1,017	1000	903	875	1003	1002	898	968																
19	1号炉	924	904	872	908	945	959	948	930	932	943	938	940	925	927	953	983	956	952	945	987	950	948	946	932	休炉
	2号炉																									
20	1号炉	920	928	918	943	953	924	926	916	925	950	910	898	892	922	895	909	896	895	882	925	940	972	898	856	休炉
	2号炉																									
21	1号炉	915	903	908	858	875	914	887	899	898	932	928	915	892	903	899	873	880	879	896	933	955	886	943	920	休炉
	2号炉																									
22	1号炉	936	917	915	931	882	881	891	909	908	924	903	919	891	940	899	883	878	876		904	880	879	891	876	休炉
	2号炉																									
23	1号炉	893	852	846	892	876	884	868	868	826	893	878	888	923	884	884	931	886	902	899	906	896	915	928	867	休炉
	2号炉																									
24	1号炉	864	863	893	878	893	883	878	824	881	882	919	940	907	932	941	916	918	940	938	964	939	927	935	911	休炉
	2号炉																									
25	1号炉	940	910	922	969	926	943	923	935	934	935	898	913	930	946	899	907	927	914	963	957	931	955	942	907	休炉
	2号炉																									
26	1号炉	920	929	935	950	943	947	916	941	933	938	934	922	900	906	922	911	906	908	934	902	907	933	914	935	立ち上げ~定常運転 定常運転~立ち下げ
	2号炉												844	916	921	905	917	895	911	909	932	894				
27	1号炉	907	933	844		890	879	897	903	897	922	884	926	887	916	977	929	875	919	918	928	923	905	877	931	休炉
	2号炉																									
28	1号炉	930	907	924	902	905	890	892	896	899	934	908	889	899	882	880	865	881	901	903	904	893	904	915	928	休炉
	2号炉																									
29	1号炉	918	919	890	885	899	928	926	880	880	890	907	912	916	953	890	835	890	866		883	833	842	883	879	立ち上げ~定常運転 18:25~19:55給じん停止
	2号炉															801	901	921	914	837	783	878	910	909	893	
30	1号炉	867	885	916	937	903	958	945	957	958	851	963	984	1,002	938	1,013	981	979	954	964	881	902	927	933	879	7:06~9:14給じん停止
	2号炉	878	930	916	933	931	929	962	778		838	943	978	975	995	991	982	981	972	962	967	998	982	947	905	
31	1号炉	911	871	890	923	921	943	919	956	957	938	962	953	970	937	965	930	989	996	990	949	926	934	942	934	
	2号炉	983	975	942	899	933	942	948	930	931	952	955	970	993	932	998	987	959	970	971	966	934	977	945	903	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成30年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	906	920	944	914	916	927	935	960	923	971	934	934	966	960	966	944	957	941	923	900	963	919	979	972	
	2号炉	922	952	981	977	958	965	986	954	943	986	987	990	976	1008	979	993	1008	940	970	936	941	994	979	992	
2	1号炉	921	978	961	970	970	936	945	944	951	935	987	941	970	978	961	978	970	994	962	936	977	947	948	935	
	2号炉	966	986	917	949	923	941	947	970	934	938	947	952	956	925	933	923	930	937	991	947	972	965	968	993	
3	1号炉	953	930	909	922	875	910	995	980	961	916	902	887	913	897	930	858	880	926	964	956	998	923	958	873	
	2号炉	894	982	914	925	945	895	921	967	941	967	984	943	929	949	947	968	945	983	950	957	985	890	951	934	
4	1号炉	879	899	896	924	921	922	894	922	896	906	929	922	912	916	908	906	889	917	944	922	949	920	917	895	
	2号炉	997	938	955	957	974	962	936	910	964	920	920	937	945	943	915	995	984	921	880	928	915	910	876	919	
5	1号炉	920	885	905	919	930	963	891	912	894	879	937	935	940	934	909	969	927	905	903	878	868	902	933	900	
	2号炉	911	921	692	897	928	913	886	937	850				951	916	926	980	981	963	929	945	930	921	926	921	2:08~2:45給じん停止
6	1号炉	927	902	900	912	914	904	915	912	917	827	969	933	949	989	974	973	1,000	943		937	943	934	909	914	
	2号炉	952	972	948	987	1,009	984	954	923	981	778	977	871	1,004	977	855	1,006	1,018	909	1,014	935	987	955	942	951	9:05~9:35給じん停止
7	1号炉	925	984	931	949	894	904	914	900	926	923	918	932	866	909	900	892	919	888	917	893	918	905	880	909	
	2号炉	982	968	971	960	972	967	936	945	985	1,005	978	983	1,049	966	963	978	969	941	937	957	946	1,019	978	1,035	
8	1号炉	927	909	886	955	909	891	914	890	907	924	912	939	919	918	896	916	890								定常運転~立ち下げ
	2号炉	987	1003	947	970	920	887	1,025	1,013	969	996	933	953	964	1,038	982	1,059	1,000								定常運転~立ち下げ
9	1号炉																									休炉
	2号炉																									休炉
10	1号炉																									休炉
	2号炉			863	985	923	930	954	1,004	979	953	983	1,011	981	994	1,006	996	1,003	946	915	981	958	969	893	912	立ち上げ~定常運転
11	1号炉		776	908	899	898	907	871	882	904	941	945	950	899	911	869	868	880	886	914	884	900	888	904	902	立ち上げ~定常運転
	2号炉	1,022	958	949	957	973	942	971	997	1,029	964	1,014	980	986	950	999	1,005	961	972	1,019	1,019	964	1,003	971	992	
12	1号炉	903	899	926	915	966	952	909	941	940	946	961	987	981	902	889	900	946	929	892	977	980	944	902	902	
	2号炉	950	1,009	1,029	956	990	973	948	973	979		1,081	969	1,002	965	977	950	975	993	999	1,005	1,005	964	996	965	
13	1号炉	939	956	939	925	907	923	909	875	921	810	897	895	891	946	936	934	913	971	912	922	954	976	924	903	
	2号炉	985	996	967	941	977	1,017	940	957	1,003	780	916	1,001	1,026	1,053	986	948	996	966	1,027	985	980	968	960	1,010	9:08~9:40給じん停止
14	1号炉	930	930	931	927	917	912	926	924	931	957	915	906	962	971	918	958	970	937	974	930	959	927	898	839	
	2号炉	976	1,016	1,038	1,011	978	1,014	991	1,020	973	1,052	1,016	995	980	1,030	1,018	994	973	977	1,002	1,004	971	982	939	941	
15	1号炉	932	914	877	922	902	913	949	945	926	988	924	946	940		859	965	925	829	911	912	943	981	926	910	
	2号炉	984	1007	931	942	967	959	979	976	974	1,009	994	1,010	991	1,009	1,011	979	976	964	929	949	1,069	979	997	951	

6月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	924	953	986	975	980	978	985	1,031	1,000	951	929	991	978	971	961	943	974	998	1,031	1,038	998	965	982	1,043	
	2号炉	994	1,019	999	1,020	1,009	1,012	1,015	1,050	1,031	967	932	983	1,013	1,009	986	971	1,001	1,036	1,111	1,026	989	1,037		964	
17	1号炉	965	977	980	975	1,000	965	920	1,017	977	928	937	951	912	924	963	979	930	945	951	964	949	939	941	950	
	2号炉	1,027	1,036	959	989	1,029	957	1,008	916	981	979	942	912	934	957	971	948	920	987	989	1,034	1,011	966	943	952	
18	1号炉	976	1,010	950	906	933	923	936	913	908	944	941	932	930	923	962	972	918	923	915	928	930	906	878	864	
	2号炉	945	1,003	954	933	967	922	995	987	987	942	935	938	958	1,068	988	975	993	937	913	895	936	991	933	913	
19	1号炉	864	869	885	942	888	1,002	937	971	913	895	920	915	901	915	871	852	871	885	925	889	860	885	861	924	
	2号炉	931	929	982	939	999	1,014	945	1,011	1,017	964	1,006	975	951	952	942	918	975	942		980	911	911	911	933	
20	1号炉	923	927	938	936	938	944	946	977	877	777	929	913	926	942	892	895	929	917	902	898	924	892	869	923	9:13~9:34給じん停止
	2号炉	890	942	972	955	938	968	925	972	891	835	970	1,008	970	944	996	962	1,020	954	964	964	985	1,002	967	948	
21	1号炉	915	940	901	922	956	944	902	941	956	931	908	942	894	932	982	965	953	974	874	880	887	882	942	892	
	2号炉	967	945	953	967	972	992	995	1,032	996	1,009	1,009	1,034	1,021	1,001	984	1,000	985	1,025	971	948	993	1,018	1,011	997	
22	1号炉	985	958	931	881	941	941	1,006	977	936	931	937	905	936	956	958	947	881	922	947	948	928	896	897	887	
	2号炉	1,016	1,032	1,019	1,007	1,020	1,044	1,028	1,036	995	994	956	896	1,009	1,071	999	934	932	993	1,034	939	974	954	946	929	
23	1号炉	938	925	895	899	875	932	944	985	963	940	954	938	944	932	990	1,004	969	917	934	918	873	882	969	963	
	2号炉	959	1,005	999	977	944	959	953	1,002	989	1,023	864	971	970	989	1,025	962	986	964	945	955	926	971	939	979	
24	1号炉	936	958	947	919	918	904	957	918	958	920	911	922	911	920	913	931	938	936	967	956	941	928	985	919	
	2号炉	928	942	943	958	913	925	994	935	947	948	958	946	933	950	954	992	984	956	977	941	912	969	937	937	
25	1号炉	945	929	931	922	982	980	991	903	913	932	907	952	940	953	942	964	958	910	889	893	936	914	922	919	
	2号炉	934	945	949	921	932	913	949	901	926	918	945	963	974	944	963	947	940	883	891	881		919	909	910	
26	1号炉	916	919	923	902	883	889	901	916	884			894	885	886	893	890	942	826	872	857	885	913	934	905	8:35~11:10給じん停止
	2号炉	904	959	897	896	865	858	870	854	892	918	920	942	928	889	901	984	951	911	1,005	889	885	912	857	860	
27	1号炉	884	913	934	978	911	944	903	895	945	737	930	924	916	961	942	934	928	929	908	904	942	964	932	1,014	8:58~9:30 9:50~9:52給じん停止
	2号炉	866	912	902	914	914	881	952	873	921	750	922	943	944	949	902	959	940	925	881	893	911	988	958	975	9:18~9:58給じん停止
28	1号炉	923	942	987	997	970	911	932	920	939	1,006	954	964	958	938	943	1,023	961	937	903	905	921	900	950	915	
	2号炉	944	996	1,029	1,016	985	981	968	931	1,003	957	968	961	909	978	996	934	968	1,056	979	923	951	951	933	967	
29	1号炉	897	902	992	943	960	929	925	936	888																定常運転~立ち下げ
	2号炉	928	965	942	935	957	937	966	937	895	951	983	929	927	953	963	1,010	1,040	921	903	911	902	929	886	911	
30	1号炉																									休炉
	2号炉	915	950	902	1,003	972	920	913	987	945	946	972	947	1,025	1,011	1,002	971	931	932	922	897	946	992	986	1,017	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成30年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	976	966	982	975	1,018	957	920	995	1,045	909	1,006	964	994	975	986	964	942	931	976	984	994	997	974	1,017	
2	1号炉																									休炉
	2号炉	984	1019	975	951	941	987	992	1,004	993	984	984	994	979	994	986	963	942	944	946	961	955	950	974	941	
3	1号炉																									休炉
	2号炉	972	949	979	922	914	919	899	951	965	982	974	1,009	1,016	927	892	955	975	915	1,030	981	879	916	937	925	
4	1号炉																									休炉
	2号炉	965	961	920	962	909	880	892	892	771	878	923	971	965	954	938	963	944	933	927	968	992	924	962	916	8:36~9:06給じん停止
5	1号炉																									休炉
	2号炉	975	930	936	921	938	929	925	906	924	928	916	933	928	917	905	956	926	905	930	929	924	932	907	918	
6	1号炉																									休炉
	2号炉	933	907	913	898	915	918	887	875	905	896	898	875	930	913	884	912	897	955	938	925	926	959	933	914	
7	1号炉										806		837	867	869	885	869	873	863	869	859	876	887	883	立ち上げ~定常運転	
	2号炉	985	990	986	929	922	955	981	896	963	925	915	919	883	888	938	908	931	920	1,002	898	888	893	863	884	
8	1号炉	877	879	860	884	916	923	926	914	900	874	895	877	908	906	924	927	919	908	884	891	887	918	840	958	
	2号炉	908	871	917	941	929	979	965	940	960	935	923	886	938	933	940	933	929	890	921	942	935	1,014	1,043	1,000	
9	1号炉	921	920	899	908	887	911	910	897	917	928	948	933	910	911	902	928	909	882	909	927	906	872	852	879	
	2号炉	955	972	883	912	942	956	915	962	950	970	923	971	934	895	882	884	900	921	937	961	946	981	966	960	
10	1号炉	933	923	925	906	899	926	874	946	892	892	915	934	944	956	936	935	972	920	926	889	883	894	898	896	
	2号炉	975	912	921	925	882	896	932	894	933	947	930	932	996	946	937	913	939	888		893	873	870	866	888	
11	1号炉	916	940	969	964	937	938	924	917	917	904	901	914	942	936	872	919	949	922	951	952	947	932	947	937	
	2号炉	881	937	883	911	920	939	940	943	886	853	911	931	925	912	934	933	940	856	905	896	900	893	864	944	
12	1号炉	886	951	980	973	941	911	916	949	928	976	905	903	933	959	931	978	986	937	962	936	948	936	912	908	
	2号炉	940	983	955	945	918	916	893	900	892	963	893	896	959	1,010	930	956	966	926	940	903	886	925	900	866	
13	1号炉	971	967	921	964	953	938	991	976	975	919	936	911	889	889	921	881	925	886	872	884	921	908	975	965	
	2号炉	967	999	946	990	933	918	912	936	1,002	953	950	931	909	951	932	925	961	929	933	937	931	961	1,005	955	
14	1号炉	943	956	933	910	885	915	916	941	893	910	868	915	901	880	907	876	874	911	930	902	856	877	875	894	
	2号炉	889	992	964	946	909	914	808	853	1,017	934	917	963	963	954	938	941	940	997	923	1,001	964	939	971	951	
15	1号炉	894	878	925	951	911	918	954	965	943	964	933	928	952	936	907	920	919	931	991	936	965	965	919	958	
	2号炉	946	970	951	999	990	926	937	868	964	966	975	1,023	979	960	941	1,013	986	1,028	990	971	968	944	1,008	990	

7月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	966	954	939	945	953	949	944	954	969	963	922	920	925	871	849	945	916	916	892	941	928	952	940	904	
	2号炉	968	980	976	992	956	971	948	923	966	953	982	940	935	966	937	944	943	925	925	937	989	997	1,024	1,004	
17	1号炉	951	940	902	908	910	956	903	874	896			951	902	874	903	888	885	896	881	901	900	914	921	880	
	2号炉	997	985	914	943	932	972	918	961	967	973	964	905	981	979	940	960	957	931	939	933	932	920	1,027	956	
18	1号炉	888	937	907	899	878	916	925	961	936	838	967	969	972	981	928	901	916	922	942	945	949	952	911	928	
	2号炉	960	977	927	926	909	949	958	926	972	782	1035	997	1,010	968	966	964	948	963	953	953	966	953	915	958	9:12~9:50給じん停止
19	1号炉	940	995	916	878	916	927	922	949	949	938	887	911	905	913	914	935	922	886	889	891	887	901	900	922	
	2号炉	949	981	944	932	920	939	903	910	920	943															定常運転~立ち下げ
20	1号炉	929	968	918	885	912	898	912	906	911	927	943	916	994	932	920	927	928	943	944	939	934	938	938	960	
	2号炉																									休炉
21	1号炉	962	974	975	896	908	942	942	938	947	913	930	961	979	958	942	941	941	967	978	959	945	946	932	939	
	2号炉																									休炉
22	1号炉	953	893	954	942	936	971	961	979	966	942	955	960	925	899	897	910	895	868	887	874	900	917	972	934	
	2号炉																									休炉
23	1号炉	904	953	928	946	904	901	884	894	910	940	929	925	905	915	915	901	923	993	914	970	999	1015	964	902	
	2号炉																									休炉
24	1号炉	949	912	941	1000	957	906	970	950	974	971	937	988	921	939	915	935	951	939	920	930	930	951	903	941	
	2号炉																									休炉
25	1号炉	935	932	948	875	955	937	930	952	958	808	953	960	951	942	956	959	962	973	1,017	917	926	916	927	944	
	2号炉																									休炉
26	1号炉	931	917	918	897	893	929	907	869	910	911	1,018	939	912	948	950	915	970	956	972	905	925	946	889	973	
	2号炉																									休炉
27	1号炉	960	956	936	924	926	888	957	933	941	907	936	945	928	947	947	958	955	906	928	889	923	973	965	935	
	2号炉																									休炉
28	1号炉	928	946	921	861	904	923	939	908	936	908	901	928	942	944	945	962	905	938	926	897	911	921	922	905	
	2号炉																									休炉
29	1号炉	925	926	940	898	959	947	954	928	896	921	923	925	955	943	960	940	935	924	911	946	1001	953	933	919	
	2号炉																									休炉
30	1号炉	939	949	937	946	949	937	979	935	934	845															定常運転~立ち下げ
	2号炉											891	924	898	881	861	883	893	892	919	904	916	916	956	922	立ち上げ~定常運転
31	1号炉																									休炉
	2号炉	961	984	939	942	937	910	937	935	931	899	921	907	935					883	924	948	933	924	903	945	959



燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成30年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	977	950	933	936	926	892	937	976	934	939	924	939	961	958	961	990	946	943	962	975	961	953	936	945	
2	1号炉																									休炉
	2号炉	910	947	951	941	979	971	967	961	949	924	943	951	963	935	948	989	970	950	971	959	952	936	919	937	
3	1号炉																									休炉
	2号炉	956	959	924	958	917	940	910	942	924	953	930	928	919	944	948	967	950	937	906	878	930	933	900	953	
4	1号炉																									休炉
	2号炉	948	936	942	959	933	914	922	929	909	906	915	927	905	913	920	917	915	931	922	920	911	908	909	891	
5	1号炉																									休炉
	2号炉	918	913	921	881	928	939	990	990	988	958	950	1,022	978	956	1,003	981	1,016	965	989	987	980	1,033	930	943	
6	1号炉																									休炉
	2号炉	1,043	953	982	987	1,013	953	993	993	993	982	946	966	960	970	1,005	956	973	990	1,014	990	963	1,009	972	987	
7	1号炉																									休炉
	2号炉	973	966	987	1,003	924	957	921	910	936	1,014	967	990	975	937	953	928	967	880				976	973	958	
8	1号炉																									休炉
	2号炉	950	948	946	1,003	917	932	963	951	931	865	981	935	943	937	981	973	996	1,019	972	979	986	968	975	981	
9	1号炉																									休炉
	2号炉	970	981	944	934	991	969	955	931	935	958	959	973	974	929	946	932	923	975	963	965	930	965	938	969	
10	1号炉																									休炉
	2号炉	931	954	944	963	956	981	991	963	907	919	970	944	956	959	943	918	931	949	912	933	931	903	909	963	
11	1号炉																									休炉
	2号炉	921	899	906	925	936	944	934	955	945	949	942	917	896	970	930	921	950	936	887	889	878	961	1,012	1,011	
12	1号炉																									休炉
	2号炉	1,000	942	973	963	958	966	976	910	931	1,028	1,009	932	941	948	929	964	1,002	913	962	972	922	900	927	914	
13	1号炉		840	935	912	957	936	927	945	895	954	973	954	887	949	927	913	889	887	919	913	962	914	948	957	立ち上げ～定常運転
	2号炉	933	947	946	1,025	1,006	1,026	1,074	1,021	1,059	1,116	928	958	967	1,010	1,047	855	1,050	1,033	908	929	935	927	986	910	
14	1号炉	936	948	945	938	934	951	896	885	956	964	999	973	966	953	919	931	917	910	905	891	966	919	943	918	
	2号炉	951	948	908	922	915	884	878	909	918					936	943	895	913	925	905	936	901	902	881	873	
15	1号炉	938	944	917	948	951	968	939	960	950	968	1,034	975	929	954	964	949	960	983	914	921	996	913	902	920	
	2号炉	960	911	891	904	908	938	942	930	904	848	1,065	963	945	921	949	950	949	958	906	968	939	919	885	908	

8月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	946	937	946	941	984	978	961	942	963	974	967	985	1045	1004	994	981	946	921	935	952	960	925	927	924	
	2号炉	944	931	969	991	971	944	970	941	960	911	984	1,024	1,010	994	930	912	920	952	947	918	948	896	950	893	
17	1号炉	956	929	943	975	989	956	966	979	949	983	987	978	986	977	943	970	989	972	949	1,000	921	950	1,007	921	
	2号炉	929	940	906	904	932	910	941	965	998	970	975	978	950	970	998	961	948	952	948	963	958	943	1,021	995	
18	1号炉	984	1015	971	934	950	1005	1000	1,004	912	913	920	935	944	950	910	933	931	911	929	942	1,015	952	983	942	
	2号炉	1020	989	961	993	964	1,057	1,065	941	912	927	996	992	979	935	968	989	978	930	959	936	991	977	960	965	
19	1号炉	953	907	979	1,020	963	1,003	942	957	1,001	1,040	969	944	865				820	997	932	948	933	964	1,033	1,040	
	2号炉	960	929	984	1007	1,006	975	958	1,039	1,014	978	949	952	966	975	944	981	997	969	987	990	929	961	983	989	
20	1号炉	953	916	946	914	958	915	917	957	924	891	946	932	988	1,015	970	941	982	911	837	947	895	961	957	874	
	2号炉	993	940	929	893	941	910	987	943	921	991	890	933	897	971	973	1,006	918	1,054	880	1,000	976	993	928	871	
21	1号炉	902	916	908	920	927	909	905	876	872				965	867	897	882	874	850	874	917	916	902	873	912	
	2号炉	896	940	924	946	930	968	970	933	926	957	923	936	947	894	906	914	946	857							
22	1号炉	856	922	888	899	913	932	934	917	860	835	884	907	926	941	969	950	915	945	917	926	922	905	936	920	
	2号炉	864	910	904	896	897	901	897	898	932	819	924	906	892	917	935	934	921	914	907	923	942	906	958	1,020	
23	1号炉	892	882	911	876	857	901	876	905	885	925	927	916	878	905	903	921	909	904	891	899	872	873	863	877	
	2号炉	1012	1063	1002	964	1,029	972	955	985	983	1,005	1,029	1,004	1,012	993	1,010	1,008	971	1,037	1,014	955	987	984	929	982	
24	1号炉	911	903	870	900	882	866	922	907	905	919	904	873	914	928	906	921	915	942	936	946	919	919	876	954	
	2号炉	991	1016	1011	1014	1,014	1,027	1,032	963	986	1,024	952	959	1,002	976	1,041	1,043	989	984	907	930	953	920	968	965	
25	1号炉	929	906	934	939	910	934	974	943	899	958	926	931	940	994	991	1,018	998	876	883	852	922	976	1,009	881	
	2号炉	946	912	938	946	895	953	1,009	925	967	953	935	931	981	961	944	958	990	901	906	873	939	931	952	961	
26	1号炉	901	904	923	904	897	960	952	979	904	906	929	930	950	881	923	940	944	900	899	943	918	929	1,020	884	
	2号炉	945	977	924	954	942	954	922	906	993	923	979	936	951	968	975	1,026	1,000	953	988	961	957	980	963	975	
27	1号炉	802	969	989	980	935	963	935	967	924	959	1,000	983	866	890	881	869	891	909	914	894	905	944	1,003	960	
	2号炉	974	924	989	991	941	946	960	964	956	1,001	1,009	1,028	986	919	914	903	909	900	916	920	922	989	1,027	1,004	23:44～24:48給じん停止
28	1号炉	765	894	889	863	878	898	895	886	871				913	879	867	861	884	891	888	902	919	921	915	938	23:59～給じん停止
	2号炉	969	969	1043	942	901	966	1,024	978	1,037	1,004	989	1,015	990	1,057	969	988	979	928			950	917	991	935	23:59～給じん停止
29	1号炉	738																								給じん停止
	2号炉	765																								給じん停止
30	1号炉																858	911	885	903	886	895	881	921	927	15:30～給じん開始
	2号炉														862	964	983	1,018	953	967	991	963	940	879	784	13:46～給じん開始 23:12～24:07給じん停止
31	1号炉	743	875	864	881	986	923	879	871	903	912	908	922	929	909	926	944	939	930	924	883	887	912	904	870	0:00～0:32給じん停止 0:35～0:56給じん停止
	2号炉	871	946	924	967	992	952	924	942	998	1,012	983	1,000	966	996	1,043	1,007	1,006	877	865	944	1,065	1,005	959	961	