

平成30年度 排ガス中のばい煙濃度等

| 4月 | ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値: 20ppm以下 | | | 塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下 | | |
|----|---|----|----|----------------------------------|----|------|--|----|------|------------------------------|----|----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 69 | 1 | 28.5 | 36 | 0 | 28.5 | 0 | 0 | 0 | 9 | 2 | 6 |
| 2 | 0 | 0 | 0 | 67 | 1 | 31.5 | 35 | 2 | 24.5 | 0 | 0 | 0 | 11 | 1 | 6 |
| 3 | 0 | 0 | 0 | 80 | 0 | 29.5 | 39 | 0 | 24 | 0 | 0 | 0 | 11 | 1 | 5 |
| 4 | 0 | 0 | 0 | 70 | 8 | 43 | 38 | 0 | 23 | 1 | 0 | 0 | 8 | 3 | 5 |
| 5 | 0 | 0 | 0 | 68 | 6 | 38 | 51 | 1 | 27.5 | 0 | 0 | 0 | 11 | 2 | 7 |
| 6 | 0 | 0 | 0 | 86 | 10 | 43 | 39 | 5 | 27 | 1 | 0 | 0 | 16 | 3 | 7.5 |
| 7 | 0 | 0 | 0 | 70 | 2 | 42 | 43 | 1 | 27.5 | 1 | 0 | 0 | 15 | 2 | 7.5 |
| 8 | 0 | 0 | 0 | 86 | 10 | 46.5 | 43 | 6 | 31 | 1 | 0 | 0 | 12 | 4 | 8.5 |
| 9 | 0 | 0 | 0 | 64 | 11 | 32 | 48 | 22 | 34 | 0 | 0 | 0 | 9 | 4 | 6 |
| 10 | 0 | 0 | 0 | 48 | 1 | 23.5 | 45 | 4 | 31.5 | 0 | 0 | 0 | 8 | 1 | 3 |
| 11 | 0 | 0 | 0 | 63 | 1 | 23 | 47 | 0 | 27.5 | 0 | 0 | 0 | 4 | 1 | 2.5 |
| 12 | 0 | 0 | 0 | 60 | 9 | 33.5 | 52 | 15 | 30.5 | 1 | 0 | 0 | 6 | 1 | 3.5 |
| 13 | 0 | 0 | 0 | 58 | 5 | 29.5 | 51 | 9 | 32 | 0 | 0 | 0 | 6 | 1 | 3 |
| 14 | 0 | 0 | 0 | 84 | 7 | 41 | 46 | 6 | 32 | 0 | 0 | 0 | 13 | 2 | 5 |
| 15 | 0 | 0 | 0 | 75 | 4 | 44.5 | 42 | 5 | 26.5 | 1 | 0 | 0 | 11 | 2 | 6.5 |
| 16 | 0 | 0 | 0 | 75 | 5 | 38.5 | 43 | 9 | 28 | 0 | 0 | 0 | 10 | 1 | 4 |
| 17 | 0 | 0 | 0 | 49 | 1 | 22.5 | 45 | 2 | 34.5 | 0 | 0 | 0 | 7 | 1 | 3 |
| 18 | 0 | 0 | 0 | 63 | 5 | 29.5 | 40 | 8 | 29.5 | 0 | 0 | 0 | 6 | 2 | 3 |
| 19 | 0 | 0 | 0 | 59 | 11 | 32.5 | 37 | 20 | 31 | 0 | 0 | 0 | 10 | 2 | 5 |
| 20 | 0 | 0 | 0 | 65 | 10 | 31.5 | 39 | 2 | 27 | 1 | 0 | 0 | 8 | 2 | 4 |
| 21 | 0 | 0 | 0 | 79 | 5 | 35.5 | 37 | 4 | 25.5 | 0 | 0 | 0 | 9 | 1 | 5 |
| 22 | 0 | 0 | 0 | 66 | 1 | 26.5 | 40 | 1 | 28.5 | 0 | 0 | 0 | 9 | 1 | 4 |
| 23 | 0 | 0 | 0 | 77 | 0 | 27.5 | 40 | 12 | 30 | 0 | 0 | 0 | 7 | 2 | 3.5 |
| 24 | 0 | 0 | 0 | 51 | 4 | 21.5 | 40 | 10 | 30.5 | 0 | 0 | 0 | 9 | 2 | 4 |
| 25 | 0 | 0 | 0 | 71 | 3 | 24 | 58 | 1 | 34 | 1 | 0 | 0 | 10 | 1 | 5.5 |
| 26 | 0 | 0 | 0 | 86 | 3 | 29 | 40 | 2 | 27 | 0 | 0 | 0 | 15 | 1 | 5.5 |
| 27 | 0 | 0 | 0 | 54 | 2 | 18.5 | 39 | 16 | 32 | 0 | 0 | 0 | 10 | 2 | 5.5 |
| 28 | 0 | 0 | 0 | 47 | 7 | 22 | 37 | 9 | 29 | 0 | 0 | 0 | 6 | 2 | 4 |
| 29 | 0 | 0 | 0 | 70 | 3 | 37 | 48 | 5 | 29 | 0 | 0 | 0 | 6 | 2 | 4 |
| 30 | 0 | 0 | 0 | 55 | 1 | 29 | 38 | 24 | 30 | 0 | 0 | 0 | 6 | 3 | 4 |

平成30年度 排ガス中のばい煙濃度等

| 5月 | ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値: 20ppm以下 | | | 塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下 | | |
|----|---|----|----|----------------------------------|----|------|--|----|------|------------------------------|----|----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 72 | 3 | 32 | 38 | 8 | 30 | 0 | 0 | 0 | 5 | 1 | 3 |
| 2 | 0 | 0 | 0 | 91 | 6 | 45 | 40 | 4 | 24 | 1 | 0 | 0 | 5 | 2 | 3 |
| 3 | 0 | 0 | 0 | 58 | 19 | 38 | 37 | 20 | 31 | 0 | 0 | 0 | 7 | 3 | 4 |
| 4 | 0 | 0 | 0 | 75 | 10 | 32 | 35 | 12 | 28 | 0 | 0 | 0 | 7 | 2 | 4 |
| 5 | 0 | 0 | 0 | 62 | 7 | 31 | 38 | 13 | 30 | 0 | 0 | 0 | 6 | 2 | 3 |
| 6 | 0 | 0 | 0 | 66 | 0 | 32 | 38 | 2 | 25 | 0 | 0 | 0 | 6 | 0 | 4 |
| 7 | 0 | 0 | 0 | 60 | 13 | 34 | 34 | 15 | 27 | 0 | 0 | 0 | 6 | 2 | 4 |
| 8 | 0 | 0 | 0 | 39 | 0 | 21 | 41 | 5 | 31 | 0 | 0 | 0 | 5 | 0 | 3 |
| 9 | 0 | 0 | 0 | 71 | 9 | 27 | 42 | 13 | 30 | 0 | 0 | 0 | 4 | 2 | 3 |
| 10 | 0 | 0 | 0 | 47 | 8 | 23 | 40 | 20 | 33 | 0 | 0 | 0 | 3 | 1 | 2 |
| 11 | 0 | 0 | 0 | 59 | 0 | 24 | 42 | 1 | 29 | 0 | 0 | 0 | 3 | 0 | 2 |
| 12 | 0 | 0 | 0 | 66 | 13 | 39 | 43 | 21 | 34 | 0 | 0 | 0 | 9 | 2 | 4 |
| 13 | 0 | 0 | 0 | 81 | 6 | 30 | 38 | 24 | 33 | 0 | 0 | 0 | 6 | 3 | 4 |
| 14 | 0 | 0 | 0 | 84 | 3 | 40 | 39 | 8 | 27 | 2 | 0 | 0 | 24 | 3 | 8 |
| 15 | 0 | 0 | 0 | 57 | 2 | 25 | 42 | 7 | 31 | 0 | 0 | 0 | 25 | 3 | 8 |
| 16 | 0 | 0 | 0 | 73 | 1 | 29 | 49 | 3 | 29.5 | 0 | 0 | 0 | 7 | 0 | 3.5 |
| 17 | 0 | 0 | 0 | 76 | 6 | 28.5 | 40 | 7 | 27.5 | 0 | 0 | 0 | 10 | 3 | 5 |
| 18 | 0 | 0 | 0 | 71 | 9 | 29.5 | 36 | 14 | 29 | 0 | 0 | 0 | 9 | 2 | 5 |
| 19 | 0 | 0 | 0 | 68 | 17 | 47 | 38 | 11 | 28 | 0 | 0 | 0 | 14 | 4 | 9 |
| 20 | 0 | 0 | 0 | 73 | 1 | 32 | 36 | 14 | 27 | 0 | 0 | 0 | 14 | 2 | 6 |
| 21 | 0 | 0 | 0 | 65 | 1 | 28 | 33 | 0 | 25 | 0 | 0 | 0 | 12 | 2 | 5 |
| 22 | 0 | 0 | 0 | 44 | 2 | 25 | 36 | 1 | 26 | 0 | 0 | 0 | 6 | 1 | 3 |
| 23 | 0 | 0 | 0 | 54 | 2 | 22 | 35 | 11 | 25 | 0 | 0 | 0 | 3 | 1 | 2 |
| 24 | 0 | 0 | 0 | 35 | 3 | 18 | 36 | 15 | 30 | 0 | 0 | 0 | 5 | 2 | 3 |
| 25 | 0 | 0 | 0 | 54 | 8 | 34 | 38 | 17 | 30 | 0 | 0 | 0 | 5 | 2 | 3 |
| 26 | 0 | 0 | 0 | 74 | 1 | 36.5 | 38 | 0 | 18 | 0 | 0 | 0 | 8 | 2 | 4.5 |
| 27 | 0 | 0 | 0 | 68 | 10 | 31 | 36 | 6 | 25 | 0 | 0 | 0 | 7 | 2 | 5 |
| 28 | 0 | 0 | 0 | 45 | 1 | 18 | 37 | 20 | 28 | 0 | 0 | 0 | 6 | 3 | 4 |
| 29 | 0 | 0 | 0 | 64 | 0 | 23.5 | 45 | 0 | 17.5 | 1 | 0 | 0 | 6 | 1 | 3 |
| 30 | 0 | 0 | 0 | 73 | 10 | 39 | 35 | 2 | 23 | 1 | 0 | 0 | 7 | 2 | 4 |
| 31 | 0 | 0 | 0 | 54 | 8 | 31.5 | 40 | 15 | 28 | 0 | 0 | 0 | 6 | 3 | 4.5 |

平成30年度 排ガス中のばい煙濃度等

| 6月 | ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値: 20ppm以下 | | | 塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下 | | |
|----|---|----|----|----------------------------------|----|------|--|----|------|------------------------------|----|-----|---|----|------|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 82 | 12 | 41 | 37 | 5 | 25.5 | 1 | 0 | 0 | 8 | 2 | 5 |
| 2 | 0 | 0 | 0 | 87 | 19 | 42.5 | 35 | 11 | 28 | 0 | 0 | 0 | 10 | 3 | 6 |
| 3 | 0 | 0 | 0 | 87 | 10 | 44 | 36 | 9 | 25.5 | 0 | 0 | 0 | 11 | 3 | 5 |
| 4 | 0 | 0 | 0 | 68 | 16 | 44.5 | 37 | 10 | 28.5 | 0 | 0 | 0 | 11 | 4 | 6.5 |
| 5 | 0 | 0 | 0 | 71 | 1 | 34 | 39 | 8 | 29.5 | 0 | 0 | 0 | 12 | 1 | 5.5 |
| 6 | 0 | 0 | 0 | 70 | 4 | 41.5 | 61 | 0 | 26.5 | 1 | 0 | 0 | 7 | 1 | 4.5 |
| 7 | 0 | 0 | 0 | 61 | 3 | 32.5 | 35 | 10 | 27 | 0 | 0 | 0 | 7 | 2 | 4.5 |
| 8 | 0 | 0 | 0 | 76 | 13 | 34 | 34 | 11 | 26.5 | 0 | 0 | 0 | 9 | 2 | 5 |
| 9 | - | - | - | - | - | - | - | - | - | - | - | - | - | - | - |
| 10 | 0 | 0 | 0 | 82 | 21 | 48 | 31 | 4 | 16 | 2 | 1 | 0 | 4 | 1 | 2 |
| 11 | 0 | 0 | 0 | 69 | 0 | 31 | 34 | 1 | 23 | 0 | 0 | 0 | 6 | 0 | 3.5 |
| 12 | 0 | 0 | 0 | 72 | 3 | 32.5 | 37 | 0 | 26 | 0 | 0 | 0 | 5 | 1 | 3 |
| 13 | 0 | 0 | 0 | 64 | 1 | 29 | 36 | 5 | 26 | 0 | 0 | 0 | 6 | 1 | 3 |
| 14 | 0 | 0 | 0 | 66 | 9 | 35 | 39 | 6 | 26.5 | 0 | 0 | 0 | 7 | 1 | 4 |
| 15 | 0 | 0 | 0 | 84 | 1 | 41.5 | 39 | 0 | 25 | 0 | 0 | 0 | 8 | 1 | 5 |
| 16 | 0 | 0 | 0 | 87 | 17 | 59.5 | 35 | 1 | 23 | 1 | 0 | 0 | 17 | 3 | 7.5 |
| 17 | 0 | 0 | 0 | 83 | 11 | 55 | 35 | 0 | 22.5 | 1 | 0 | 0 | 14 | 2 | 8 |
| 18 | 0 | 0 | 0 | 73 | 5 | 37.5 | 37 | 5 | 25 | 1 | 0 | 0 | 12 | 3 | 5.5 |
| 19 | 0 | 0 | 0 | 75 | 0 | 27 | 36 | 0 | 23.5 | 0 | 0 | 0 | 9 | 1 | 4.5 |
| 20 | 0 | 0 | 0 | 73 | 1 | 31.5 | 36 | 2 | 23 | 1 | 0 | 0 | 10 | 3 | 4.5 |
| 21 | 0 | 0 | 0 | 89 | 4 | 36.5 | 36 | 1 | 24.5 | 1 | 0 | 0 | 7 | 3 | 4 |
| 22 | 0 | 0 | 0 | 93 | 1 | 42 | 41 | 0 | 24 | 1 | 0 | 0 | 9 | 0 | 4.5 |
| 23 | 0 | 0 | 0 | 94 | 19 | 61 | 53 | 1 | 26 | 4 | 0 | 0.5 | 25 | 3 | 14.5 |
| 24 | 0 | 0 | 0 | 98 | 22 | 57 | 55 | 0 | 20 | 1 | 0 | 0 | 15 | 2 | 6 |
| 25 | 0 | 0 | 0 | 91 | 6 | 47.5 | 34 | 0 | 18 | 1 | 0 | 0 | 12 | 2 | 7 |
| 26 | 0 | 0 | 0 | 64 | 4 | 28.5 | 35 | 0 | 23.5 | 1 | 0 | 0 | 10 | 0 | 5 |
| 27 | 0 | 0 | 0 | 78 | 7 | 39 | 37 | 4 | 19.5 | 2 | 0 | 0 | 8 | 1 | 4 |
| 28 | 0 | 0 | 0 | 86 | 15 | 47 | 39 | 4 | 21.5 | 1 | 0 | 0 | 19 | 2 | 6 |
| 29 | 0 | 0 | 0 | 93 | 14 | 40.5 | 37 | 3 | 21 | 1 | 0 | 0 | 9 | 1 | 4.5 |
| 30 | 0 | 0 | 0 | 79 | 12 | 49 | 31 | 1 | 14 | 1 | 0 | 0 | 6 | 1 | 4 |

平成30年度 排ガス中のばい煙濃度等

| 7月 | ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値: 20ppm以下 | | | 塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下 | | |
|----|---|----|----|----------------------------------|----|------|--|----|------|------------------------------|----|-----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 84 | 21 | 55 | 28 | 3 | 12 | 1 | 0 | 0 | 9 | 2 | 5 |
| 2 | 0 | 0 | 0 | 82 | 29 | 52 | 28 | 5 | 15 | 1 | 0 | 0 | 8 | 2 | 4 |
| 3 | 0 | 0 | 0 | 77 | 1 | 38 | 35 | 0 | 20 | 0 | 0 | 0 | 8 | 1 | 5 |
| 4 | 0 | 0 | 0 | 68 | 12 | 44 | 30 | 3 | 16 | 2 | 0 | 0 | 6 | 1 | 3 |
| 5 | 0 | 0 | 0 | 60 | 25 | 43 | 33 | 16 | 26 | 1 | 0 | 0 | 8 | 2 | 4 |
| 6 | 0 | 0 | 0 | 61 | 9 | 32 | 34 | 21 | 28 | 0 | 0 | 0 | 7 | 3 | 4 |
| 7 | 0 | 0 | 0 | 53 | 1 | 26 | 37 | 2 | 26 | 0 | 0 | 0 | 6 | 0 | 4 |
| 8 | 0 | 0 | 0 | 69 | 2 | 28.5 | 36 | 12 | 24 | 1 | 0 | 0 | 8 | 2 | 4.5 |
| 9 | 0 | 0 | 0 | 49 | 2 | 20.5 | 33 | 11 | 25.5 | 0 | 0 | 0 | 6 | 1 | 3.5 |
| 10 | 0 | 0 | 0 | 57 | 2 | 24.5 | 38 | 2 | 25 | 0 | 0 | 0 | 7 | 1 | 3.5 |
| 11 | 0 | 0 | 0 | 61 | 2 | 30.5 | 36 | 2 | 23.5 | 2 | 0 | 0 | 11 | 1 | 4 |
| 12 | 0 | 0 | 0 | 84 | 2 | 41.5 | 36 | 8 | 25 | 0 | 0 | 0 | 8 | 1 | 3.5 |
| 13 | 0 | 0 | 0 | 74 | 2 | 40.5 | 33 | 7 | 23.5 | 1 | 0 | 0 | 6 | 2 | 3 |
| 14 | 0 | 0 | 0 | 87 | 1 | 49.5 | 35 | 0 | 22 | 1 | 0 | 0 | 15 | 1 | 9 |
| 15 | 0 | 0 | 0 | 81 | 30 | 55 | 47 | 5 | 29 | 0 | 0 | 0 | 13 | 4 | 7 |
| 16 | 0 | 0 | 0 | 89 | 17 | 52 | 30 | 3 | 18.5 | 1 | 0 | 0 | 13 | 2 | 6 |
| 17 | 0 | 0 | 0 | 85 | 3 | 44.5 | 36 | 2 | 23 | 1 | 0 | 0 | 7 | 2 | 4 |
| 18 | 0 | 0 | 0 | 88 | 26 | 55 | 35 | 2 | 22 | 4 | 0 | 0.5 | 11 | 3 | 6.5 |
| 19 | 0 | 0 | 0 | 71 | 6 | 39.5 | 37 | 11 | 28 | 1 | 0 | 0 | 9 | 3 | 5 |
| 20 | 0 | 0 | 0 | 62 | 8 | 30 | 35 | 8 | 24 | 0 | 0 | 0 | 8 | 3 | 5 |
| 21 | 0 | 0 | 0 | 63 | 12 | 41 | 33 | 15 | 26 | 0 | 0 | 0 | 8 | 2 | 5 |
| 22 | 0 | 0 | 0 | 46 | 7 | 24 | 33 | 8 | 24 | 0 | 0 | 0 | 6 | 2 | 3 |
| 23 | 0 | 0 | 0 | 56 | 2 | 24 | 35 | 9 | 23 | 0 | 0 | 0 | 8 | 2 | 4 |
| 24 | 0 | 0 | 0 | 41 | 9 | 22 | 36 | 5 | 26 | 0 | 0 | 0 | 7 | 2 | 4 |
| 25 | 0 | 0 | 0 | 56 | 10 | 22 | 35 | 6 | 24 | 0 | 0 | 0 | 5 | 2 | 3 |
| 26 | 0 | 0 | 0 | 54 | 9 | 25 | 33 | 15 | 25 | 0 | 0 | 0 | 3 | 1 | 2 |
| 27 | 0 | 0 | 0 | 39 | 5 | 27 | 34 | 14 | 25 | 0 | 0 | 0 | 5 | 2 | 3 |
| 28 | 0 | 0 | 0 | 34 | 8 | 23 | 34 | 18 | 27 | 0 | 0 | 0 | 5 | 2 | 3 |
| 29 | 0 | 0 | 0 | 40 | 6 | 23 | 35 | 22 | 29 | 0 | 0 | 0 | 6 | 3 | 4 |
| 30 | 0 | 0 | 0 | 73 | 1 | 37 | 59 | 2 | 33 | 1 | 0 | 0 | 7 | 0 | 4 |
| 31 | 0 | 0 | 0 | 71 | 11 | 43 | 15 | 0 | 5 | 1 | 0 | 0 | 4 | 1 | 2 |

平成30年度 排ガス中のばい煙濃度等

| 8月 | ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下 | | | 一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下 | | | 窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下 | | | 硫黄酸化物濃度(ppm) 管理値: 20ppm以下 | | | 塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下 | | |
|----|---|----|----|----------------------------------|----|------|--|----|------|------------------------------|----|-----|---|----|-----|
| | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 | 最大 | 最小 | 平均 |
| 1 | 0 | 0 | 0 | 70 | 23 | 52 | 22 | 12 | 18 | 0 | 0 | 0 | 5 | 3 | 4 |
| 2 | 0 | 0 | 0 | 76 | 34 | 57 | 24 | 10 | 18 | 1 | 0 | 0 | 5 | 2 | 3 |
| 3 | 0 | 0 | 0 | 77 | 34 | 58 | 32 | 11 | 21 | 1 | 0 | 0 | 21 | 2 | 6 |
| 4 | 0 | 0 | 0 | 93 | 42 | 64 | 36 | 17 | 25 | 1 | 0 | 0 | 9 | 3 | 6 |
| 5 | 0 | 0 | 0 | 68 | 24 | 48 | 38 | 20 | 31 | 1 | 0 | 0 | 6 | 3 | 5 |
| 6 | 0 | 0 | 0 | 71 | 23 | 47 | 37 | 18 | 28 | 0 | 0 | 0 | 7 | 3 | 5 |
| 7 | 0 | 0 | 0 | 67 | 1 | 42 | 36 | 1 | 26 | 1 | 0 | 0 | 5 | 0 | 3 |
| 8 | 0 | 0 | 0 | 74 | 38 | 56 | 31 | 15 | 22 | 2 | 0 | 0 | 4 | 1 | 3 |
| 9 | 0 | 0 | 0 | 88 | 28 | 56 | 32 | 16 | 23 | 1 | 0 | 0 | 5 | 2 | 4 |
| 10 | 0 | 0 | 0 | 79 | 25 | 63 | 32 | 13 | 20 | 1 | 0 | 0 | 5 | 2 | 4 |
| 11 | 0 | 0 | 0 | 80 | 43 | 61 | 36 | 18 | 26 | 1 | 0 | 0 | 6 | 3 | 4 |
| 12 | 0.02 | 0 | 0 | 94 | 17 | 63 | 35 | 12 | 24 | 1 | 0 | 0 | 8 | 2 | 6 |
| 13 | 0 | 0 | 0 | 90 | 4 | 46.5 | 50 | 4 | 28.5 | 1 | 0 | 0 | 9 | 1 | 4 |
| 14 | 0 | 0 | 0 | 67 | 4 | 32.5 | 47 | 6 | 31 | 1 | 0 | 0 | 9 | 0 | 4 |
| 15 | 0 | 0 | 0 | 89 | 12 | 42 | 39 | 17 | 28.5 | 2 | 0 | 1 | 8 | 2 | 4.5 |
| 16 | 0 | 0 | 0 | 82 | 14 | 43.5 | 47 | 16 | 34 | 3 | 0 | 1 | 6 | 2 | 3.5 |
| 17 | 0 | 0 | 0 | 70 | 9 | 39.5 | 47 | 22 | 35 | 4 | 0 | 1 | 8 | 2 | 3.5 |
| 18 | 0 | 0 | 0 | 93 | 11 | 47.5 | 48 | 16 | 35 | 6 | 0 | 2 | 6 | 3 | 4 |
| 19 | 0 | 0 | 0 | 82 | 2 | 48 | 41 | 0 | 30 | 3 | 0 | 1 | 6 | 1 | 4.5 |
| 20 | 0 | 0 | 0 | 91 | 6 | 40 | 44 | 5 | 31 | 4 | 0 | 1 | 8 | 2 | 5 |
| 21 | 0 | 0 | 0 | 64 | 0 | 28.5 | 40 | 11 | 30.5 | 2 | 0 | 0.5 | 6 | 1 | 3.5 |
| 22 | 0 | 0 | 0 | 88 | 6 | 38.5 | 38 | 10 | 26 | 1 | 0 | 0.5 | 5 | 2 | 3 |
| 23 | 0 | 0 | 0 | 71 | 5 | 33.5 | 39 | 16 | 29.5 | 2 | 0 | 0 | 8 | 2 | 3.5 |
| 24 | 0 | 0 | 0 | 71 | 3 | 37.5 | 37 | 19 | 30 | 2 | 0 | 0.5 | 7 | 2 | 4.5 |
| 25 | 0 | 0 | 0 | 81 | 8 | 44.5 | 37 | 10 | 26.5 | 1 | 0 | 0 | 8 | 1 | 5.5 |
| 26 | 0 | 0 | 0 | 74 | 18 | 47 | 39 | 12 | 28 | 2 | 0 | 0.5 | 10 | 4 | 6.5 |
| 27 | 0 | 0 | 0 | 87 | 0 | 42.5 | 37 | 0 | 26.5 | 2 | 0 | 0.5 | 11 | 2 | 5.5 |
| 28 | 0 | 0 | 0 | 61 | 0 | 27.5 | 65 | 1 | 32 | 2 | 0 | 0.5 | 8 | 0 | 4 |
| 29 | 0 | 0 | 0 | 4 | 3 | 3.5 | 7 | 5 | 6 | 0 | 0 | 0 | 0 | 0 | 0 |
| 30 | 0 | 0 | 0 | 77 | 5 | 40.5 | 31 | 0 | 17.5 | 1 | 0 | 0 | 12 | 2 | 5.5 |
| 31 | 0 | 0 | 0 | 79 | 5 | 40.5 | 35 | 0 | 14.5 | 2 | 0 | 0 | 8 | 1 | 5.5 |