

平成27年度 排ガス中のばい煙濃度等

4月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	23	7	14.5	41	5	25.5	1	0	0	5	2	3
2	0	0	0	28	5	15.5	57	3	28	3	0	0	9	2	5
3	0	0	0	23	4	14	38	0	25	1	0	0	5	0	2.5
4	0	0	0	25	4	16	40	1	25	0	0	0	5	1	3
5	0	0	0	26	4	17	53	3	30	1	0	0	8	1	5
6	0	0	0	20	6	12.5	48	7	32	1	0	0	5	2	3
7	0	0	0	24	5	11.5	46	10	33.5	3	0	0	5	0	2.5
8	0	0	0	20	4	12	56	5	35	1	0	0	4	2	2.5
9	0	0	0	19	3	9.5	44	16	32	0	0	0	4	2	2
10	0	0	0	15	4	9	44	15	33	0	0	0	3	0	2
11	0	0	0	20	3	12	41	1	31	0	0	0	5	1	3
12	0	0	0	25	4	13	36	7	25	1	0	0	3	2	3
13	0	0	0	20	3	10	40	13	32	1	0	0	4	2	3
14	0	0	0	17	3	9	42	7	29	2	0	0	4	2	3
15	0	0	0	16	4	9	37	6	27	0	0	0	3	2	3
16	0	0	0	18	4	11	41	6	32	1	0	0	5	2	3
17	0	0	0	20	2	11	41	3	25	2	0	0	4	1	3
18	0	0	0	22	4	13.5	52	9	32	1	0	0	6	2	3.5
19	0	0	0	25	9	15.5	45	5	29	2	0	0	6	2	4.5
20	0.01	0	0	22	4	11	47	4	32.5	1	0	0	4	2	3
21	0	0	0	18	3	8.5	44	13	31	1	0	0	4	2	3
22	0	0	0	21	7	13.5	63	6	33.5	3	0	0	6	3	4.5
23	0	0	0	22	5	13.5	47	21	35.5	1	0	0	15	3	5.5
24	0	0	0	17	1	10.5	43	0	31.5	0	0	0	5	1	3.5
25	0	0	0	27	5	17	48	2	32	1	0	0	11	3	7
26	0	0	0	23	9	17	40	8	30	0	0	0	8	3	5
27	0	0	0	18	8	14	49	21	32	0	0	0	6	2	3
28	0	0	0	26	1	19	48	0	30	0	0	0	6	1	3
29	0	0	0	26	6	18	44	7	31	1	0	0	4	1	3
30	0	0	0	25	12	19	40	2	31	1	0	0	8	1	3

平成27年度 排ガス中のばい煙濃度等

5月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	25	10	18	44	7	34	1	0	0	6	2	3
2	0	0	0	26	8	20	42	11	32	0	0	0	12	3	6
3	0	0	0	28	16	23	44	21	33	1	0	0	15	5	10
4	0	0	0	25	12	19	42	18	33	0	0	0	10	3	6
5	0	0	0	22	13	17	40	18	33	0	0	0	6	2	3
6	0	0	0	21	8	15	47	12	31	0	0	0	5	2	3
7	0	0	0	22	10	15	48	4	33	1	0	0	5	2	3
8	0	0	0	25	7	19	42	7	31	0	0	0	7	2	4
9	0	0	0	27	5	20	41	3	23.5	0	0	0	12	3	7
10	0	0	0	28	4	20	44	2	27	0	0	0	16	2	8
11	0	0	0	26	9	17.5	41	1	25.5	0	0	0	16	2	5
12	0	0	0	24	6	16	35	1	23.5	0	0	0	7	1	4
13	0.01	0	0	27	2	18	41	1	24	4	0	0.5	10	0	4.5
14	0	0	0	26	9	17	39	1	23.5	10	0	0.5	15	0	5
15	0.01	0	0	23	9	16.5	38	2	25	4	0	0	7	3	4.5
16	0	0	0	27	8	19.5	38	1	26.5	1	0	0	11	3	6
17	0	0	0	24	3	16.5	36	1	21	0	0	0	9	1	5.5
18	0	0	0	24	7	15	33	0	22	2	0	0	8	2	3.5
19	0.01	0	0	20	6	13.5	39	3	26	1	0	0	5	2	3.5
20	0	0	0	25	2	12	55	0	29	2	0	0	4	1	3
21	0	0	0	28	8	18	41	5	27	3	0	0	8	2	5
22	0	0	0	24	4	14	41	0	22	2	0	0	6	0	3.5
23	0	0	0	27	10	17.5	37	3	24.5	6	0	0.5	9	2	4.5
24	0	0	0	26	3	19	37	3	23	1	0	0	7	0	3.5
25	0.01	0	0	26	10	17	37	8	24.5	3	0	0	6	1	3.5
26	0.01	0	0	22	7	14	39	12	28.5	1	0	0	5	0	2.5
27	0.01	0	0	29	6	16	40	2	25	1	0	0	6	1	3
28	0.01	0	0	27	1	18.5	37	2	24	2	0	0	7	0	2.5
29	0.01	0	0	26	1	17.5	39	1	26	1	0	0	5	0	3
30	0.01	0	0	26	5	16	38	0	21.5	3	0	0	6	2	3.5
31	0	0	0	26	1	19	37	1	20.5	1	0	0	6	0	4

平成27年度 排ガス中のばい煙濃度等

6月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	22	6	15	36	15	29	0	0	0	3	2	2
2	0	0	0	23	8	15	33	4	23	3	0	0	5	2	3
3	0	0	0	22	11	17	35	3	20	3	0	0	3	1	2
4	0	0	0	22	5	15	33	12	27	1	0	0	4	2	3
5	0	0	0	24	9	14	37	15	26	2	0	0	3	2	2
6	0	0	0	24	5	16	34	3	18	1	0	0	4	2	3
7	0	0	0	17	1	11	39	3	28	0	0	0	4	0	3
8	0	0	0	21	7	14	42	16	28	1	0	0	4	2	3
9	0	0	0	20	9	15	36	15	29	2	0	0	3	2	3
10	0	0	0	22	5	12	34	6	25	0	0	0	3	1	2
11	0	0	0	23	6	15	34	12	28	2	0	0	4	2	3
12	0	0	0	24	5	15	37	4	24	0	0	0	3	1	2
13	0	0	0	21	8	14	27	4	17	0	0	0	3	2	3
14	0	0	0	24	10	17	33	2	19	0	0	0	4	2	2
15	0	0	0	24	7	15	66	1	33	2	0	0	4	1	2
16	0.01	0	0	19	4	13.5	38	0	27.5	3	0	0.5	3	0	1.5
17	0.01	0	0.01	25	8	17.5	37	8	25.5	0	0	0	3	1	2
18	0.01	0	0.01	25	6	16.5	41	19	29	1	0	0	4	1	2.5
19	0.01	0	0	26	7	15	38	5	25.5	1	0	0	4	2	3
20	0.01	0	0.01	27	10	18	39	10	28	1	0	0	9	2	3.5
21	0.01	0	0.01	27	13	20	39	12	30.5	2	0	0	7	1	3
22	0.01	0	0.01	26	7	16.5	37	6	27.5	0	0	0	4	1	2
23	0.01	0	0	20	8	15	39	13	29	0	0	0	2	1	2
24	0.01	0	0	25	11	18	38	10	26	0	0	0	3	1	2
25	0.01	0	0	23	12	19	38	21	30	0	0	0	3	2	2
26	0.01	0	0	21	5	15	36	0	23	0	0	0	3	1	2
27	0.01	0	0	23	14	18	36	22	30	0	0	0	4	2	3
28	0	0	0	26	16	21	36	14	28	0	0	0	6	3	4
29	0	0	0	26	11	20	35	3	25	0	0	0	5	2	3
30	0	0	0	25	12	19	35	6	29	0	0	0	8	3	4

平成27年度 排ガス中のばい煙濃度等

7月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	24	4	17	36	5	27	0	0	0	5	1	3
2	0	0	0	24	10	17	37	8	25	0	0	0	3	2	2
3	0	0	0	24	1	14	36	0	23	0	0	0	3	0	2
4	0	0	0	22	14	17	37	17	28	0	0	0	3	2	2
5	0	0	0	23	14	18	37	17	29	0	0	0	4	1	3
6	0	0	0	23	5	18	38	5	28	0	0	0	3	1	2
7	0.01	0	0	21	8	15	38	8	27	0	0	0	5	2	3
8	0	0	0	18	10	14	38	8	28	0	0	0	4	2	3
9	0.01	0	0	24	9	19	34	12	28	0	0	0	3	2	3
10	0.01	0	0	20	9	14	38	9	28	0	0	0	3	2	3
11	0.01	0	0	25	11	17	36	16	29	0	0	0	4	2	3
12	0	0	0	25	17	21	36	13	30	0	0	0	4	2	3
13	0.01	0	0	20	9	16	38	16	29	0	0	0	4	3	3
14	0.01	0	0	17	9	13	53	18	32	0	0	0	4	2	3
15	0.01	0	0	24	6	15	38	2	20	1	0	0	4	1	3
16	0	0	0	27	8	17	39	1	22	0	0	0	4	2	3
17	0	0	0	23	9	14	36	6	22	0	0	0	4	2	3
18	0	0	0	25	12	18	35	12	26	0	0	0	3	2	3
19	0.01	0	0	25	4	19	34	1	26	0	0	0	5	1	3
20	0.01	0	0	24	10	20	36	17	28	0	0	0	4	2	3
21	0.01	0	0.01	20	8	14.5	36	13	27.5	0	0	0	4	0	1.5
22	0.01	0	0.01	24	7	16	37	8	27.5	0	0	0	6	2	3.5
23	0.01	0	0.01	23	6	14.5	40	1	31.5	0	0	0	5	2	3
24	0.01	0	0.01	20	5	10	41	18	32.5	1	0	0	4	2	3
25	0.01	0	0.01	21	1	16	40	1	30	0	0	0	4	0	3.5
26	0.01	0	0.01	21	2	14.5	41	1	28	0	0	0	5	1	2.5
27	0.01	0	0.01	27	8	14.5	37	11	27	0	0	0	4	0	2.5
28	0.01	0	0.01	23	6	15.5	39	2	29.5	0	0	0	4	2	3
29	0.01	0	0.01	25	3	18.5	38	1	26.5	1	0	0	6	1	3.5
30	0.01	0	0.01	24	11	17.5	39	5	27	0	0	0	5	2	3.5
31	0.01	0	0.01	24	9	17	36	1	22	1	0	0	5	2	3.5

平成27年度 排ガス中のばい煙濃度等

8月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	23	11	17	36	6	29	0	0	0	4	2	3
2	0	0	0	22	10	16	37	21	30	0	0	0	4	2	3
3	0	0	0	21	2	16	38	0	28	1	0	0	3	1	3
4	0	0	0	25	9	18	38	14	30	1	0	0	4	2	2
5	0	0	0	27	4	17	39	1	28	0	0	0	4	2	3
6	0	0	0	27	11	20	35	16	29	1	0	0	7	2	4
7	0	0	0	27	15	22	38	23	31	0	0	0	4	3	3
8	0	0	0	28	18	23	37	19	30	0	0	0	5	3	4
9	0	0	0	26	14	21	37	25	32	0	0	0	4	2	4
10	0	0	0	26	4	19	38	22	31	0	0	0	4	2	3
11	0	0	0	24	8	18	56	11	36	0	0	0	3	1	2
12	0	0	0	28	13	19	37	9	31	0	0	0	3	1	2
13	0.01	0	0.01	26	10	21	36	2	25.5	3	0	0	3	0	1.5
14	0.01	0	0.01	27	9	19.5	39	1	28.5	0	0	0	6	1	2
15	0.01	0	0.01	27	3	20.5	37	1	26.5	0	0	0	5	0	3
16	0.01	0	0.01	28	14	21.5	38	11	30	0	0	0	5	2	3
17	0.01	0	0.01	26	11	18.5	39	8	28.5	0	0	0	5	2	3
18	0.01	0	0.01	23	1	14.5	36	0	25	0	0	0	5	1	3
19	0.01	0	0.01	23	7	16.5	43	9	29	0	0	0	4	1	2.5
20	0.01	0	0.01	25	7	16	37	7	26.5	0	0	0	4	1	2
21	0.01	0	0.01	27	8	16	38	10	28	0	0	0	3	1	2
22	0.01	0	0.01	27	9	19.5	37	13	29	0	0	0	3	2	2
23	0.01	0	0.01	26	5	17.5	40	0	28.5	0	0	0	4	2	2.5
24	0.01	0	0.01	26	8	18	39	10	30	0	0	0	4	1	3
25	0.01	0	0.01	26	7	17.5	44	3	28.5	1	0	0	4	1	2.5
26	0.01	0	0.01	24	9	16	46	5	35	1	0	0	4	1	3
27	0.01	0	0.01	22	7	15.5	49	8	33.5	0	0	0	6	2	3.5
28	0.01	0	0.01	24	4	16	42	10	30	0	0	0	4	1	3
29	0.01	0	0.01	25	10	19	39	5	29.5	0	0	0	4	2	3.5
30	0.01	0	0.01	26	12	18.5	51	14	30.5	0	0	0	5	2	4
31	0.01	0	0.01	24	6	16	65	0	28	1	0	0	6	2	4

平成27年度 排ガス中のばい煙濃度等

9月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0.01	20	6	13	39	10	30.5	0	0	0	5	3	4
2	0.01	0	0.01	25	3	13.5	37	1	25.5	0	0	0	4	2	3.5
3	0.01	0	0.01	23	4	14	38	4	28	0	0	0	6	3	4
4	0.01	0	0.01	17	6	12	39	11	29.5	0	0	0	4	1	2.5
5	0.01	0	0.01	24	6	15.5	37	19	30	0	0	0	5	1	3
6	0.01	0	0.01	26	2	17.5	41	3	29	1	0	0	4	0	2.5
7	0.01	0	0.01	26	7	15.5	41	8	27.5	0	0	0	5	2	3
8	0.01	0	0.01	20	8	14	38	8	29	0	0	0	5	2	3.5
9	0.01	0	0.01	22	3	14	39	1	28.5	0	0	0	4	1	3
10	0.01	0	0.01	25	6	17	44	15	30	0	0	0	5	0	2
11	0	0	0	19	9	15	34	9	23	0	0	0	3	2	2
12	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20	0	0	0	26	15	21	34	5	24	1	0	0	3	0	2
21	0	0	0	26	15	21	38	13	31	1	0	0	6	1	4
22	0	0	0	24	14	19	36	16	30	0	0	0	5	2	4
23	0	0	0	24	14	18	36	20	31	0	0	0	5	2	4
24	0	0	0	24	13	18	38	28	33	0	0	0	4	2	3
25	0	0	0	24	13	19	38	22	32	0	0	0	7	2	4
26	0	0	0	21	10	16	37	9	32	1	0	0	3	1	3
27	0	0	0	20	12	16	38	27	34	0	0	0	4	2	3
28	0	0	0	21	6	14	38	9	31	0	0	0	5	1	4
29	0	0	0	24	8	17	37	23	32	0	0	0	5	3	4
30	0	0	0	25	12	18	37	7	28	0	0	0	6	3	5