

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	877	917	879	880	905	912	890	874	890	863	961	936	895	918	921	902	892	890	872	870	887	868	896	881	
	2号炉																									休炉
17	1号炉	878	898	917	870	874	890	831	836	883		833	818	879	864	870	867	832	681	1,002	831	832	832	863	839	17:34~18:14給じん停止
	2号炉																									休炉
18	1号炉	861	839	838	853	874	860	839	882	923	926	890	889	918	867	908	871	868	885	867	890	920	886	815	841	
	2号炉										1,064	1,003	908	860	890	868	889	864	865	879	879	861	894	888	890	立ち上げ~定常運転
19	1号炉	901	867	916	860	879	865	820	892	876	914	916	910	861	895	822	849	867	835	823	898	861	891	883	876	
	2号炉	899	894	912	906	901	884	879	881	907	938	933	949	885	889	909	892	889	870	894	894	882	886	872	934	
20	1号炉	896	881	886	839	880	897	838	840	899	882	892	907	883	875	875	880	916	895	849	844	868	898	885	851	
	2号炉	916	895	893	901	912	910	917	886	922	944	938	955	910	896	891	915	908	935	924	894	897	905	885	904	
21	1号炉	855	851	820	827	833	865	882	881	902	912			1,069	869	847	827	869	882	855	866	844	847	859	879	
	2号炉	889	897	875	900	893	911	879	883	903	900	910	869	908	959	942	899	879	924	936	911	909	896	926	920	
22	1号炉	919	838	848	849	835	876	860	866	861	787	913	928	901	917	880	920	927	877	822	857	874	895	912	877	8:55~9:32給じん停止
	2号炉	962	888	897	908	870	910	883	867	888	809	936	908	903	945	919	947	917	889	885	930	918	931	967	918	
23	1号炉	902	868	869	857	901	915	881	874	888	914	989	954	922	871	899	871	865	882	907	886	880	839	839	856	
	2号炉	953	895	913	919	897	902	907	911	943	937	904	939	915	907	922	937	903	911	915	920	915	890	893	894	
24	1号炉	849	878	872	877	881	871	825	861	804	746															定常運転~立ち下げ
	2号炉	899	899	896		856	892	901	904	857	896	945	963	921	934	872	895	874	906	892	903	897	917	929	950	
25	1号炉																									休炉
	2号炉	922	955	862	852	1,021	970	892	927	861	870	896	867	878	899	894	896	919	854	875	902	862	881	973	871	
26	1号炉																									休炉
	2号炉	867	900	913	888	929	844	878	844	844	874	832	842	830	887	897	881	874	910	889	889	876	885	906	887	
27	1号炉																									休炉
	2号炉	890	888	877	877	895	910	912	926	897	896	907	882	868	864	912	863	924	887	889	891	879	867	862	871	
28	1号炉																									休炉
	2号炉	866	923	898	888	910	906	924	961	873	876	910	889	904	874	939	859	827	872				877	872	853	
29	1号炉																									休炉
	2号炉	852	880	901	872	887	867	880	882	826	805	854	888	887	887	881	905	887	897	878	888	881	867	898	783	23:10~24:00給じん停止
30	1号炉																									休炉
	2号炉	933	853	865	865	888	899	875	885	871	895	912	901	888	880	864	882	869	889	886	868	886	892	897	885	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	882	861	870	866	894	898	878	877	875	910	943	852	892	900	851	846	876	863	845	891	892	852	851	839	
2	1号炉																									休炉
	2号炉	873	901	902	874	871	877	864	868	872	869	855	857	866	898	913	919	850	821	853	914	892	864	873	925	
3	1号炉																									休炉
	2号炉	861	900	876	874	868	871	892	899	893	880	860	881	870	863	887	872	895	910	899	888	863	859	897	923	
4	1号炉																									休炉
	2号炉	864	860	842	923	903	832	873	870	867	878	929	883	872	866	883	865	837	882	876	857	875	869	865	862	
5	1号炉																									休炉
	2号炉	878	873	876	875	862	866	872	861	876	875	869	887	879	893	874	895	898	881	879	878	880	873	890	881	
6	1号炉																									休炉
	2号炉	860	891	877	852	862	869	889	871	797	908	853	885	869	865	887	896	896	881	892	888	899	883	862	889	8:33~8:53給じん停止
7	1号炉																									休炉
	2号炉	882	868	886	896	885	863	868	852	856	891	915	922	892	894	892	902	876	883	886	869	879	883	899	908	
8	1号炉																									休炉
	2号炉	883	885	926	911	865	905	879	855	845	847	892	910	876	922	965	944	916	915	851				866	819	
9	1号炉					825	858	933	793	884	908	901	858	876	903	925	868	858	930	948	910	900	913	876	立ち上げ~定常運転 8:55~9:18給じん停止	
	2号炉	862	839	839	848	873	856	831	849	860	900	872	846	865	840	905	900	854	872	870	858	883	853	869	842	
10	1号炉	879	907	760	872	847	788	841	883	889	929	940	851	917	877	898	918	931	922	911	912	886	856	887	856	2:17~3:05、5:48~6:10給じん停止
	2号炉	865	892	919	878	867	896	872	870	883	889	870	882	857	875	883	928	854	835	860	879	871	865	895	935	
11	1号炉	863	895	936	937	889	920	895	886	893	952	936	931	955	909	884	903	944	943	846	879	892	887	895	865	
	2号炉	895	906	919	879	897	874	874	889	843	895	890	852	892	868	855	886	889	816	868	855	883	883	859	910	
12	1号炉	858	838	846	813	840	874	880	896	872	900	880	887	896	903	873	881	938	902	896	900	921	888	890	930	
	2号炉	881	839	847	844	839	884	916	849	882	905	893	897	894	863	876	883	930	865	837	869	888	869	880	873	
13	1号炉	953	926	887	872	885	922	882	899	882	813		960	951	929	899	863	950	968	936	936	920	905	853	940	
	2号炉	903	870	873	862	864	947	879	851	875	786	888	920	906	894	891	940	900	890	916	910	903	873	882	899	9:03~9:36給じん停止
14	1号炉	891	886	922	880	939	931	843	927	939	989	951	946	894	903	926	902	960	898	828	874	873	847	903	846	
	2号炉	862	879	886	894	890	903	905	940	882	930	962	910	876	916	884	882	960	911	866	866	869	866	881	870	
15	1号炉	885	922	898	891	917	892	844	860	842	899	926	988	953	916	862	898	923	897	918	913	895	876	869	893	
	2号炉	843	860	846	856	869	849	855	846	879	865	862	876	889	863	889	864	862	863	865	876	883	868	864	867	

6月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉	847	854	853	861	857	862	886	887	887	892	899	909	878	888	882	876	896	851	811						829	
	2号炉													702	897	908	900	891	864	886	888	895	901	884	882		立ち上げ～定常運転
17	1号炉	907	863	865	834	885	868	867	838	860	781	895	881	891	906	868	860	867	857	825	873	878	893	871	886		8:57～9:34給じん停止
	2号炉	872	924	885	890	916	887	938	900	904	916	889	899	929	928	922	904	922	904	902	885	907	901	899	913		
18	1号炉	882	898	898	893	905	873	894	863	887	870	882	899	854	865	862	859	856	883	876	873	879	888	858	857		
	2号炉	895	923	957	964	940	918	921	913	900	915	963	922	932	913	927	887	903	897	880	876	877	887	885	885		
19	1号炉	853	858	879	885	867	848	911	844	842	856	828	850	882	924	909	863	935	855	849	851	907	866	904	906		
	2号炉	876	898	905	943	916	934	858	939	921	928	987	922	874	893	917	902	887	900	903	911	895	892	893	891		
20	1号炉	906	892	902	866	892	913	892	907	899	840	926	912	906	913	894	877	964	880	820	875	838	915	940	890		
	2号炉	894	899	899	915	916	906	891	897	883	874	899	872	888	924	952	936	985	919	901	897	880	909	879	901		
21	1号炉	885	896	905	910	889	896	896	904	901	923	871	914	894	888	888	902	881	900	877	908	910	894	883	889		
	2号炉	895	959	972	927	895	894	908	921	907	886	938	951	958	909	899	912	917	930	917	946	911	903	945	927		
22	1号炉	890	876	892	867	891	866	876	874	757																	定常運転～立ち下げ
	2号炉	941	910	898	906	917	913	910	922	902	904	942	888	870	879	876	895	879	882	885	925	916	873	901	898		
23	1号炉																										休炉
	2号炉	888	869	884	888	904	920	891	890	879	904	938	936	924	901	901	877	894	896	944	862	951	897	874	882		
24	1号炉																										休炉
	2号炉	891	955	917	893	988	913	899	899	899	779	936	951	902	882	924	958	942	1,000	861	877	913	913	911	942		9:00～9:43給じん停止
25	1号炉																										休炉
	2号炉	931	906	895	894	891	888	902	909	893	914	908	906	886	934	968	942	942	927	917	929	892	894	911	899		
26	1号炉																										休炉
	2号炉	886	853				976	901	880	910	906	913	897	878	909	904	919	883	891	937	892	908	884	894	892		
27	1号炉																										休炉
	2号炉	917	939	875	886	877	915	869	878	883	880	865	886	834	880	874	876	882	883	885	910	885	897	864	898		
28	1号炉																										休炉
	2号炉	911	952	962	907	898	917	936	911	933	875	870	866	894	872	890	889	889	910	910	907	969	902	888	888		
29	1号炉																										休炉
	2号炉	899	885	860	910	911	974	897	939	900	892	945	911	906	939	932	920	891	891	901	901	818	966	889	910		
30	1号炉																										休炉
	2号炉	904	920	967	952	852	940	906	906	867	882	908	898	895	909	889	908	891	866	892	826	854	877	882	879		

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	863	878	875	859	855	887	872	863	887	752	940	896	927	925	902	944	923	838				898	869	885	8:55~9:30給じん停止
2	1号炉																									休炉
	2号炉	881	891	886	885	861	856	870	862	891	884	886	900	892	852	872	867	895	876	860	871	897	883	917	898	
3	1号炉																									休炉
	2号炉	901	871	892	877	875	854	871	861	890	899	884	888	887	883	882	903	881	882	847		906	916	868	866	
4	1号炉																									休炉
	2号炉	872	904	873	888	882	885	886	875	884	881	886	884	902	867	924	860	898	865	854	860	867	867	872	869	
5	1号炉																									休炉
	2号炉	902	886	926	880	890	912	894	889	873	905	859	891	874	883	908	891	864	884	882	880	883	891	917	896	
6	1号炉																									休炉
	2号炉	856	690	633	876	893	893	849	906	871	899	917	938	944	926	904	923	895	870	890	870	882	883	914	899	1:10~2:47給じん停止
7	1号炉																									休炉
	2号炉	889	864	899	887	893	907	907	888	898	961	890	872	877	859	901	869	920	890	899	917	907	890	885	868	
8	1号炉																									休炉
	2号炉	890	896	891	919	912	890	893	897	887	713	919	897	916	924	940	929	927	888	882	887	867	917	881	902	9:00~9:46給じん停止
9	1号炉																									休炉
	2号炉	880	937	951	937	898	889	905	901	899	921	903	938	890	915	929	943	964	891	867	883	874	884	885	896	
10	1号炉																									休炉
	2号炉	872	899	891	886	859	889	882	907	880	895	902	891	884	877	879	895	899	851	863	870	887	882	926	886	
11	1号炉																									休炉
	2号炉	876	878	878	865	875	866	881	862	885	862	881	884	890	929	927	856	881	881	927	937	895	936	882	899	
12	1号炉																									休炉
	2号炉	934	896	876	887	865	893	888	885	885	902	874	870	879	888	889	895	906	888	877	885	879	895	899	892	
13	1号炉																									休炉
	2号炉	869	885	868	852	877	871	872	877	881	881	882	877	885	863	877	891	898	889	883	853	893	899	895	863	
14	1号炉																									休炉
	2号炉	864	888	876	860	867	880	869	872	886	892	902	891	873	865	883	877	877	882	869	887	851	862	868	900	
15	1号炉																									休炉
	2号炉	889	846	894	893	839	818	853	678							822	868	881	913	883	905	931	859	884	796	7:13~14:09、23:16~00:03給じん停止

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	915	886	894	861	880	867	857	862	871	896	912	912	907	878	866	920	908	910	899	915	928	953	936	942	
	2号炉																									休炉
2	1号炉	929	892	884	878	862	873	841	849	904	885	877	883	888	918	893	909	888	897	929	945	949	981	927	925	
	2号炉																									休炉
3	1号炉	935	879	888	893	890	898	865	879	878	939	932	922	934	929	926	685			903	915	921	905	893	898	15:15~18:02給じん停止
	2号炉																									休炉
4	1号炉	882	912	930	934	974	931	931	939	949	967	992	930	948	968	934	955	959	883	899	950	967	913	939	973	
	2号炉																									休炉
5	1号炉	926	968	961	991	993	927	931	959	931	818	956	933	934	942	918	952	897						894	935	935
	2号炉																									休炉
6	1号炉	916	979	1,028	997	1,012	979	940	994	996	960	967	976	965	978	986	985	973	974	944	946	937	957	949	945	
	2号炉																									休炉
7	1号炉	965	978	959	955	945	1,008	1,013	982	970	955	967	956	964	958	975	943	949	961	956	961	966	976	968	948	
	2号炉																									休炉
8	1号炉	1,003	970	958	954	968	988	1,004	943	988	968	946	916	935	1,056	1,004	989	993	978	957	973	992	961	966	963	
	2号炉																									休炉
9	1号炉	965	987	988	968	953	958	977	946	944	944	953	950	941	980	952	965	984	960	972	973	989	995	967	964	
	2号炉																									休炉
10	1号炉	993	1,027	938	949	1,001	956	940	976	972	981	994	992	1,005	962	973	979	982	957					935	899	
	2号炉																									休炉
11	1号炉	944	874	860	923	962	977	953	945	977	957	961	961	965	972	977	980	961	950	946	979	950	985	982	946	
	2号炉																									休炉
12	1号炉	938	943	945	955	952	963	953	925	964	863	973	1,014	970	974	973	987	950	980	923	957	1,040	964	999	990	
	2号炉																									休炉
13	1号炉	979	949	955	956	973	980	957	1,014	985	971	987	1,001	804	971	973	970	978	1,028	886	949	968	969	956	989	
	2号炉												620	867	950	845	831	885	915	882	899	917	888	894	937	立ち上げ~定常運転
14	1号炉	951	963	950	956	965	955	953	958	960	992	1,009	977	956	971	965	971	965	953	963	946	938	1,000	997	940	
	2号炉	901	918	920	925	936	900	903	905	945	935	923	957	963	901	961	873	770	924	917	881	835	892	881	917	15:40~16:33給じん停止
15	1号炉	962	986	968	956	961	1,008	990	923	909							960	960	940	913	954	950	931	959	974	
	2号炉	913	917	898	923	927	884	911	865	892	918	883	890	923	909	906	886	869	913	870	842	873	918	922	877	

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	1,009	946	988	995	932	973	997	966	947	960	948	958	967	947	946	957	953	993	961	968	986	975	964	956	
	2号炉	865	920	912	898	889	897	893	894	906	879	872	871	888	877	858	888	892	895	895	883	897	915	946	896	
17	1号炉	956	955	948	961	1,012	956	949	956	944	982	983	979	969	971	962	959	981	951	946	946	939	947	963	948	
	2号炉	886	919	902	905	917	879	868	872	872	958	918	766	901	821	874	865	843	856	850	859	855	857	875	840	10:51~11:30給じん停止
18	1号炉	965	943	937	964	978	985	971	977	948	963	975	955	982	971	974	961	959	910					972	882	
	2号炉	862	849	851	874	876	850	856	858	855	856	859	843	864	867	876	743	853	851	839	872	882	889	873	896	14:57~15:47給じん停止
19	1号炉	966	950	914	953	952	933	964	948	995	845	971	963	947	946	973	957	944	937	961	973	954	958	949	993	
	2号炉	882	886	932	953	907	892	909	891	922	818	936	926	886	912	925	930	916	869	901	885	933	892	904	895	
20	1号炉	993	978	949	952	958	977	960	955	950	952	967	967	967	969	945	944	954	965	953	963	993	975	955	947	
	2号炉	916	913	906	904	916	928	880	887	911	944	929	790	888	797	920	938	883	892				989	890	922	11:04~11:42、 12:49~13:24給じん停止
21	1号炉	957	963	953	945	955	967	942	952	939	950	937	956	949	951	951	945	959	972	959	980	953	954	937	946	
	2号炉	909	887	891	885	871	863	876	865	898	869	892	891	874	870	861	867	863	906	887	894	882	893	881	890	
22	1号炉	947	940	942	934	962	959	946	956	972	961	950	951	954	936	936	917	956	943	956	954	956	966	959	960	
	2号炉	902	884	864	879	894	882	894	867	873	879	876	892	875	883	916	901	864	892	875	865	893	908	906	926	
23	1号炉	968	954	954	966	952	950	934	1,003	955	969	955	953	956	953	964	928		973	956	992	948	974	873	853	
	2号炉	908	890	893	879	871	863	884	874	857	881	864	864	870	884	850	872	866	882	884	878	893	896	884	889	
24	1号炉	971	939	949	944	937	938	948	944	966	986	980	976	982	944	965	975	965	946	949	956	939	954	958	940	
	2号炉	905	872	868	881	903	892	886	888	896	901	908	900	845	909	874	880	888	876	888	877	882	859	885	888	
25	1号炉	951	949	946	941	955	942	934	933	946	974	960	961	933	959	941	943	932	987	976	938	954	960	952	962	
	2号炉	874	858	870	862	891	897	882	871	871	872	887	892	902	888	885	837	860	898	858	847	852	869	854	871	
26	1号炉	965	950	974	967	960	951	951	937	931	780	952	938	952	976	982	978	981	946	956	945	944	943	937	953	8:53~9:22給じん停止
	2号炉	885	849	895	903	873	894	890	885	902	770	914	915	862	884	862	881	884	898	915	929	896	902	912	887	9:16~9:48給じん停止
27	1号炉	930	965	945	950	942	932	945	930	939	933	945	943	961	936	942	940	963	936	927	920	921	927	918	935	
	2号炉	921	891	859	930	895	890	856	887	908	900	902	877	875	872	928		907	872	883	890	868	888	872	889	
28	1号炉	924								765	925	962	947	949	938	940	942	946	931	932	933	949	931	957	953	0:53~8:40給じん停止
	2号炉	885	911	869	892	912	925	911	934	894	886	878	881	888	908	886	898	917	903	898	915	929	874	869	883	
29	1号炉	937	940	953	946	927	926	930	948	963	935	957	949	931	943	940	932	937	949	955	959	948	947	932	935	
	2号炉	887	857	853	896	892	917	896	824	889				895	885	892	864	891	850	853	902	882	880	880	880	
30	1号炉	937	953	964	945	934	962	944	958	952	956	944	936	942	956	949	958	962	965	954	948	959	941	960	953	
	2号炉	895	900	875	907	904	865	890	888	901	874	866	900	872	868	907	914	895	889	896	899	877	932	908	903	
31	1号炉	938	946	949	939	957	945	987	980	950	957	954	944	951	939	948	941	942	958	941	949	950	942	969	962	
	2号炉	890	863	887	904	902	873	829	859	893	795	761	891	921	692	867	843	866	881	857	855	855	827	872	900	9:29~10:27、 13:14~14:09給じん停止

