

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	993	914	924	924	955	982	961	960	973	922	919	941	934	936	889	918	939	933	911	687				967	19:11~23:08給じん停止
	2号炉									658	928	977	968	975	995	988	944	965	944	944	934	947	958	972		立ち上げ~定常運転
2	1号炉	950	963	950	917	915	928	910	920	930	929	940	921	929	892	875	908	1,036	970	957	1,010	974	971	962	957	
	2号炉	950	973	965	956	966	938	951	902	950	947	964	961	928	955	954	948	963	943	919	898	912	925	918	923	
3	1号炉	954	961	831				951	958	947	963	988	986	989	961	975	969	967	968	974	960	976	978	999	991	
	2号炉	920	940	921	927	919	917	940	941	949	926	945	950	955	937	952	943	954	931	867					951	
4	1号炉	995	979	978	970	951	960	968	970	980	952	952	956	973	964	978	979	972	968	948	997	986	1,039	1,006	964	
	2号炉	931	962	935	934	933	908	937	933	932	917	935	938	927	947	919	913	937	932	925	939	924	922	917	920	
5	1号炉	978	1,022	1,015	952	983	955	972	966	967	978	971	967	980	920	1,001	976	974	989	960	1,000	972	961	971	975	
	2号炉	943	917	944	948	959	933	936	939	967	934	969	964	917	929	934	917	924	911	921	951	923	934	925	923	
6	1号炉	992	1,003	987	964	1,004	982	989	968	980	971	969	995	960	942	945	994	1,014	972	967	953	974	987	952	945	
	2号炉	939	952	926	926	932	953	956	946	942	931	914	932	908	931	915	935	878	911	921	943		931	909	916	
7	1号炉	957	942					950	955	940	828	987	973	1,027	975	957	974	1,018	972	1,004	961	927	966	968	949	
	2号炉	915	909	899	891	922	922	934	895	924	880	890	932	947	973	858	854	971	941	939	929	926	955	929	929	
8	1号炉	957	964	949	952	951	946	963	958	953	987	976	951	933	910	904	898	904	898	893	916	907	941	949	883	
	2号炉	940	918	928	911	904	925	917	904	918	923	929	922	934	898	894	909	907	908	907	903	908	933	910	925	
9	1号炉	918	888	902	891	876	864	864	909	918	913	916	933	917	905	889	907	902	911	902	901	897	912	923	906	
	2号炉	955	944	905	918	900	901	898	886	913	906	904	914	900	936	902	927	930	932	933	924	912	924	931	935	
10	1号炉	899	908	900	884	906	890	887	874	896	909	971	965	973	1,022	1,015	963	962	1,002	996	1,024	959	996	957		
	2号炉	939	902	921	978	962	945	947	949	945	916				948	915	915	914	918	947	932	913	936	900		
11	1号炉	1,003	1,019	990	974	1,003	969	964	955	955	955	955	955	967	953	967	957	973	986	967	960	993	980	984	986	
	2号炉	906	933	935	926	944	930	996	997	997	997	997	997	984	935	946	940	943	942	928	928	928	924	926	923	
12	1号炉	930			922	984	1,005	1,000	981	968	962	982	979	990	956	970	972	973	957	959	963	963	976	983	964	
	2号炉	927	905	934	926	924	940	913	908	936	965	939	906	947	926	933	947	924	925	911	934	925	911	921	914	
13	1号炉	980	975	985	979	980	959	958	967	963	989	948	942	1,003	978	1,028	979	973	966	1,037	955	962	963	973	963	
	2号炉	938	918	917	909	914	920	932	903	924	927	913	905	898	912	927	887	896	897	906	954	899	900	891	893	
14	1号炉	970	974			977	972	974	983	990	861	970	973	967	974	1,004	945	997	928	985	953	967	970	963	1,048	
	2号炉	906	898	922	913	901		935	979	907	843	924	919	881	920	915	888	939	897	905	900	916	895	898	913	
15	1号炉	978	966	964	956	984	957	966	979	1,013	985	1,004	973	961	975	956	969	958	947	958	978	957	958	959	943	
	2号炉	927	920	922	908	901	922	946	928	935	932	964	822	909	919	916	899	903	913	875	902	892	890	881	888	

10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	955	982	956	973	967	938	954	929	949	951	952	943	957	957	936	970	966	943	952	987	992	954	936	947	
	2号炉	883	913	900	880	896	868	875	898	910	920	882	914	896	881	908	893	903	899	906	889	908	897	853	865	
17	1号炉	938	945	953	954	958	944	950	939	969	968	1,014	1,003	956	992	995	1,000	1,009	984	967	985	950	963	942	956	
	2号炉	889	892	886	879	907	844	884	866	898	886	945	951	879	910	912	942	927	926	893	887	876	886	889	875	
18	1号炉	963	958	924	982	981	958	960	954	958	965	955	967	946	960	950	982	944		498	955	983	960	969	907	16:58~18:54給じん停止
	2号炉	877	908	883	878	887	872	893	878	880	874	874	872	879	881	895	880	882	901	890	902	889	879	880	880	
19	1号炉	890	957	942	1,027	956	952	937	945	944	882	976	966	927	999	980	958	946	990	968	941	940	951	973	949	
	2号炉	883	901	935	940	925	937	931	938	959	938	949	938	945	925	929	949	942	977	948	944	921	930	939	914	
20	1号炉	962	931	955	933	939	941	956	936	959	976	977	955	959			931	792	841	959	916	940	933	949	932	16:30~17:33給じん停止
	2号炉	956	921	933	917	915	921	904	936	950	935	952	954	798	952	991	887	991	902	915	919	911	925	913	913	12:27~13:04給じん停止
21	1号炉	942	943	966	958	964	926	937	928	938	767	942	949	968	966	957	956	960	955	972	956	983	958	972	957	9:04~9:35給じん停止
	2号炉	912	905	905		1,017	919	916	902					845	969	942	936	926	926	936	917	903	997	950	933	923
22	1号炉	931	957	939	948	959	933	939	974	945	945	964	961	975	949	945	892	966	933	923	943	941	937	967	937	
	2号炉	938	902	911	928	935	907	940	976	935	924	912	964	922	921	935	935	924	921	891	902	901	904	906	898	
23	1号炉	934	929	954	969	962	971	972	936	975	896		729	964	945	959	893	931	928	956	1,050	1,003	959	969	969	9:45~11:42給じん停止
	2号炉	907	902	908	929	912	899	905	936	921	918	929	927	938	918	910	908	909	901	923	910	903	899	895	906	
24	1号炉	980	970	948	960	968	956	962	958	937	960	959	943	951	954	938	939	963	927							
	2号炉	920	933	969	917	925	899	900	918	932	928	913	915	903	928	912	916	916	919	897	901	887	889	888	876	
25	1号炉	685	958	946	953	939	993	960	948	948	936	949	927	932	945	938	964	954	972	936	982	962	944	942	969	前日17:33~00:34給じん停止
	2号炉	823	859	907	934	884	885	895	895	901	898	917	886	890	884	897	892	880	913	899	908	889	871	905	868	
26	1号炉	954	980	968	931	968	958	947	955	931	969	962	993	970	974	908	982	967	933	932	934	937	963	971	955	
	2号炉	906	905	971	905	893	904	885	913	902	881					881	875	884	855	848	847	877	870	908	875	
27	1号炉	961	965	930	967	979	958	965	947	980	941	963	931	922	953	929	956	969	962	955	961	983	952	970	961	
	2号炉	879	873	856	887	876	875	875	870	879	889	883	885	868	870	854	872	905	886	883	893	894	886	878	894	
28	1号炉	961	944	931	951	955	945	972	945	949	799	955	941	945	955	985	971	965	965	962	945	939	848	931	910	9:05~9:35給じん停止
	2号炉	878	877	879	880	878	881	913	910	939	816	965	910	942	949	948	923	931	940	920	934	947	936	915	956	
29	1号炉	889	927	953	954	954	940	964	961	954	960	1,004	953	933	999	948	939	936	952	970	943	961	928	971		
	2号炉	914	927	928	909	928	925	893	946	918	908	900	891	892	905	912	921	931	852		971	940	947	919	891	
30	1号炉	967	949	950	1,002	953	952	946	940	961	970	967	975	954	957	942	945	957	949	966	947	931	956	959	942	
	2号炉	900	903	904	912	920	899	877	890	900	908	950	910	893	886	806	895	944	894		970	903	909	931	916	
31	1号炉	960	903	940	945	919	948	981	954	924	888			910	918	945	928	940	930	926	935	949	975	973	976	
	2号炉	931	869	858	947	934	947		921	862	917	927	938	944	946	874	941	933	945	938	932	936	965	949	959	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	966	939	963	940	928	964	965	928	939	942	939	951	984	953	934	949	953	938	949	948	946	983	993	953	
	2号炉	965	940	937	948	934	942	937	938	961	933	924	958	920	936	908	914	930	929	938	917	931	926	968	928	
2	1号炉	965	972	971	964	942	959	971	953	941	965	961	966	968	971	942	956	959	948	926	938	932	938	941	935	
	2号炉	924	910	925	939	924	898	927	963	933	933	941	948	918	910	922	913	919	913	895	894	903	925	917	904	
3	1号炉	943	972	967	957	966	972	983	946	963	966	936	961	950	954	922	939	946	936	952	933	951	957	929	938	
	2号炉	925	930	921	919	923	956	947	908	962	957	892	895	912	945	950	924	956	943	953	929	923	931	919	905	
4	1号炉	938	951	988	951	958	960	938	934	951	844	946	958	957	964	930	964	970	951	933	932	945	940	917	919	
	2号炉	925	915	938	951	937	940	938	912	938	772	945	925	913	907	941	923	933	944	915	913	903	890	881	882	9:30~10:00給じん停止
5	1号炉	954	982	979	974	941	938	936	935	930	947	943	917	962	946	951	941	950	971	936	930	943	927	916	907	
	2号炉	881	938	920	919	898	920	906	899	890	914	918	922	915	921	907	903	916	891	873	888	837	905	903	892	
6	1号炉	931	941	960	952	940	934	959	940	850																定常運転~立ち下げ
	2号炉	918	915	902		920	907	909	927	903	908	927	965	938	949	910	918	933	929	912	889	916	908	896	891	
7	1号炉																									休炉
	2号炉	905	908	909	893	913	894	899	927	891	886	929	904	910	892	922	920	912	896	912	894	888	907	897	924	
8	1号炉																									休炉
	2号炉	890	895	928	930	952	903	893	906	896	898	901	909	899	897	907	907	899	933	937	948	928	921	904	932	
9	1号炉																									休炉
	2号炉	923	907	921	906	893	912	927	877	898	922	924	923	916	929	911	917	905	897	933	920	920	885	905	950	
10	1号炉																									休炉
	2号炉	958	897				937	905	914	899	930	906	893	918	911	907	914	926	946	969	913	912	940	898	913	
11	1号炉																									休炉
	2号炉	930	907	872	904	897	908	917	898	916	818	931	907	917	928	905	883	916	916	922	892	905	928	888	944	
12	1号炉																									休炉
	2号炉	950	949	932	904	917	932	914	909	934	931	949	943	939	910	906	920	942	879	894	920	884	879	880	896	
13	1号炉																									休炉
	2号炉	875	885	897	880	900	918	890	880	890	851	882	904	881	896	888	921	949	935	952	902	902	898	882	879	
14	1号炉												844	851	892	881	910	930	941	928	935	904	884	861		立ち上げ~定常運転
	2号炉	872	924	895	906	917	900	887	896	906	913	955	961	946	887	937	954	902	940	929	908	928	896	888	895	
15	1号炉	867	938	909	906	905	911	920	945	960	935	928	914	942	923	958	940	926	934	949	934	934	958	957	966	
	2号炉	902	896	898	901	917	933	922	913	896	943	921	931	922	890	915	922	881	892	914	905	906	924	912	913	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成27年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	963	954	938	926	935	938	935	944	940	945	954	975	975	952	954	974	979	961	942	936	959	966	953	951	
	2号炉																									休炉
2	1号炉	961	937	942	953	957	954	952	940	944	850	970	959	953	943	953	958	964	956	963	956	951	956	943	951	
	2号炉										651	851	876	927	885	861	866	883	795	863	873	899	888	915	911	立ち上げ～定常運転
3	1号炉	964	940	946	962	962	971	973	969	824	981	943	945	975	980	942	966	961	941	967	971	960	957	983	983	
	2号炉	865	883	906	915	875	918	902	875	938	954	926	937	920	915	901	901	909	894	895	898	908	876	918	915	
4	1号炉	983	964	984	971	1,004	958	970	952	944	930	881	989	961	954	966	965	953	943	926	940	959	924	935	935	
	2号炉	919	879	906	939	935	899	927	917	915	927	932	897	918	897	913	910	895	898	889	893	879	848	909	906	
5	1号炉	957	945	925	975	918	946	956	935	956	968	970	964	988	949	972	959	966	975	974	963	998	874	798		22:25～翌日1:18給じん停止
	2号炉	930	951	962	968	969	940	932	961	923	931	941	942	968	925	909	922	933	891	922	895	915	930	944	935	
6	1号炉		893	980	1,006	958	953	965	968	951	951	985	971	954	955	982	967	967	981	978	955	955	940	946	933	
	2号炉	884	895	899	910	900	923	901	963	893	839	951	930	913	911	932	857	887	907	915	873	886	899	880	877	
7	1号炉	955	950	965	959	961	973	957	980	957	951	946	977	1,011	978	996	999	968	974	949	944	951	956	992	942	
	2号炉	900	909	871	909	878	888	887	875	870	875	878	863		864	896	889	892	877	873	904	925	945	922	953	
8	1号炉	962	940	918	939	943	958	959	947	955	903	953	956	967	960	949	942	976	975	949	961	946	939	982	987	
	2号炉	950	973	959	927	925	909	924	906	935	906	939	934	958	957	930	947	960	909	911	910	916	915	914	960	
9	1号炉	991	958	982	978	950	941	946	941	952	831									895	876	897	942	934	919	
	2号炉	988	942	965	959	927	901	907	908	912	931	876	1,022	960	948	937	941	949	944	960	958	946	937	896	896	
10	1号炉	936	932	954	930	938	938	931	929	930	929	918	931	926	931	934	924	934	932	923	946	928	930	943	980	
	2号炉	912	868			870	904	912	906	889	913	904	927	904	899	941	914	895	907	908	921	887	898	915	912	
11	1号炉	949	933	959	949	995	963	961	942	956	947	948	938	952	933	931	947	944	959	942	954	963	953	959	939	
	2号炉	940	862	877	896	889	890	935	929	917	911	932	926	937	917	900	930	926	930	903	909	912	893	886	933	
12	1号炉	944	963	949	957	963	960	944	984	952	947	949	960	948	952	961	953	949	954	881	984	973	964	945	926	
	2号炉	898	931	903	915	916	927	924	968	906	955	929	906	890	923	897	908	902	910	923	911	934	903	915	923	
13	1号炉	933	948	965	955	970	934	958	962	966	934	961	958	947	944	962	974	947	909	961	983	966	932	946	950	
	2号炉	889	919	959	920	885	925	940	896	936	919	926	893	883	897	911	927	901	898	905	921	903	911	905	900	
14	1号炉	964	963	971	957	950	933	947	949	951	942	955	950	935	916	923			932	745						定常運転～立ち下げ
	2号炉	912	898	898	922	917	905	876	882	900	861	900	894	885	897	884	881	875	905	896	896	887	877	867	870	
15	1号炉																									休炉
	2号炉	863	865	874	910	906	912	881	966	969	956	1,004	1,015	935	938	960	924	924	951	919	928	952	906	936	918	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成28年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉																									休炉
2	1号炉																									休炉
	2号炉																									休炉
3	1号炉																									休炉
	2号炉																									休炉
4	1号炉																									休炉
	2号炉																									休炉
5	1号炉								706	867	919	963	928	905	881	865	897	946	943	914	895	934	962	969		立ち上げ～定常運転
	2号炉																									休炉
6	1号炉	929	932	975	950	914	939	984	969	950	946	989	951	951	999	977	989	1,002	993	1,004	987	988	1,005	1,017	1,009	
	2号炉													707	869	889	935	886	866	844	901	945	970	996		立ち上げ～定常運転
7	1号炉	1,014	984	1,019	1,052	1,026	1,017	996	987	1,011	985	986	1,000	983	1,009	1,041	1,020	1,001	1,003	986	971	987	1,010	971	983	
	2号炉	956	961	984	991	995	956	962	947	955	930	973	950	947	979	1,006	966	1,004	949	931	950	965	965	960	965	
8	1号炉	1,002	995	992	999	978	982	990	989	980	988	980	1,011	1,014	998	979	993	1,055	995	995	997	1,018	1,017	985	981	
	2号炉	981	996	1,002	977	988	977	1,004	979	984	1,010	965	972	987	990	975	987	981	986	965	977	973	988	971	965	
9	1号炉	988	1,024	1,021	991	990	988	1,001	1,001	1,002	1,003	1,020	976	1,001	975	1,023	992	983	1,027	1,081	1,013	1,008	995	1,018	1,047	
	2号炉	988	949	956	930	1,005	982	995	1,032	1,019	1,002	991	1,003	995	1,023	1,035	982	982	991	1,018	978	1,012	957	983	1,004	
10	1号炉	1,026	1,008	1,013	1,005	993	1,007	1,014	1,034	1,059	1,058	1,063	1,040	1,027	1,025	1,013	1,036	1,047	1,027	1,042	1,024	1,063	1,032	1,029	1,027	
	2号炉	1,019	1,002	1,001	975	998	983	1,002	1,015	1,016	1,014	1,016	1,007	1,016	987	1,018	1,036	997	1,024	1,035	1,045	1,037	1,047	1,041	1,012	
11	1号炉	1,059	1,042	1,032	1,021	1,051	1,056	1,073	1,039	1,068					998	986	1,027	1,015	1,018	1,004	1,041	1,046	1,056	1,018	1,008	
	2号炉	1,048	1,028	1,061	1,032	1,078	1,035	1,070	1,072	1,050	1,079	971	923	872	1,031	986	1,063	1,033	1,053	999	1,042	1,023		1,041	1,052	
12	1号炉	982	993	1,000	1,033	1,047	1,023	941	977	997	974	977	1,012	1,022	985	999	1,014	1,028	999	971	955	980	1,004	1,026	1,000	
	2号炉	1,077	1,055	1,066	1,030	1,080	1,079	959	965	1,013	976	1,017	1,100	749	1,004	1,055	991	1,031	892				1,005	1,007	1,018	12:00～12:48給じん停止
13	1号炉	1,000	991	1,008	996	1,010	995	971	961	990	795	997	997	1,000	976	981	985	1,007	966	976	995	988	977	977	1,006	8:56～9:28給じん停止
	2号炉	1,044	983	967	964	978	991	956	955	965	854	960	999	978	1,004	964	998	979	1,000	978	980	962	977	968	986	
14	1号炉	1,002	989	1,022	1,028	992	1,035	1,010	1,006	1,009	1,018	1,020	1,014	1,027	1,000	972	973	1,034	1,034	1,035	1,024	988	971	1,014	981	
	2号炉	991	993	978	971	1,026	1,023	992	993	1,012	970	991	976	950	948	935	964	993	1,002	1,007	1,001	958	960	979	953	
15	1号炉	968	957	959	962	980	976	1,006	967	977	976	985	963	978	974	990	1,031	1,031	991	998	987	966	1,012	1,001	979	
	2号炉	945	962	960	982	976	979	992	956	942	975	978	1,001	987	996	992	1,066	1,054	950	937	885	992	999	991	935	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成28年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	942	871	920	915	918	920	929	938	926	957	962	934	986	939	951	944	943								定常運転～立ち下げ
	2号炉																									休炉
2	1号炉															771	842	880	836	849	909	904	863	924		立ち上げ～定常運転
	2号炉																									休炉
3	1号炉	888	955	945	952	949	929	925	941	932	929	927	933	914	939	935	940	934	917	938	938	970	913	901	903	
	2号炉																									休炉
4	1号炉	906	905	915	911	943	938	927	929	929	922	905	926	933	912	906	902	894	902	905	907	910	885	906	903	
	2号炉																									休炉
5	1号炉	920	914	934	929	927	936	940	916	906	912	919	895	956	906	897	911	899	857	895	901	904	921	918	917	
	2号炉																									休炉
6	1号炉	893	928	890	902	915	927	934	928	939	943	922	932	927	916	922	907	926	917	950	928	905	926	941	942	
	2号炉																									休炉
7	1号炉	959	985	986	985	968	786		886	947	943	934	977	951	942	945	939	945	942	910	935	913	921	880	848	5:16～7:15給じん停止
	2号炉																									休炉
8	1号炉	947	949	968	947	951	988	958	979	958	973	966	945	945	953	958	978	969	887	924	912	932	953	946	861	
	2号炉																									休炉
9	1号炉	958	949	927	961	952	958	953	938	936	947	946	937	1,027	972	949	964	959	964				849	936	933	
	2号炉																									休炉
10	1号炉	930	937	957	960	916	938	934	933	954	739	939	989	990	1,018	976	961	969	970	965	941	945	954	960	969	8:56～9:36給じん停止
	2号炉																									休炉
11	1号炉	945	947	968	970	978	964	982	984	980	975	950	952	962	968	945	988	969	975	947	957	949	913	981	976	
	2号炉																									休炉
12	1号炉	993	963	995	977	990	924	963	976	974	976	981	992	1,047	1,004	1,035	988	1,027	994	990	939	995	981	956	979	
	2号炉																									休炉
13	1号炉	974	984	997	944	965	963	985	987	1,003	1,002	996	1,018	961	982	1,020	882	981	1,002	960	982	995	966	988	986	
	2号炉																									休炉
14	1号炉	989	968	966	977	995	1,002	1,017	1,003	1,028	984	967	1,009	1,003	996	992	1,003	969	996	997	999	1,000	1,006	974	968	
	2号炉																									休炉
15	1号炉	967	983	887	803	862	956	981	961	968	987	984	969	972	990	981	1,005	976	853							定常運転～立ち下げ
	2号炉														690	873	882	843	891	862	888	960	925	890	903	立ち上げ～定常運転

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉																									休炉
	2号炉	856	838	895	853	889	892	901	904	949	945	965	941	970	955	954	981	960	881	995	1,001	996	979	929	935	
17	1号炉																									休炉
	2号炉	932	935	907	914	943	948	967	978	950	929	969	960	954	949	973	949	943	934	950	964	1,035	966	971	957	
18	1号炉																									休炉
	2号炉	956	973	1,001	987	977	953	955	952	955	954	967	992	941	952	936	940	959	943	942	945	924	953	972	941	
19	1号炉																									休炉
	2号炉	949	939	972	927	971	1,016	981	974	940	938	1,009	934	942	958	934	932	938	921	922	938	932	928	939	934	
20	1号炉																									休炉
	2号炉	907	934	938	962	956	943	940	951	978	950	943	939	894	911	906	929	891	876	892	876	911	910	911	921	
21	1号炉																									休炉
	2号炉	892	874	878	889	890	890	937	920	927	946	954	935	925	920	919	915	962	930	915	921	916	905	868	899	
22	1号炉																									休炉
	2号炉	916	905	909	890	896	937	913	906	897	880	876	916	889	864	887	895	947				900	918	918	912	
23	1号炉																									休炉
	2号炉	922	951	936	863	909	894	899	896	947	929	918	959	881	898	871	913	860	938	947	948	962	944	923	941	
24	1号炉																									休炉
	2号炉	944	931	937	969	917	922	912	916	920	781	934	958	1,004	947	977	996	969	1,002	969	994	974	965	932	992	9:14~9:49給じん停止
25	1号炉																									休炉
	2号炉	971	885	969	958	1,001		945	945	955	977	977	975	967	951	952	937	951	937	911	978	988	981	945	967	
26	1号炉																									休炉
	2号炉	975	950	952	951	973	1,022	1,010	973	1,032	992	996	971	998	1,014	943	924	953	966	919	970		897	982	940	
27	1号炉																									休炉
	2号炉	912	961	965	1,036	975	942	961	956	957	940	967	947	945	965	965	939	943	984	947	953	936	977	949	989	
28	1号炉																									休炉
	2号炉	972	942	938	935	1,008	1,039	947	988	942	947	936	946	980	992	945	947	975	957	942	910	956	974	974	982	
29	1号炉																									休炉
	2号炉	969	953	910	935	947	943	916	912	950	952	955	939	946	939	895	923	912	863	897	889	934	897	855	917	

3月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	963	956	983	967	966	969	955	960	962	810	968	982	965	966	953	958	960	984	990	987	987	975	1,002	1,000	
	2号炉																									
17	1号炉	995	986	983	985	983	979	977	978	968	996	952	969	1,004	991	973	985	983	997	976	987	971	941	917	870	
	2号炉																									
18	1号炉	967	938	943	944	947	952	953	954	954	966	934	933	931	931	943	942	941	925	924	942	921	917	895	987	
	2号炉																									
19	1号炉	925	969	965	950	945	1,003	935	1,008	988	962	968	960	953	950	968	948	967	1,038	950	973	1,011	975	990	969	
	2号炉																									
20	1号炉	983	983	969	958	960	983	962	983	953	964	1,002	984	974	978	965	959	951	960	963	959	993	1,012	957	968	
	2号炉																									
21	1号炉	965	1,011	1,040	1,037	1,000	954	985	973	969	973	961	1,003	952	922	933	926	934	933	945	952	954	931	934	941	
	2号炉																									
22	1号炉	930	933	930	962	1,021	916	896	905	929	907	821	883	911	886	881	893	902	876					870	873	
	2号炉																									
23	1号炉	894	944	940	951	936	951	961	951	959	800	940	928	916	961	957	971	959	916	929	940	931	971	923	913	
	2号炉																									
24	1号炉	894	922	947	992	997	961	942	930	941	923	928	936	956	933	912	911	926	889	932	940	934	985	991	958	
	2号炉																									
25	1号炉	956	927	934	944	947	966	949	955	959	954	962	964	960	936	932	928	907	914	940	937	971	948	970	957	
	2号炉																									
26	1号炉	967	923	928	915	946	942	937	932	929	952	934	974	947	967	976	966	981	1,068	1,063	1,007	1,002	1,002	1,009	988	
	2号炉																									
27	1号炉	1,004	975	992	995	970	989	996	973	978	995	992	953	951	971	981	971	993	971	987	967	972	960	963	950	
	2号炉																									
28	1号炉	954	950	966	980	974	959	952	959	942	949	967	958	956	962	969	902	939	888						931	
	2号炉																									
29	1号炉	946	981	943	980	959	1,035	939	967	968	1,014	975	931	962	977	993	960	948	961	957	947	962	1,002	977	798	23:15～翌日0:12給じん停止
	2号炉																									
30	1号炉	956	1,012	950	987	997	994	977	991	1,010	722	999	1,009	986	989	1,001	1,002	1,044	1,036	953	994	1,021	1,023	905	876	9:25～10:05給じん停止
	2号炉												790	1,012	955	932	916	913	885	842	889	946	986	971	975	立ち上げ～定常運転
31	1号炉	990	981	1,016	977	979	927	985	1,019	969	1,000	994	975	986	965	970	971	1,026	1,017	985	981	1,006	976	996	993	
	2号炉	963	957	983	986	990	976	1,004	1,002	980	983	991	959	962	967	987	1,038	1,029		961	1,013	973	997	973	1,002	