

平成28年度 排ガス中のばい煙濃度等

4月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0.01	84	27	53	37	13	26	1	0	0	6	1	3
2	0.01	0	0.01	90	5	59	37	1	27.5	7	0	0.5	8	1	4
3	0.01	0	0.01	81	12	52.5	37	4	29.5	5	0	0	6	2	3.5
4	0.01	0	0.01	56	8	29	38	21	31.5	0	0	0	5	1	3
5	0.01	0	0.01	87	11	40.5	38	1	26	5	0	0	5	1	3
6	0.01	0	0.01	66	13	37	38	5	29.5	6	0	2	5	1	3
7	0.01	0	0.01	59	10	36.5	36	0	24	3	0	1	5	1	3
8	0.01	0	0.01	60	13	31.5	40	20	30.5	2	0	0.5	4	2	3
9	0.01	0	0.01	63	10	36	40	11	31.5	1	0	0	6	2	3.5
10	0.01	0	0.01	66	6	39	38	0	27	1	0	0	5	1	3.5
11	0.01	0	0.01	58	2	27	39	21	32.5	1	0	0	4	2	3
12	0.01	0	0	71	5	37.5	39	0	28	2	0	0	4	1	2
13	0.01	0	0.01	66	10	36	41	10	30.5	1	0	0	5	1	3
14	0.01	0	0.01	66	11	31.5	41	16	32.5	0	0	0	4	1	2.5
15	0.01	0	0.01	60	13	32	40	3	30.5	0	0	0	3	1	3
16	0	0	0	79	17	45	44	15	29	1	0	0	4	2	3
17	0	0	0	75	23	47	39	20	29	1	0	0	4	2	3
18	0	0	0	71	3	42	37	5	26	0	0	0	5	1	4
19	0	0	0	71	18	44	36	20	30	1	0	0	5	2	4
20	0	0	0	85	24	51	39	7	29	2	0	0	6	2	3
21	0	0	0	89	7	44	41	9	30	0	0	0	6	2	3
22	0	0	0	63	21	43	38	9	29	0	0	0	5	3	4
23	0	0	0	71	16	53	39	4	30	0	0	0	7	3	5
24	0	0	0	81	14	54	40	7	25	1	0	0	8	1	5
25	0	0	0	79	4	53	40	0	25	3	0	0	7	1	4
26	0	0	0	71	1	35	36	0	22	0	0	0	4	0	3
27	0	0	0	77	22	48	37	7	28	1	0	0	4	2	3
28	0.01	0	0	76	8	35	39	7	29.5	3	0	1	4	1	2.5
29	0.01	0	0	59	9	29	40	13	30.5	3	0	0.5	3	2	2.5
30	0.01	0	0.01	79	21	47.5	41	20	31.5	2	0	0.5	4	2	2.5

平成28年度 排ガス中のばい煙濃度等

5月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0.01	72	28	49.5	37	8	30	4	0	1	7	3	4.5
2	0.01	0	0.01	92	22	56.5	37	2	28.5	2	0	0.5	6	2	4
3	0.01	0	0.01	77	5	50	40	3	28.5	1	0	0	6	0	3
4	0.01	0	0.01	74	20	47.5	43	8	30.5	1	0	0	6	2	3
5	0.01	0	0.01	74	19	46.5	36	12	28.5	1	0	0	4	2	3
6	0.01	0	0.01	78	1	45	37	0	27	1	0	0	4	0	2.5
7	0	0	0	68	18	38	37	20	30	0	0	0	3	2	2
8	0	0	0	66	25	45	38	19	32	1	0	0	4	2	2
9	0	0	0	69	6	31	37	26	33	1	0	0	5	2	3
10	0	0	0	66	1	27	39	12	31	1	0	0	6	2	4
11	0	0	0	71	19	46	37	15	28	1	0	0	5	2	4
12	0	0	0	74	32	49	37	24	32	6	0	0	5	2	3
13	0	0	0	66	12	42	51	15	35	3	0	0	3	2	3
14	0	0	0	67	34	51	37	22	32	2	0	0	9	3	5
15	0	0	0	82	22	56.5	48	9	31.5	1	0	0	15	2	8
16	0.01	0	0	81	19	53	37	12	27	1	0	0	15	1	6.5
17	0.01	0	0	86	1	40.5	39	2	26	2	0	0	8	0	4
18	0	0	0	69	4	41.5	46	0	25	2	0	0	9	2	3.5
19	0	0	0	67	19	40	38	12	29.5	1	0	0	7	2	4
20	0.01	0	0	74	14	44.5	38	2	27.5	3	0	0	7	2	4
21	0.01	0	0	72	11	41	40	2	29	4	0	0	7	1	4
22	0.01	0	0	77	9	49.5	38	4	29	1	0	0	7	2	5
23	0.01	0	0	76	3	42	53	4	31.5	1	0	0	7	2	3.5
24	0.01	0	0	84	2	50	38	1	29	1	0	0	7	1	4.5
25	0.01	0	0	81	19	49	44	7	29	2	0	0	6	2	4
26	0.01	0	0	82	6	46	42	13	30.5	1	0	0	6	2	4
27	0.01	0	0	80	24	51.5	36	11	27.5	1	0	0	6	0	2.5
28	0	0	0	74	42	59	35	14	27	2	0	0	6	4	4
29	0	0	0	87	18	63	38	5	26	1	0	0	7	3	4
30	0	0	0	70	31	48	39	21	30	0	0	0	4	2	3
31	0.01	0	0	85	15	44	39	3	27	3	0	0	5	2	4

平成28年度 排ガス中のばい煙濃度等

6月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	87	27	54	38	9	29	6	0	1	5	3	4
2	0	0	0	81	31	56	40	17	31	1	0	0	6	2	4
3	0	0	0	72	23	51	41	24	34	0	0	0	6	3	4
4	0	0	0	76	41	59	42	11	31	1	0	0	5	3	4
5	0	0	0	75	18	56	38	2	30	2	0	0	5	2	4
6	0	0	0	73	4	41	40	3	29	0	0	0	5	0	4
7	0	0	0	82	7	51	39	0	26	2	0	0	5	1	3
8	0	0	0	60	14	39	52	15	38	1	0	0	4	2	3
9	0.01	0	0	82	15	45	44	23	34	0	0	0	7	3	4
10	0	0	0	81	23	51	37	6	27	1	0	0	4	2	3
11	0.01	0	0	81	36	61	41	21	31	1	0	0	6	2	4
12	0	0	0	71	41	60	38	12	29	1	0	0	5	2	3
13	0.01	0	0	79	8	57	40	2	25	1	0	0	4	1	3
14	0.01	0	0	78	1	47	40	1	28	1	0	0	4	0	2
15	0.01	0	0	77	24	46	37	17	31	1	0	0	5	2	4
16	0.01	0	0	82	31	49	41	12	30	1	0	0	6	2	3
17	0.01	0	0	71	17	37	40	10	30	0	0	0	3	1	2
18	0.01	0	0.01	83	6	40.5	42	3	28.5	4	0	1.5	3	0	1.5
19	0.01	0	0.01	71	5	39	41	15	33	1	0	0	4	1	2
20	0.01	0	0.01	62	4	32	43	19	34	0	0	0	4	2	3
21	0.01	0	0.01	52	2	19.5	46	3	31	1	0	0	4	1	3
22	0.01	0	0.01	54	3	23.5	46	6	31.5	1	0	0	4	2	2.5
23	0.01	0	0.01	64	4	30	42	16	31	1	0	0	5	1	2.5
24	0.01	0	0.01	61	1	26	45	12	31	2	0	0	5	2	3.5
25	0.01	0	0.01	71	4	32	44	3	30	1	0	0	7	2	4.5
26	0.01	0	0.01	83	18	45.5	41	17	28.5	1	0	0.5	6	0	3.5
27	0.01	0	0.01	70	6	34	65	5	32.5	1	0	0	6	1	2.5
28	0.01	0	0	59	1	33.5	58	0	24.5	2	0	0	6	0	3
29	0.01	0	0	74	1	31	37	0	25	10	0	0.5	5	1	3
30	0.01	0	0.01	66	7	40	35	10	26	4	0	0.5	6	2	4

平成28年度 排ガス中のばい煙濃度等

7月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	49	3	24	36	4	29	0	0	0	5	3	4
2	0	0	0	67	25	42	36	18	27	0	0	0	6	3	5
3	0	0	0	63	2	32	35	9	28	0	0	0	8	3	6
4	0	0	0	63	3	27	37	10	28	0	0	0	5	3	4
5	0	0	0	57	2	29	35	0	24	0	0	0	5	1	4
6	0	0	0	86	16	37	36	4	24	4	0	0	7	3	5
7	0	0	0	62	12	33	35	15	29	0	0	0	6	4	5
8	0	0	0	77	7	33	38	8	29	0	0	0	5	2	3
9	0	0	0	61	9	27	36	23	30	0	0	0	5	2	3
10	0	0	0	36	6	22	37	24	31	1	0	0	4	2	3
11	0	0	0	92	6	28	34	5	27	4	0	0	5	3	3
12	0	0	0	46	3	28	37	14	29	0	0	0	4	2	3
13	0	0	0	58	6	24	36	7	27	0	0	0	4	2	3
14	0	0	0	80	8	28	37	11	27	2	0	0	5	2	3
15	0	0	0	57	3	25	38	10	26	0	0	0	4	2	3
16	0	0	0	31	3	19	38	24	30	0	0	0	3	2	3
17	0.01	0	0.01	84	3	30	36	0	22.5	2	0	0.5	4	1	2.5
18	0.01	0	0.01	62	6	34.5	38	8	27	1	0	0	5	1	2.5
19	0.01	0	0	60	1	31	38	0	26	1	0	0	4	0	3
20	0.01	0	0.01	74	14	44.5	39	13	26.5	1	0	0	5	2	3.5
21	0.01	0	0.01	83	8	40	40	13	30	2	0	0	5	3	3.5
22	0.01	0	0.01	46	6	23	41	12	31.5	0	0	0	4	2	3
23	0.01	0	0.01	61	3	32.5	39	0	28.5	2	0	0	5	1	3
24	0.01	0	0.01	75	8	42.5	40	14	30.5	1	0	0	4	2	3
25	0.01	0	0.01	50	11	30.5	40	8	31.5	1	0	0	4	2	3
26	0.01	0	0	69	8	34	40	4	27.5	2	0	0	4	0	3
27	0.01	0	0.01	69	17	42.5	37	2	25	3	0	0.5	5	2	3
28	0.01	0	0.01	56	7	28	40	17	29.5	1	0	0	5	2	3.5
29	0.01	0	0.01	75	5	35	38	3	27	1	0	0	4	1	2
30	0.01	0	0.01	71	11	41.5	38	0	27	2	0	0.5	3	1	2.5
31	0.01	0	0.01	79	6	49	35	0	25	1	0	0.5	4	1	3

平成28年度 排ガス中のばい煙濃度等

8月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0.01	71	17	38	36	8	28.5	8	0	0	5	2	3
2	0.01	0	0.01	72	2	41	38	2	27	1	0	0	4	0	3
3	0.01	0	0.01	66	7	35.5	37	1	24.5	2	0	0.5	3	2	2
4	0.01	0	0.01	72	20	47	36	8	26	1	0	0	4	2	2.5
5	0.01	0	0.01	76	17	42.5	37	8	27	1	0	0	3	2	2.5
6	0.01	0	0.01	70	7	40	36	1	26	2	0	0	3	0	2
7	0.01	0	0.01	63	8	35.5	36	1	24	5	0	0.5	4	1	2.5
8	0.01	0	0.01	51	7	30.5	38	2	27	1	0	0	3	1	2.5
9	0.01	0	0.01	64	7	39.5	39	1	23.5	3	0	0.5	6	1	3
10	0.01	0	0.01	74	14	43.5	37	8	27	4	0	0.5	3	1	2
11	0.01	0	0.01	59	18	40	37	11	29	1	0	0	4	1	2.5
12	0.01	0	0.01	67	10	32.5	39	11	30.5	1	0	0	3	1	2.5
13	0.01	0	0.01	64	1	29.5	53	1	25	1	0	0	4	1	3
14	0.01	0	0.01	76	2	44	35	0	20	1	0	0	3	0	2.5
15	0	0	0	73	17	34	35	7	27	0	0	0	4	2	3
16	0	0	0	28	6	16	35	25	32	0	0	0	3	2	3
17	0.01	0	0	61	8	43	33	1	23	1	0	0	3	2	2
18	0.01	0	0	68	23	44	33	5	24	1	0	0	3	2	3
19	0.01	0	0	71	21	52	35	12	23	1	0	0	3	1	2
20	0.01	0	0	55	6	34	34	0	23	1	0	0	2	0	2
21	0.01	0	0	69	24	44	36	5	22	2	0	0	3	2	2
22	0.01	0	0	66	21	39	35	14	27	1	0	0	3	2	3
23	0.01	0	0	59	13	41	34	1	26	1	0	0	3	1	3
24	0.01	0	0	84	29	58	30	1	14	1	0	1	3	1	2
25	0.01	0	0	73	11	46	34	2	18	1	0	0	4	0	1
26	0.01	0	0	67	28	48	33	3	15	3	0	0	3	2	3
27	0	0	0	67	20	49	34	1	15	2	0	0	3	1	3
28	0	0	0	82	8	60	31	1	11	6	0	1	5	1	3
29	0	0	0	82	6	56	35	1	14	6	0	1	4	1	3
30	0	0	0	70	7	42	30	0	18	5	0	1	3	1	3
31	0	0	0	72	26	45	34	9	23	2	0	1	3	2	3

平成28年度 排ガス中のばい煙濃度等

9月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	73	27	51	32	17	24	1	0	0	4	2	4
2	0	0	0	55	0	33	32	1	26	18	2	15	3	0	2
3	0	0	0	70	11	45	31	0	14	17	1	10	5	2	3
4	0	0	0	82	32	56	30	0	14	2	1	1	4	2	3
5	0	0	0	63	20	42	33	0	22	1	0	0	4	3	4
6	0	0	0	44	12	30	37	0	25	0	0	0	3	1	3
7	0	0	0	61	23	48	32	11	22	1	0	0	3	2	3
8	0	0	0	73	28	49	39	1	23	1	0	0	3	2	3
9	0	0	0	57	25	40	35	3	20	0	0	0	3	2	3
10	0	0	0	56	24	44	33	0	9	0	0	0	4	2	3
11	0	0	0	70	24	44	38	7	23	0	0	0	3	2	3
12	0	0	0	60	29	45	33	5	20	0	0	0	4	2	3
13	0	0	0	54	1	30	39	0	23	0	0	0	4	1	3
14	0	0	0	54	17	34	35	8	22	0	0	0	3	2	2
15	0	0	0	69	10	42	34	2	12	0	0	0	3	2	3
16	0	0	0	85	24	37	35	0	16	0	0	0	3	2	2
17	0.01	0	0.01	83	2	46	34	0	15	4	0	0.5	5	1	3
18	0.01	0	0.01	81	7	54.5	43	2	24.5	1	0	0	4	1	2.5
19	0.01	0	0.01	80	17	51.5	41	11	27	1	0	0.5	4	2	3
20	0.01	0	0	60	1	33.5	59	0	28.5	2	0	0.5	4	0	2.5
21	0	0	0	63	6	32.5	35	8	27	2	0	0.5	4	1	2.5
22	0	0	0	72	5	31	38	20	31	1	0	0.5	4	2	3
23	0	0	0	50	7	25.5	40	15	30	1	0	0.5	5	2	2.5
24	0	0	0	67	10	35	38	16	30	1	0	0.5	4	2	3
25	0.01	0	0	76	16	45	38	3	24	2	0	0.5	3	2	3
26	0.01	0	0.01	77	8	33.5	37	10	26.5	2	0	0.5	3	1	2
27	0.01	0	0	57	3	27.5	37	0	28	1	0	0	3	0	2
28	0.01	0	0.01	80	7	38.5	40	7	28	7	0	0.5	4	2	2.5
29	0.01	0	0	80	11	41.5	38	11	28.5	1	0	0.5	5	2	3
30	0.02	0	0	58	10	38	40	10	29.5	2	0	0.5	3	2	3