

平成28年度 排ガス中のばい煙濃度等

10月	ばいじん濃度(mg/Nm <sup>3</sup> ) 管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0	57	6	30	38	2	30.5	1	0	0	3	1	2.5
2	0	0	0	70	13	51	34	9	25	1	0	1	3	1	2
3	0.01	0	0	65	17	43	34	1	23	2	0	1	3	1	3
4	0	0	0	81	5	50	33	1	17	2	0	1	4	1	3
5	0	0	0	83	32	52	35	4	23	5	0	1	4	2	3
6	0	0	0	79	2	35	38	0	26.5	2	0	0.5	4	0	2
7	0	0	0	76	6	36	41	4	29	2	0	0.5	4	1	2.5
8	0.01	0	0	82	2	50	37	0	22	3	0	0.5	7	0	3.5
9	0	0	0	77	27	55.5	58	2	25.5	2	0	0.5	5	1	2.5
10	0	0	0	64	15	40.5	44	5	26.5	2	0	1	3	1	2
11	0	0	0	71	3	40.5	37	0	22	4	0	1	3	1	2
12	0	0	0	74	8	50	36	0	21	3	0	1	6	1	3.5
13	0	0	0	83	12	50	36	0	24	3	0	1	7	2	4
14	0	0	0	62	3	35.5	40	1	27.5	2	0	1	4	0	3
15	0	0	0	63	20	46	32	0	14	0	0	0	4	2	3
16	0	0	0	85	27	50	30	0	13	0	0	0	5	2	4
17	0	0	0	56	12	32	34	18	27	0	0	0	3	2	3
18	0	0	0	63	16	39	35	20	27	0	0	0	3	2	2
19	0	0	0	80	40	63	32	2	14	0	0	0	4	2	3
20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
23	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
24	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
25	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
26	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
27	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
28	0	0	0	70	15	40	35	6	22	5	1	4	3	2	3
29	0	0	0	53	12	30	35	14	29	4	0	2	4	2	3
30	0	0	0	61	16	30	37	22	30	0	0	0	3	2	2
31	0	0	0	52	11	28	36	22	31	1	0	0	3	2	3

平成28年度 排ガス中のばい煙濃度等

11月	ばいじん濃度(mg/Nm <sup>3</sup> ) 管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	54	4	28	36	0	28	1	0	0	3	1	3
2	0	0	0	86	23	47	36	5	28	4	0	0	7	2	4
3	0	0	0	56	16	38	37	22	33	0	0	0	5	2	4
4	0	0	0	84	9	46	35	2	24	1	0	0	7	1	4
5	0	0	0	69	18	41	38	17	31	0	0	0	5	3	4
6	0	0	0	67	24	44	35	4	27	0	0	0	4	2	3
7	0	0	0	43	10	25	35	2	27	0	0	0	3	1	2
8	0	0	0	43	1	15	38	0	28	0	0	0	2	1	2
9	0	0	0	73	9	38	36	8	27	1	0	0	3	1	2
10	0	0	0	59	10	34	39	15	32	0	0	0	3	1	2
11	0	0	0	54	7	30	37	25	33	0	0	0	3	1	1
12	0	0	0	88	15	50.5	40	10	29	2	0	0	5	1	3
13	0	0	0	78	14	42.5	51	18	32.5	0	0	0	5	2	3.5
14	0	0	0	60	10	33	49	7	30.5	0	0	0	4	2	3
15	0	0	0	70	3	43.5	38	3	28	0	0	0	5	0	3
16	0	0	0	82	10	46	40	15	29	1	0	0	4	2	3.5
17	0	0	0	63	6	31.5	42	26	34	1	0	0	5	2	3
18	0	0	0	78	7	37	46	17	33.5	0	0	0	4	2	3
19	0	0	0	78	25	48.5	41	18	31	0	0	0	5	2	4
20	0	0	0	79	14	50	36	9	28	0	0	0	8	2	4
21	0	0	0	71	7	33	37	0	26	0	0	0	5	1	2
22	0	0	0	65	8	35.5	39	8	28	1	0	0	3	2	2
23	0	0	0	35	7	19.5	44	28	36.5	1	0	0	4	2	2.5
24	0	0	0	63	9	30	42	27	35	1	0	0	4	2	2.5
25	0	0	0	52	2	21.5	40	19	33.5	1	0	0	4	1	2.5
26	0	0	0	50	6	22	54	27	37	1	0	0	3	1	2.5
27	0	0	0	55	4	24.5	43	29	35.5	0	0	0	3	1	2.5
28	0	0	0	67	1	27.5	44	3	32.5	1	0	0	4	2	3
29	0	0	0	54	2	17	52	0	30.5	1	0	0	4	0	2.5
30	0	0	0	44	2	18	39	10	29.5	4	0	0.5	4	1	2.5



平成28年度 排ガス中のばい煙濃度等

1月	ばいじん濃度(mg/Nm <sup>3</sup> ) 管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	0	0	0	77	1	37	38	15	28	0	0	0	4	0	1
6	0	0	0	80	21	58	51	16	33	1	0	0	5	2	3
7	0.02	0	0	60	21	36	55	12	37	0	0	0	4	2	3
8	0	0	0	87	22	57	50	4	28	1	0	0	4	3	3
9	0	0	0	67	18	40	56	14	38	0	0	0	9	2	4
10	0	0	0	65	10	32	42	8	32	0	0	0	3	0	2
11	0	0	0	74	27	47	40	12	30	1	0	0	3	2	2
12	0	0	0	64	6	37	41	15	30	1	0	0	3	2	2
13	0	0	0	65	3	28	41	3	29	8	0	3.5	3	1	1.5
14	0	0	0	79	7	34.5	41	7	32	10	0	4	5	0	3
15	0	0	0	72	4	33	51	4	30	8	0	3.5	5	0	3
16	0	0	0	74	13	40.5	45	11	28	10	0	3.5	4	1	3
17	0	0	0	51	1	23	36	1	25.5	10	0	4	5	1	2.5
18	0	0	0	70	3	32.5	36	13	25.5	10	0	4.5	5	2	2.5
19	0	0	0	59	3	32.5	35	12	28	10	0	4.5	5	2	3.5
20	0	0	0	63	10	34.5	37	9	28.5	10	0	4.5	4	1	2.5
21	0	0	0	84	10	45.5	39	16	28	10	0	4	3	1	2.5
22	0	0	0	91	31	61.5	36	10	26.5	9	0	4	5	1	3
23	0	0	0	89	4	35	43	5	31	9	0	4	6	2	3.5
24	0	0	0	86	1	31	50	1	29.5	10	0	4	9	0	3.5
25	0	0	0	73	5	29	40	12	30.5	11	0	5	5	1	3
26	0	0	0	64	5	27	40	21	30.5	10	0	4.5	5	2	3
27	0	0	0	53	4	26	42	9	32	13	0	5	5	2	3
28	0	0	0	74	10	35	37	26	30	10	8	9	5	3	4
29	0	0	0	71	25	46	35	24	30	10	8	9	9	4	8
30	0	0	0	68	3	37	58	3	31	12	1	9	8	1	5
31	0	0	0	55	7	27	37	0	27	10	1	8	6	0	4

平成28年度 排ガス中のばい煙濃度等

2月	ばいじん濃度(mg/Nm <sup>3</sup> ) 管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	65	23	42	33	18	27	12	7	9	7	3	5
2	0	0	0	54	19	37	34	22	29	10	8	9	8	4	6
3	0	0	0	51	15	31	38	26	33	10	8	9	7	4	5
4	0	0	0	72	2	37.5	37	1	26.5	12	0	4.5	7	0	4
5	0	0	0	65	20	45	41	20	33	11	0	5	7	0	4.5
6	0	0	0	46	1	20	42	18	31.5	14	0	6	6	1	2
7	0	0	0	50	1	19.5	41	0	29.5	14	0	5.5	5	1	2.5
8	0	0	0	73	7	30	40	12	29.5	11	0	5	6	1	3
9	0	0	0	57	5	26.5	42	11	34.5	10	0	4.5	5	1	3
10	0	0	0	53	6	29	48	20	37	9	0	4	4	2	3
11	0	0	0	60	7	33	58	12	33	8	0	3.5	7	2	3.5
12	0	0	0	60	10	31	52	25	38.5	9	0	4	10	2	5
13	0	0	0	58	1	21.5	51	15	33.5	9	0	4	7	2	4
14	0	0	0	43	1	14.5	44	1	32.5	8	0	2	5	1	3
15	0	0	0	63	12	38.5	49	9	29	5	0	1	6	2	3
16	0	0	0	70	6	32.5	48	13	32	5	0	1.5	5	2	3.5
17	0	0	0	53	8	29	46	23	32	5	0	2	5	2	3
18	0	0	0	67	5	26	48	9	31.5	4	0	1.5	6	2	3
19	0	0	0	36	2	17	49	15	31.5	3	0	1	5	1	3
20	0	0	0	73	3	24	37	11	28	5	0	1	5	1	3
21	0	0	0	40	0	15.5	40	0	30	4	0	0.5	5	0	2.5
22	0	0	0	45	2	20.5	40	15	30.5	6	0	1	4	1	2.5
23	0	0	0	51	3	20	43	8	29	7	0	1.5	6	2	3.5
24	0	0	0	36	1	14.5	43	7	31	1	0	0	5	2	3
25	0	0	0	50	2	20	37	15	30	3	0	0	7	2	5
26	0	0	0	46	0	14	38	18	32	2	0	0	6	2	5
27	0	0	0	41	1	17	48	11	31	3	0	0	6	3	4
28	0	0	0	64	9	31	51	17	31	0	0	0	5	1	4

平成28年度 排ガス中のばい煙濃度等

3月	ばいじん濃度(mg/Nm <sup>3</sup> ) 管理値: 20mg/Nm <sup>3</sup> 以下 排出基準: 150mg/Nm <sup>3</sup> 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	65	10	37	36	6	23	1	0	0	4	2	3
2	0	0	0	81	10	40	35	16	27	2	0	0	7	2	5
3	0	0	0	52	10	30	35	23	29	2	0	0	4	2	3
4	0	0	0	44	12	30	38	19	31	0	0	0	5	3	4
5	0	0	0	58	16	34	35	2	28	1	0	0	6	3	5
6	0	0	0	45	4	20	36	14	29	1	0	0	5	3	4
7	0	0	0	43	1	21	40	3	31	0	0	0	4	2	3
8	0	0	0	71	13	35	38	13	30	0	0	0	5	1	3
9	0	0	0	67	1	32	36	21	30	0	0	0	5	3	3
10	0	0	0	33	3	21	37	23	32	0	0	0	4	2	3
11	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21	0	0	0	62	0	32	41	1	19	11	0	8	4	0	3
22	0	0	0	89	11	57	32	5	22	9	0	5	9	3	5
23	0	0	0	83	11	43	36	22	31	2	0	1	12	1	3
24	0	0	0	59	8	34	39	24	34	2	0	1	4	3	3
25	0	0	0	75	22	47	37	23	31	2	0	0	5	3	4
26	0	0	0	80	23	49	36	5	29	3	0	1	6	3	4
27	0.01	0	0	92	13	46.5	50	1	28	8	0	1	12	0	3.5
28	0	0	0	78	1	40.5	39	1	30	3	0	0.5	6	0	4
29	0	0	0	81	25	54.5	37	9	29	6	0	1	7	2	4.5
30	0	0	0	81	12	49.5	37	0	27.5	9	0	1	10	1	4
31	0	0	0	75	11	51.5	40	7	29.5	2	0	0.5	7	2	4.5