

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成28年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	965	965	990	983	939	961	970	964	906		1,009	945	965	946	951	959	962	923	939	938	942	1,037	970	960	
	2号炉																									休炉
2	1号炉	939	965	991	968	972	965	969	974	1,019	922	990	998	1,079	995	998	970	991	954	960	964	964	983	974	977	
	2号炉																									休炉
3	1号炉	961	944	976	977	997	983	981	958	953	957	951	970	976	985	960	959	970	929	928	918	970	950	959	940	
	2号炉																									休炉
4	1号炉	917	954	942	961	974	1,010	975	973	956	943	970	958	1,049	966	957	1,021	975	956	977	967	846	955	1,000	935	
	2号炉																									休炉
5	1号炉	954	955	960	973	978	938	944	951	953	1,036	1,013	995	995	977	969	970	985	949	948	952	967	964	961	977	
	2号炉																									休炉
6	1号炉	997	960	987	958	961	960	955	906	884	925	950	954	960	977	974	999	997	1,016	975	952	987	946	989	952	
	2号炉																									休炉
7	1号炉	932	957	949	950	1,015	967	975	962	966	977	959	982	970	960	935	929	960	819	894	884	937	948	943	948	
	2号炉																									休炉
8	1号炉	940	936	933	932	936	937	940	955	932	937	966	983	945	923	923	939	911	925					963	912	
	2号炉																									休炉
9	1号炉	892	889	855	880	920	937	905	928	907	847	957	960	946	952	959	976	972	899	920	898	942	935	921	895	
	2号炉																									休炉
10	1号炉	900	938	913	958	950	957	981	941	942	928	954	908	904	897	904	903	923	940	938	911	917	922	928	904	
	2号炉																									休炉
11	1号炉	913	923	911	916	915	918	911	943	945	946	949	952	944	930	915	949	938	918	936	935	936	938	924	943	
	2号炉																									休炉
12	1号炉	918	931	929	959	967	927	927	933	942	950	936	932	946	942	955	967	981	956	941	931	934	920	938	962	
	2号炉						830	922	888	891	879	878	839	877	911	936	915	936	945	931	925	921	926	911		立ち上げ～定常運転
13	1号炉	946	925	943	925	943	958	945	950	939	928	934	918	920	908	922	907	894	913	907	927	914	898	900	927	
	2号炉	928	892	896	882	914	907	908	918	914	927	919	966	884	874	890	884	915	907	901	908	921	907	880	912	
14	1号炉	897	901	894	905	896	897	917	896	880	907	855	890	863	861	866	890	872	923	931	881	869	888	904	899	
	2号炉	924	905	884	894	883	897	923	911	888	918	867	893	878	933	876	890	894	913	924	889	895	891	887	912	
15	1号炉	936	935	924	958	905	943	962	967	936	942	953	951	938	935	925	925	920					925	945	964	
	2号炉	913	899	889	904	885	897	905	906	904	986	905	919	907	933	914	906	927	976	920	923	941	948	914	965	

11月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	924	949	986	1,006	981	939	981	965	946	836	957	942	977	1,006	991	1,045	981	953	932	946	957	914	912	918	
	2号炉	926	910	938	931	926	932	986	975	941	889	947	933	967	934	953	947	952	931	939	929	953	922	911	929	
17	1号炉	896	944	934	946	934	947	947	975	963	978	979	951	937	929	929	964	957	944	955	940	916	944	940	936	
	2号炉	894	946	920	939	930	928	944	947	936	964	948	954	917	930	922	968	942	936	887	898	898	902	895	928	
18	1号炉	949	945	937	955	968	931	935	937	942	943	932	968	964	944	928	940	955	935	948	946	966	987	984	970	
	2号炉	890	912	941	947	962	1,013	955	928	874	928	951	945	945	980	928	921	960	933	918	907	973	980	981	965	
19	1号炉	957	951	992	965	950	959	966	954	962	942	947	944	922	960	940	944	964	948	947	938	951	951	933	935	
	2号炉	953	955	1,019	976	954	972	974	934	937	987	993	997	969	949	971	1,020	1,054	939	937	925	923	934	935	916	
20	1号炉	956	942	973	913	942	955	936	929	938	949	938	929	926	962	952	932	958	952	961	958	934	956	913	914	
	2号炉	905	974	919	922	918	944	929	915	936	931	920	913	918	912	932	931	930	943	922	911	928	910	947	905	
21	1号炉	909	909	895	902	885	898	900	931	889	883	898	905	862	856	862	851	874	877		1,063	904	873	880	879	
	2号炉	892	916	906	942	936	998	954	964	890			961	910	930	876	902	891	905	908	911	929	938	933	911	
22	1号炉	931	917	882	882	865	869	872	887	882	828	885	879	852	880	878	871	873	875	886	863	864	883	951	913	
	2号炉	934	935	923	910	937	908	888	915	920	852	931	889	892	918	915	901	891	945	942	887	901	935	929	950	
23	1号炉	860	878	873	874	877	927	868	879	879	859	932	916	921	926	939	949	956	947	971	969	931	975	976	979	
	2号炉	963	930	943	953	930	938	951	921	908	949	902	945	923	898	939	937	922	917	936	951	927	936	937	941	
24	1号炉	961	961	961	959	964	951	942	934	948	947	959	958	977	976	981	968	968	981	944	964	897	940	940	890	
	2号炉	955	897	882	886	952	944	951	916	962	962	980	1,008	986	972	970	974	975	952	936	934	936	943	957	937	
25	1号炉	897	953	934	954	929	968	956	947	939	927	939	945	929	948	930	969	922	937	887	942	976	929	921	950	
	2号炉	927	914	896	942	904	915	924	937	956	932	943	934	961	942	970	951	910	939	929	979	968	953	923	969	
26	1号炉	913	936	928	947	958	932	975	951	971	974	970	924	922	956	945	944	940	964	974	970	948	967	961	951	
	2号炉	951	918	926	934	948	944	935	972	946	935	938	906	895	902	922	889	876	942	966	966	956	979	937	919	
27	1号炉	955	959	966	958	925	956	951	951	960	945	979	956	938	943	927	958	936	963	928	974	957	913	906	929	
	2号炉	940	928	929	951	929	929	914	952	960	946	960	974	938	933	951	957	957	945	946	957	993	966	966	970	
28	1号炉	907	963	978	964	938	957	955	947	956	975	964	939	955	940	926	921	924	930	931	935	944	941	942	929	
	2号炉	977	974	923	943	948	936	973	954	976	1,041	985	915	915	938	924	928	961	922	906	899	946	943	927	914	
29	1号炉	917	923	911	934	945	949	940	948	957	923	944	925	933	957	921	941	943	921			1,012	921	884	882	
	2号炉	937	937	919	928	961	959	935	945	932			924	926	924	919	945	952	904	914	891	904	914	930	910	
30	1号炉	883	875	878	865	874	885	869	893	887	876	820	898	912	914	944	940	957	915	897	871	862	874	865	906	
	2号炉	915	937	928	916	897	900	896	895	907	925	755	917	911	941	900	907	891	921	892	886	910	895	906	884	10:10~10:40給じん停止

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成28年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	896	925	901	893	888	875	891	901	911	929	922	941	929	936	953	948	942	913	926	891	886	889	902	905	
	2号炉	904	885	920	900	936	949	937	913	917	919	933	912	895	892	921	899	877	918	914	885	907	880	903	926	
2	1号炉	933	916	887	897	883	885	889	883	901	912	931	914	932	925	914	942	936	936	920	891	911	919	913	921	
	2号炉	947	918	923	877	889	902	914	903	946	959	953	919	908	896	900	904	919	925	929	909	934	934	892	940	
3	1号炉	932	918	915	934	920	934	907	909	917	893	876	852	905	897	882	883	899	901	866	893	904	894	896	901	
	2号炉	925	921	935	949	921	896	897	907	893	889	901	930	958	923	937	905	893	947	882	862					定常運転～立ち下げ
4	1号炉	912	910	920	926	920	925	930	934	910	922	902	931	933	900	913	904	891	895	916	901	922	906	915	901	
	2号炉																									休炉
5	1号炉	897	890	933	944	953	914	858	888	910	907	909	904	909	896	892	898	898	869	860	855	851	865	871	854	
	2号炉																									休炉
6	1号炉	876	924	916	903	917	882	900	898	918	907	907	936	883	886	902	891	882	864				845	839	831	
	2号炉																									休炉
7	1号炉	837	867	855	869	841	856	871	856	853	822	877	868	882	866	867	876	878	875	868	865	824	808	878	871	
	2号炉																							874	912	立ち上げ～定常運転
8	1号炉	875	879	887	888	884	885	923	927	915	879	863	851	855	843	844	844	861	908	911	923	915	917	917	916	
	2号炉	903	896	909	914	914	893	907	923	939	924	934	954	977	941	965	952	975	913				920	926	957	
9	1号炉	929	888	929	888	894	920	911	907	881	876	887	885	898	890	897	880	893	869	876	928	889	875	862	861	
	2号炉	912	978	930	939	955	943	940	942	923	864	879	864	864	867	904	878	875	908	922	919	960	936	915	928	
10	1号炉	861	846	878	855	851	852	890	862	841	869	924	912	925	922	920	880	888	881	907	911	895	912	891	923	
	2号炉	926	934	968	894	901	901	944	941	871	932	938	938	908	938	930	957	927	945	956	953	940	929	936	939	
11	1号炉	910	895	912	917	892	892	873	860	877	890	895	913	881	860	853	861	862	868	885	882	889	878	897	904	
	2号炉	948	941	961	954	944	933	948	946	925	916	926	959	949	919	936	927	919	952	940	919	946	910	915	920	
12	1号炉	901	895	873	903	872	883	893	898	881	879	882	899	880	877	880	863	871	858	948	921	926	925	923	949	
	2号炉	880	968	980	926	943	943	940	976	926	934	842	978	983	948	927	934	941	943	948	924	939	943	944	934	
13	1号炉	918	910	906	918	943	895	916	906	872			985	890	887	886	896	900	909	907	867	877	897	888	887	
	2号炉	933	894	889	926	919	934	957	946	954	938	973	950	952	954	920	948	967	909				892	891	914	
14	1号炉	866	866	872	890	878	868	856	862	875	848	909	905	907	913	911	913	937	899	900	873	918	894	908	919	
	2号炉	896	891	894	894	900	908	899	923	905	832	941	921	903	875	880	895	930	858	899	916	901	945	922	931	
15	1号炉	924	893	915	899	917	912	918	908	902	917	898	875	889	902	907	896	912	914	892	871	867	849	835	837	
	2号炉	945	912	936	900	926	914	957	909	942	960	972	934	952	963	967	940	970	956	941	956	910	904	900	911	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成29年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考		
1	1号炉																									休炉	
	2号炉																										休炉
2	1号炉																										休炉
	2号炉																										休炉
3	1号炉																										休炉
	2号炉																										休炉
4	1号炉																										休炉
	2号炉																										休炉
5	1号炉																										休炉
	2号炉										833	882	863	891	860	895	860	882	897	883	879	918	953	949	977	立ち上げ～定常運転	
6	1号炉																										休炉
	2号炉	980	984	1,009	988	983	982	986	953	982	951	987	967	986	948	953	973	955	996	968	952	963	942	951	931		
7	1号炉																										休炉
	2号炉	951	934	940	943	929	899	920	945	941	912	909	939	907	924	935	947	933	913	913	910	946	858				
8	1号炉																										休炉
	2号炉			903	957	972	972	980	953	984	957	1,027	986	985	1,000	1,040	955	920	964	946	927	947	936	907	897		
9	1号炉																										休炉
	2号炉	920	948	990	971	971	973	954	951	964	952	953	953	934	985	933	909	928	922	910	903	939	938	924	905		
10	1号炉																										休炉
	2号炉	915	948	932	925	977	971	936	932	940	928	967	910	921	902	946	929	957	819			903	925	934	942		
11	1号炉																										休炉
	2号炉	936	917	904	887	888	932	937	904	938	792	948	954	955	950	947	965	950	899	931	928	927	930	958	939	9:07～9:34給じん停止	
12	1号炉																										休炉
	2号炉	903	872	906	915	910	934	930	961	939	938	955	917	902	902	894	919	914	901	915	903	915	938	954	932		
13	1号炉									847	752	752	732	858	852	869	861	855	917	893	903	906	899	928	920	立ち上げ～定常運転	
	2号炉	945	922	890	886	918	898	923	916	886	947	970	928	947	957	936	931	950	960	926	906	935	948	1,002	976		
14	1号炉	918	941	957	956	915	929	930	947	933	961	923	919	966	963	953	964	977	961	989	969	944	918	888	904		
	2号炉	943	935	948	925	964	947	969	932	941	952	913	916	910	903	923	897	949	1,006	978	966	1,002	955	914	896		
15	1号炉	915	916	929	968	963	970	973	989	974	953	968	966	945	950	931	946	942	912	1,002	983	947	940	938	950		
	2号炉	929	924	949	909	910	926	947	944	961	947	918			921	900	927	895	937	942	970	983	939	920	941		

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

平成29年 ※1時間ごとの平均値。空白部分のごみの供給停止中。

(単位:℃)

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	970	960	963	962	960	942	944	950	831	950	987	967	991	996	1,013	997	1,006	958	980	979	995	984	973	983	
	2号炉																									休炉
2	1号炉	972	969	992	989	978	972	979	998	978	1,011	956	991	973	967	1,022	996	1,014	1,000	984	978	957	971	945	963	
	2号炉																									休炉
3	1号炉	977	985	973	985	1,011	1,006	994	980	981	989	1,008	999	996	1,006	1,000	994	1,012	1,003	975	989	995	1,012	1,026	987	
	2号炉																									休炉
4	1号炉	989	1,024	972	1,004	975	990	967	984	993	986	946	952	985	1,004	998	1,007	961	1,005	981	1,036	988	839	1,028	1,033	
	2号炉										877	904	868	866	869	888	907	914	949	904	914	946	933	947	990	立ち上げ～定常運転
5	1号炉	986	1,041	1,020	1,021	991	986	989	1,023	1,040	972	965	970	961	977	960	978	970	999	1,002	985	968	977	972	967	
	2号炉	953	971	961	946	935	956	963	984	948	968	946	955	971	956	958	946	956	982	979	976	945	993	972	927	
6	1号炉	962	940	984	945	915	948	1,002	985	979	945	942	945	964	949	906	923	903	934	906	903	917	925	886	931	
	2号炉	946	936	934	902	913	956	956	971	967	947	974	958	936	937	970	929	954	951	918	880	906	876	888	941	
7	1号炉	943	920	912	943	957	962	922	927	890			977	908	904	908	890	904	840	868	863	864	857	864	843	
	2号炉	941	942	943	908	964	961	946	930	921	952	953	931	946	948	939	941	940	904		962	900	878	1,966	911	23:00熱電対故障
8	1号炉	859	874	911	884	874	875	891	887	877	796	877	939	941	906	906	888	884	877	890	904	950	928	853	885	9:01～9:34給じん停止
	2号炉	923	921	944	925	961	912	951	949	964	853	966	965	968	1,020	986	950	966	904	894	983	956	954	886	878	
9	1号炉	890	943	932	908	971	942	897	917	915	907	914	907	898	902	920	906	912	947	966	910	937	918	933	935	
	2号炉	903	969	989	983	985	994	967	925	968	961	994	976	970	967	976	959	988	936	957	921	926	983	974	971	
10	1号炉	925	934	913	910	916	922	927	926	894	900	889	898	905	907	915	926	904	913	907	918	902	907	912	909	
	2号炉	960	934	946	950	982	975	976	973	976	1,002	993	937	959	953	969	972	982	980	957	984	967	997	973	988	
11	1号炉	923	928	916	913	902	893	881	908	910	933	936	946	922	890	917	899	980	973	936	900	899	938	916	952	
	2号炉	984	972	953	958	947	937	949	934	967	984	961	990	1,003	967	962	1,007	969	1,011	1,027	1,023	987	963	961	974	
12	1号炉	907	908	899	898	916	905	891	900	920	901	939	928	919	900	916	917	912	889	908	927	950	955	932	931	
	2号炉	948	947	952	952	970	918	899	899	940	962	931	956	967	959	938	919	958	930	917	915	894	900	883	857	
13	1号炉	958	925	948	937	926	904	934	927	966	929	932	917	903	926	900	949	935	995	947	942	922	905	886	885	
	2号炉	881	867	882	882	884	874	871	876	882	881	857	852	900	880	871	876	865	970	903	914	911	886	900	898	
14	1号炉	864	878	879	879	865	874	862	857	861				934	862	876	866	886	879	903	879	872	877	864	916	
	2号炉	878	889	885	863	856	856	860	863	862	903	888	873	883	902	904	887	886	931				909	860	869	
15	1号炉	893	921	947	982	973	943	955	970	1,018	885	987	983	972	992	997	993	957	979	972	973	939	944	944	944	
	2号炉	885	894	878	893	938	917	907	912	892	805	946	941	930	928	915	907	928	984	931	929	915	913	937	950	

3月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉																										休炉
	2号炉																										休炉
17	1号炉																										休炉
	2号炉																										休炉
18	1号炉																										休炉
	2号炉																										休炉
19	1号炉																										休炉
	2号炉																										休炉
20	1号炉																										休炉
	2号炉																										休炉
21	1号炉										850	867	854	886	891	868	850	854	837	925	875	914	920	881	907	立ち上げ～定常運転	
	2号炉																										休炉
22	1号炉	890	971	940	930	933	977	954	975	932	926	906	973	982	827	853	971	943	890	855	856	874	945	1,024	976		
	2号炉																										休炉
23	1号炉	965	987	1,019	949	973	933	946	904	897	925	1,001	974	887	863	880	860	895	939	888	860	874	865	896	942		
	2号炉																										休炉
24	1号炉	931	886	864	873	875	852	852	859	889	918	936	866	871	873	901	867	912	926	929	906	935	916	896	882		
	2号炉																										休炉
25	1号炉	917	904	940	908	903	891	876	879	881	924	914	939	949	930	930	988	962	952	892	879	881	886	977	947		
	2号炉																										休炉
26	1号炉	977	923	922	876	906	900	901	929	892	902		901	916	901	926	892	918	902	902	905	895	877	942	952		
	2号炉																										休炉
27	1号炉	1,000	973	962	919	923	961	993	979	1,000	1,044		909	940	934	924	883	890	952	863	900	914	882	888	958		
	2号炉												819	901	901	882	902	897	872	916	879	899	930	906	898	946	立ち上げ～定常運転
28	1号炉	903	906	880	890	894	835	898	873	894	934	877	875	885	871	928	917	860	903			919	903	975	890		
	2号炉	906	935	900	900	891	897	920	889	930	988	956	914	911	953	940	946	948	941	901	932	949	925	960	958		
29	1号炉	886	878	864	938	952	933	952	928	991	857	986	1,003	957	987	961	935	932	952	946	924	943	980	1,008	964		
	2号炉	940	925	935	899	905	922	909	896	905	933	894	909	869	914	907	860	851	877	893	879	925	906	911	897		
30	1号炉	917	986	1,046	975	1,018	1,025	1,096	973	1,000	1,102	1,018	934	927	1,071	1,031	1,098	764	840	958	898	992	931	985	969	16:13～17:14給じん停止	
	2号炉	857	917	889	871	900	917	943	908	917	931	867	879	952	905	893	915	933	887	882	887	894	694		820	21:21～23:05給じん停止	
31	1号炉	940	953	954	1,002	1,012	1,060	1,034	1,024	1,047	926	951	1,020	1,016	1,045	1,030	998	1,006	950	962	896	928	905	941	899		
	2号炉	896	896	911	899	929	930	913	929	909	949	929	921	950	923	876	932	900	894	892	888	910	921	929	903		