

平成29年度 排ガス中のばい煙濃度等

4月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	82	21	52.5	40	19	31.5	1	0	0	8	2	4.5
2	0	0	0	75	3	45.5	39	2	31.5	1	0	0	6	0	4
3	0	0	0	89	10	53.5	45	10	29.5	2	0	0.5	8	2	4
4	0	0	0	74	0	44	39	5	26	3	0	0.5	7	1	4
5	0	0	0	84	22	51	56	9	34	4	0	1	8	2	4.5
6	0	0	0	81	15	45	35	2	21.5	4	0	1	6	2	4
7	0	0	0	79	20	48	40	4	21.5	4	0	0	7	0	3
8	0	0	0	84	22	53	38	6	26	2	0	0.5	5	2	3.5
9	0	0	0	86	4	55.5	31	0	20.5	2	0	0	6	0	3
10	0	0	0	65	14	39	35	15	25	0	0	0	5	2	3
11	0	0	0	55	2	32	28	4	20	0	0	0	5	1	3
12	0	0	0	64	7	31	37	12	26	0	0	0	4	2	3
13	0	0	0	48	4	30	36	19	27	0	0	0	6	3	4
14	0	0	0	78	28	53	33	1	21	2	0	0	8	3	5
15	0	0	0	74	28	48	33	13	25	1	0	0	6	3	5
16	0	0	0	84	25	50	35	11	27	1	0	0	7	3	5
17	0	0	0	55	5	34	33	11	26	1	0	0	6	3	4
18	0	0	0	88	11	36	29	2	19	1	0	0	5	2	3
19	0	0	0	77	22	52	34	3	20	1	0	0	5	3	4
20	0	0	0	77	15	55	33	5	24	0	0	0	7	3	5
21	0	0	0	80	28	57	37	3	22	0	0	0	7	3	5
22	0	0	0	75	26	51.5	39	1	21.5	1	0	0	6	1	2.5
23	0	0	0	74	29	49	37	18	29	0	0	0	7	3	4
24	0	0	0	69	5	44	39	4	29	0	0	0	5	2	3
25	0	0	0	63	0	41	39	0	22	1	0	0	5	0	3
26	0	0	0	59	36	49	30	6	22	1	0	0	4	2	3
27	0	0	0	81	23	56	31	9	20	2	0	0	7	2	5
28	0	0	0	71	23	46	41	11	28	1	0	0	5	3	4
29	0	0	0	82	12	54	35	5	22	1	0	0	6	1	3
30	0	0	0	80	21	59	40	8	24	1	0	0	5	1	3

平成29年度 排ガス中のばい煙濃度等

5月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	69	18	44	34	1	19	1	0	0	4	1	2
2	0	0	0	79	0	44.5	61	0	31	4	0	1	3	0	1.5
3	0	0	0	75	19	51.5	59	2	27	3	0	0.5	7	1	3
4	0	0	0	79	23	54.5	43	12	26.5	2	0	0.5	5	1	3
5	0	0	0	85	21	60	33	2	18.5	2	0	0.5	7	3	3.5
6	0	0	0	85	2	56	36	2	24.5	1	0	0	7	0	3.5
7	0	0	0	73	20	50.5	37	11	27	1	0	0	4	1	2.5
8	0	0	0	80	10	48	41	15	28.5	1	0	0	4	2	3
9	0	0	0	73	1	38	38	0	26	1	0	0	3	1	2
10	0	0	0	75	30	56	36	10	25	1	0	0	4	2	2.5
11	0	0	0	88	27	59	34	3	21	2	0	0	6	2	3.5
12	0	0	0	82	14	52.5	33	4	21.5	1	0	0	6	2	4
13	0	0	0	87	1	50	37	0	21.5	1	0	0	9	1	4.5
14	0	0	0	69	17	50	37	16	25.5	1	0	0	7	0	3
15	0	0	0	80	14	43.5	38	6	25	2	0	0	6	1	3.5
16	0	0	0	82	1	38	41	2	28	1	0	0	4	1	2.5
17	0	0	0	87	23	57.5	38	6	25	2	0	0.5	12	2	5.5
18	0	0	0	79	22	49.5	38	1	25	1	0	0	12	3	6
19	0	0	0	75	18	43.5	36	11	25.5	1	0	0	8	2	3.5
20	0	0	0	87	6	57	57	0	14.5	2	0	0.5	8	0	4
21	0	0	0	86	27	43	59	16	31	0	0	0	6	3	4
22	0	0	0	77	35	56	34	4	23	0	0	0	6	0	3
23	0	0	0	80	13	46	32	2	17	0	0	0	6	1	4
24	0	0	0	86	20	53	29	0	14	0	0	0	6	2	3
25	0	0	0	85	23	53	32	19	26	0	0	0	5	1	2
26	0	0	0	79	2	46	31	12	23	0	0	0	5	1	2
27	0	0	0	84	45	62	33	11	26	0	0	0	7	4	6
28	0	0	0	82	9	64	32	2	22	0	0	0	8	3	6
29	0	0	0	85	28	61	33	4	20	0	0	0	8	4	6
30	0	0	0	69	1	44	31	0	21	0	0	0	7	1	5
31	0	0	0	69	31	52	30	4	19	0	0	0	6	3	5

平成29年度 排ガス中のばい煙濃度等

6月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	83	24	53	32	7	21	0	0	0	7	3	5
2	0	0	0	74	16	54	32	12	25	0	0	0	8	3	4
3	0	0	0	79	37	57	32	16	26	0	0	0	6	3	5
4	0	0	0	86	16	61	31	6	24	0	0	0	11	3	7
5	0	0	0	85	16	65	31	5	20	0	0	0	10	5	7
6	0	0	0	88	6	55	33	0	17	0	0	0	7	0	3
7	0	0	0	83	40	61	33	5	17	0	0	0	4	1	2
8	0	0	0	76	26	56	29	10	22	0	0	0	4	0	2
9	0	0	0	87	30	63	33	4	20	0	0	0	6	3	5
10	0	0	0	83	39	59	31	14	24	0	0	0	7	3	5
11	0	0	0	88	25	58	32	14	24	0	0	0	6	3	4
12	0	0	0	79	30	58	32	14	25	0	0	0	5	3	4
13	0	0	0	80	13	53	33	4	18	0	0	0	4	2	3
14	0	0	0	90	27	63	29	4	17	1	0	0	7	3	5
15	0	0	0	91	50	72	32	2	18	0	0	0	6	3	5
16	0	0	0	96	14	57	43	2	17.5	3	0	0.5	8	2	5
17	0	0	0	79	33	57	34	8	24.5	3	0	0.5	9	4	6
18	0	0	0	84	40	56	37	6	25	1	0	0	8	3	5.5
19	0	0	0	84	26	57.5	37	2	25	1	0	0	8	3	5
20	0	0	0	82	1	44	36	0	22	2	0	0	6	1	3.5
21	0	0	0	87	36	60.5	34	2	20.5	2	0	0.5	5	1	3
22	0	0	0	83	11	59.5	53	18	32	1	0	0	7	2	3.5
23	0	0	0	69	13	43	34	5	26	1	0	0	4	1	2.5
24	0	0	0	82	2	50	31	1	22	1	0	0	5	2	3.5
25	0	0	0	66	27	48	33	8	26.5	2	0	0	6	2	3.5
26	0	0	0	82	16	49.5	33	6	22	1	0	0	5	2	3
27	0	0	0	76	6	38.5	36	0	21.5	2	0	0	6	1	3.5
28	0	0	0	83	1	45	47	0	20	2	0	0	5	0	2.5
29	0	0	0	83	17	45.5	35	9	23	1	0	0	6	0	3
30	0	0	0	87	14	34	33	7	24.5	1	0	0	5	1	3

平成29年度 排ガス中のばい煙濃度等

7月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	73	33	53	37	6	24	1	0	0	11	3	6
2	0	0	0	75	39	55	36	17	26	1	0	0	7	3	4
3	0	0	0	70	17	44	47	8	25	1	0	0	6	3	4
4	0	0	0	62	1	37	35	3	23	1	0	0	5	1	3
5	0	0	0	78	25	58	27	5	18	2	0	1	7	2	4
6	0	0	0	63	24	44	34	7	21	1	0	0	5	3	4
7	0	0	0	70	20	44	37	9	23	1	0	0	4	2	3
8	0	0	0	74	30	46	43	12	27	1	0	0	5	2	3
9	0	0	0	82	33	58	48	18	29	1	0	0	4	2	3
10	0	0	0	78	27	50	48	8	28	1	0	0	4	2	3
11	0	0	0	69	16	43	38	0	23	1	0	0	4	1	2
12	0	0	0	73	9	47	44	1	19	4	0	1	4	1	2.5
13	0	0	0	81	7	45.5	53	4	25	2	0	0.5	6	1	3
14	0	0	0	76	9	39.5	43	5	23	1	0	0.5	5	2	2.5
15	0	0	0	65	24	42	41	15	29	1	0	0	4	2	3
16	0	0	0	66	6	35.5	40	7	29	1	0	0	5	2	3
17	0	0	0	69	12	36.5	41	11	25	1	0	0	3	2	2.5
18	0	0	0	80	3	33.5	43	0	25	2	0	0.5	3	1	2
19	0	0	0	78	15	40.5	39	4	26.5	1	0	0	5	1	3
20	0	0	0	86	5	47	41	0	23	2	0	0	7	2	4
21	0	0	0	72	7	32	37	3	25.5	1	0	0	4	2	3
22	0	0	0	71	18	42.5	41	4	26.5	2	0	0	6	3	4
23	0	0	0	99	13	55.5	36	1	21	3	0	0.5	9	2	5
24	0	0	0	76	7	43.5	40	7	26	1	0	0	7	3	4.5
25	0	0	0	60	2	31	39	1	23	1	0	0	5	1	3.5
26	0	0	0	91	17	50.5	34	2	17.5	2	0	0.5	6	2	3.5
27	0	0	0	80	16	48	38	10	24.5	2	0	0.5	8	2	4.5
28	0	0	0	67	20	44	43	12	30	1	0	0	6	1	3
29	0	0	0	75	25	48.5	48	11	30	1	0	0	7	2	4
30	0	0	0	84	29	58	55	8	25	2	0	0.5	7	2	4
31	0	0	0	78	16	50.5	34	4	21	2	0	0.5	6	2	3.5

平成29年度 排ガス中のばい煙濃度等

8月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	68	5	38	34	3	22.5	1	0	0	4	0	2.5
2	0	0	0	68	13	41	35	2	18	4	0	0.5	4	1	3
3	0	0	0	77	16	46	31	7	22.5	2	0	0.5	5	2	3.5
4	0	0	0	78	3	45.5	32	10	21.5	1	0	0.5	6	2	3
5	0	0	0	71	29	49.5	35	10	22.5	1	0	0.5	4	1	2.5
6	0	0	0	70	25	52	40	6	25.5	1	0	0	4	2	3
7	0	0	0	90	15	50.5	36	3	20.5	3	0	0.5	4	2	3
8	0	0	0	64	10	37.5	35	0	20	1	0	0	5	1	2.5
9	0	0	0	65	0	35	31	2	13	2	0	0.5	3	1	2
10	0	0	0	81	0	41	35	0	15.5	2	0	0.5	4	0	2.5
11	0	0	0	83	0	42.5	32	0	16.5	2	0	0.5	3	0	2
12	0	0	0	82	17	48.5	30	3	16.5	2	0	0.5	4	1	2.5
13	0	0	0	76	25	58	28	6	18	0	0	0	4	2	3
14	0	0	0	74	27	51	31	3	20	0	0	0	4	2	3
15	0	0	0	60	6	38	26	6	19	0	0	0	4	2	3
16	0	0	0	82	21	57	30	2	14	0	0	0	3	2	3
17	0	0	0	88	39	62	25	1	12	0	0	0	4	2	3
18	0	0	0	73	25	49	35	12	23	0	0	0	4	2	3
19	0	0	0	76	26	44	32	10	25	0	0	0	4	2	3
20	0	0	0	64	23	43	32	21	26	0	0	0	3	1	2
21	0	0	0	69	30	49	34	9	23	0	0	0	3	1	2
22	0	0	0	71	1	43	30	3	20	0	0	0	4	1	3
23	0	0	0	82	26	53	28	7	17	0	0	0	6	2	4
24	0	0	0	76	24	55	49	19	33	0	0	0	5	3	4
25	0	0	0	80	11	43	35	9	26	0	0	0	6	3	4
26	0	0	0	78	28	54	32	12	23	0	0	0	5	2	4
27	0	0	0	68	16	44	33	15	25	0	0	0	4	3	3
28	0	0	0	58	7	39	35	17	25	0	0	0	4	2	3
29	0	0	0	73	19	42	34	11	25	0	0	0	4	3	3
30	0.01	0	0	71	1	40.5	36	1	20	1	0	0.5	6	1	2.5
31	0	0	0	72	6	51.5	32	9	22	2	0	0	8	1	4

平成29年度 排ガス中のばい煙濃度等

9月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	88	2	49.5	54	1	20	4	0	0.5	5	0	3
2	0	0	0	79	11	55	36	5	22	2	0	0.5	5	2	3.5
3	0	0	0	82	33	59.5	34	13	24.5	2	0	0.5	6	2	4
4	0	0	0	80	17	53.5	37	12	26.5	2	0	0.5	7	2	3.5
5	0	0	0	83	0	45.5	37	0	25.5	2	0	0.5	6	1	2
6	0	0	0	82	35	58.5	32	3	19	3	0	0.5	4	0	2
7	0	0	0	79	14	52.5	34	8	23.5	2	0	0	4	1	2
8	0	0	0	83	34	55	37	8	23	3	0	0.5	4	1	2
9	0	0	0	99	23	52.5	35	9	23.5	2	0	0.5	4	1	2.5
10	0	0	0	76	1	56	25	0	16	1	0	1	3	1	3
11	0	0	0	86	36	57	32	1	15	2	0	1	3	2	2
12	0	0	0	87	4	47	38	3	17	2	0	1	3	1	2
13	0	0	0	85	12	50	28	2	10	3	0	1	3	1	2
14	0	0	0	78	38	60	20	1	7	3	0	1	5	1	2
15	0	0	0	72	2	53	24	0	11	1	0	1	4	0	2
16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17	0	0	0	74	7	50	25	0	17	3	0	2	4	1	3
18	0	0	0	81	20	49	31	6	19	7	0	2	4	2	3
19	0	0	0	94	25	54	32	6	19	6	1	4	4	1	3
20	0	0	0	96	18	58	29	0	17	6	1	3	8	2	4
21	0	0	0	86	5	43	32	7	22	5	1	3	7	3	4
22	0	0	0	69	1	36	35	0	19	7	1	4	4	2	3
23	0	0	0	76	18	43	56	13	31	7	3	5	6	2	4
24	0	0	0	87	16	46.5	35	2	22	5	0	2.5	4	1	2
25	0	0	0	85	18	52.5	34	3	22	6	0	2	4	1	2.5
26	0	0	0	86	4	50	31	1	18	7	0	2	4	1	2.5
27	0	0	0	95	6	61	28	0	13	18	0	5.5	7	2	3
28	0	0	0	88	14	65	29	0	13	18	0	8	6	1	3.5
29	0	0	0	88	11	57	43	1	20.5	2	0	0.5	5	1	3
30	0	0	0	85	12	54.5	35	1	20.5	3	0	0.5	7	1	3