

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	973	995	969	959	969	940	963	958	942	954	963	959	938	953	1,009	979	914	1,011	1,025	994	969	981	977	973	
	2号炉																									休炉
17	1号炉	980	978	953	946	1,001	982	985	984	980	981	978	966	928	947	931	909	917	890	881	878	946	929	954	919	
	2号炉																									休炉
18	1号炉	950	938	873	876	919	921	887	901	878		989	924	870	910	917	891	889	925	932	937	895	962	979	985	
	2号炉																									休炉
19	1号炉	945	961	976	982	962	952	967	980	900	852	929	949	1,009	959	963	965	989	950	1,004	981	946	966	965	966	
	2号炉																									休炉
20	1号炉	985	975	1,001	982	989	965	953	954	961	984	1,025	952	982	942	989	962	971	981	952	968	964	938	846	891	
	2号炉																									休炉
21	1号炉	924	937	922	986	964	957	1,004	1,013	943	978	972	988	956	1,008	1,025	994	976	963	950	953	953	946	934	945	
	2号炉																									休炉
22	1号炉	903	899	901	994	984	952	954	987	972	1,014	938	947	927	932	872										定常運転～立ち下げ
	2号炉															908	877	886	889	872	887	880	874	869	871	立ち上げ～定常運転
23	1号炉																									休炉
	2号炉	869	888	904	903	923	937	912	902	919	906	906	898	913	912	932	913	887	897	902	895	884	891	857	884	
24	1号炉																									休炉
	2号炉	908	929	955	930	940	953	941	936	941	897	952	939	964	984	979	966	939	944	945	890	928	942	910	896	
25	1号炉																									休炉
	2号炉	891	887	939	874	907	922	905	880	905	878	901	948	905	920	955	865	924				912	875	898	903	
26	1号炉																									休炉
	2号炉	913	861	861	856	860	888	867	865	891	855	888	897	869	858	873	877	868	901	899	890	889	908	888	916	
27	1号炉																									休炉
	2号炉	831	853	862	855	873	882	918	883	909	887	894	896	891	914	906	912	887	858	886	866	895	880	864	860	
28	1号炉																									休炉
	2号炉	880	864	863	869	861	862	853	845	842	858	865	857	901	856	843	865	847	949	901	922	914	902	883	904	
29	1号炉																									休炉
	2号炉	897	860	894	941	888	819	914	831	889	908	905	900	903	893	927	906	925	892	913	942	918	942	944	934	
30	1号炉																									休炉
	2号炉	942	903	921	933	921	883	907	883				771	848	856	859	858	872	938	932	931	974	967	973	944	7:56～11:50給じん停止

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成29年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	987	977	859	945	940	980	951	948	948	992	959	943	973	982	926	852	916	902	923	930	860	936	713	919	21:55~22:40給じん停止
2	1号炉									853	826	849	955	918	831	832	906	951	943	900	924	916	933	987	1,011	立ち上げ~定常運転
	2号炉	954	961	752	842	976	1,006	1,005	951	895	880	834	924	961	955	958	1,019	980	717				1,008	952	980	2:21~3:16、 17:10~21:37給じん停止
3	1号炉	982	993	1,003	996	948	925	939	1,000	970	949	937	981	938	986	945	946	955	970	980	964	914	956	978	931	
	2号炉	958	1,026	981	909	928	926	902	913	907	803	919	934	902	880	883	876	878	902	910	911	892	898	903	884	
4	1号炉	970	982	991	1,003	1,018	989	1,012	964	980	911	943	937	901	935	916	931	923	935	942	920	944	949	978	982	
	2号炉	896	898	905	892	903	938	918	917	922	884	895	896	888	893	890	886	891	881	896	905	875	932	904	894	
5	1号炉	987	977	965	969	958	948	926	956	957	907	913	944	925	918	937	921	932	925	891	874	901	901	892	899	
	2号炉	886	918	908	886	905	883	884	917	927	942	929	932	929	930	915	916	911	916	887	900	909	901	889	863	
6	1号炉	898	913	919	885	856	861	870	866	882	895	883	865	878	872	906	896	909	867	887	893	953	983	948	975	
	2号炉	912	910	881	896	847	845	854	873	911	926	945	915	884			997	927	913	908	905	894	898	906	896	
7	1号炉	959	939	937	909	910	889	914	878	900	929	925	939	950	914	908	969	934	925	935	924	921	966	911	915	
	2号炉	904	926	889	872	881	873	892	876	877	906	896	888	912	894	894	907	900	914	910	888	907	895	886	882	
8	1号炉	943	924	901	875	908	908	916	921	886	847	877	921	901	902	930	935	889	906	888	875	902	908	882	899	
	2号炉	931	943	891	898	905	896	903	870	887	935	913	868	845	838	934	944	963	924	914	902	891	930	924	921	
9	1号炉	906	875	869	864	879	860	895	947	906			824	841	894	902	920	938	945	962	978	901	924	891	923	
	2号炉	944	920	921	921	924	864	860	895	916	913	915	928	918	906	862	904	895	918			936	879	919	891	
10	1号炉	918	919	896	932	953	918	935	950	927	895	981	935	897	920	916	950	939	940	917	911	954	962	905	907	
	2号炉	909	902	889	887	867	889	902	924	919	827	934	936	933	935	925	938	961	942	914	918	989	938	934	944	
11	1号炉	897	917	942	901	914	897	918	908	885	922	897	902	877	898	907	876	884	891	846	852	859	920	930	917	
	2号炉	950	925	965	933	939	921	933	930	953	935	919	927	914	899	902	938	949	922	882	876	884	924	858	857	
12	1号炉	952	931	963	950	958	921	949	916	898	903	919	928	909	944	950	966	975	917	924	895	888	875	878	878	
	2号炉	861	887	898	901	910	885	893	901	893	916	917	896	901	919	938	916	992	952	908	868	851	874	865	893	
13	1号炉	884	883	933	994	941	867	910	912	869	886	849	894	868	815			871	852	896	939	894	902	878	864	
	2号炉	876	875	889	884	822	918	860	882	881	864	850	894	869	860	889	878	877	899	882	879	845	844	881	886	
14	1号炉	861	913	880	897	853	852	903	867	864	888	913	887	879	884	862	856	840	899	868	832	864	838	818	871	
	2号炉	846	888	876	852	845	844	837	863	868	883	890	856	870	866	904	879	871	873	873	877	857	861	868	847	
15	1号炉	855	955	894	891	879	890	918	879	880	856		853	855	906	855	847	862	870	871	877	896	935	933	954	
	2号炉	843	891	853	881	872	844	854	851	851	849	854	855	860	849	816	833	853	887	944	945	943	993	871	965	

6月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	1,007	999	982	936	922	936	900	973	1,017	1,044	1,061	1,099	1,063	1,049	1,034	1,046	1,061	1,023	982	1,009	1,048	1,058	1,047	1,026	
	2号炉																	892	902	889	889	945	943	920	980	立ち上げ～定常運転
17	1号炉	1,028	1,021	993	982	1,045	1,026	996	977	926	1,044	1,049	983	980	1,006	982	1,018	1,011	970	987	979	971	980	983	980	
	2号炉	952	940	932	907	954	925	921	897	906	954	1,004	946	954	943	949	932	939	958	954	965	1,006	1,021	984	969	
18	1号炉	968	974	1,003	976	966	1,016	945	981	1,020	1,016	1,026	1,011	953	973	1,025	958	990	962	952	973	967	994	968	988	
	2号炉	972	980	973	943	955	982	971	955	997	957	948	989	987	982	976	957	919	968	959	963	961	983	946	958	
19	1号炉	1,020	975	1,007	974	966	944	943	972	964	1,041	1,011	964	999	1,010	1,006	1,037	853	1,005	940	972	910	947	957	1,005	
	2号炉	960	968	965	970	989	957	978	996	978	928	944	971	960	938	942	946	973	968	1,010	989	935	962	998	974	
20	1号炉	924	921	929	935	916	916	905	897	903	934	920	1,008	978	939	931	889	958	924			907	939	895	883	
	2号炉	938	983	968	949	984	953	972	978	1,014		1,062	911	930	929	935	959	935	935	988	944	921	944	913	948	
21	1号炉	917	920	950	941	948	937	947	928	941	850	951	957	954	978	991	979	971	958	902	916	969	960	957	919	
	2号炉	991	980	967	967	976	970	963	964	976	906	975	972	937	953	968	932	959	993	974	930	949	1,014	975	1,038	
22	1号炉	911	925	931	971	949	947	921	920	902	954	946	944	896	882	880	873	878	875	931	938	925	905	843	868	
	2号炉	935	976	965	984	985	962	992	970	972	986	1,019	1,007	1,005	985	978	944	944	996	998	1,002	982	973	948	957	
23	1号炉	872	886	895	903	934	890	958	912	895	928	916	897	942	933	898	920	911	869	916	882	847	882	918	975	
	2号炉	922	926	947	969	976	961	962	979	974	949	949	967	947	972	920	978	948	962	984	966	997	977	971	1,019	
24	1号炉	911	953	988	938	943	961	957	977	875	858	918	894	923	901	907	872	928	948	931	946	999	912	991	985	
	2号炉	955	953	957	990	1,036	956	984	953	931	967	976	938	933	937	970	975	965	972	948	975	957	973	919	934	
25	1号炉	983	952	979	936	979	970	944	964	964	954	967	981	976	969	956	984	984	950	955	948	961	943	959	932	
	2号炉	949	988	1,006	945	955	981	981	960	946	985	998	979	985	981	956	985	971	995	959	945	978	971	974	963	
26	1号炉	970	925	964	985	1,022	987	990	963	1,010	937	963	989	954	908	954	912	928	945	946	949	997	898	934	939	
	2号炉	986	973	951	943	944	1,007	1,036	1,023	1,006	1,030	984	1,012	930	946	949	935	950	1,000	990	973	1,001	993	1,006	983	
27	1号炉	957	939	913	916	861	921	887	908	885		1,007	1,003	1,065	970	935	1,019	944	954	952	926	916	942	932	934	
	2号炉	994	1,002	944	960	916	942	971	955	958	980	947	1,032	997	959	953	958	980	975			1,030	981	977	957	
28	1号炉	917	886	911	903	843	885	970	956	945	800			800	942	948	966	945	1,013	998	916	918	982	928	989	
	2号炉	976	952	962	964	947	921	953	979	983	934	1,009	958	1,029	1,012	1,012	1,002	980	1,009	978	956	933	970	946	911	
29	1号炉	955	944	946	912	893	933	984	907	961	991	996	998	1,004	1,009	973	970	960	1,000	953	937	944	991	903	930	
	2号炉	925	926	914	899	922	913	939	912	912	923	930	917	934	923	926	910	909	942	928	934	900	902	879	917	
30	1号炉	917	910	934	946	914	928	913	875	914																定常運転～立ち下げ
	2号炉	886	890	890	892	906	892	868	890	889	884	916	916	901	885	875	871	867	902	904	868	875	891	892	899	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成29年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	893	879	897	910	907	900	890	889	890	862	845	853	879	884	884	875	870	870	876	893	868	870	876	898	
2	1号炉																									休炉
	2号炉	899	910	919	898	887	903	862	889	909	909	873	864	903	916	895	878	876	879	900	869	902	889	884	902	
3	1号炉																									休炉
	2号炉	907	913	916	902	912	899	913	882	870	882	874	878	850	864	859	901	887	895	879	897	878	885	881	869	
4	1号炉																									休炉
	2号炉	871	881	876	878	927	881	875	872	880	877	913	905	883	863	883	865	887	846				899	856	852	
5	1号炉																									休炉
	2号炉	871	869	882	871	858	857	869	893	877	818	861	871	853	890	858	862	874	880	899	864	854	873	897	852	
6	1号炉																									休炉
	2号炉	874	857	883	869	858	861	853	844	879	901	894	896	865	872	879	851	870	891	878	880	859	867	906	920	
7	1号炉																									休炉
	2号炉	885	876	915	905	893	884	875	857	873	861	885	886	876	878	877	884	898	882	903	871	892	914	885	904	
8	1号炉																									休炉
	2号炉	889	906	867	891	875	867	887	900	886	874	867	870	884	864	869	866	877	874	856	860	884	898	898	884	
9	1号炉																									休炉
	2号炉	881	867	878	854	834	911	929	923	928	926	920	922	936	922	924	922	947	920	906	907	894	891	899	879	
10	1号炉																									休炉
	2号炉	918	919	874	904	924	917	883	873	873	892	880	907	944	896	886	901	881	875	878	884	840	860	887	861	
11	1号炉																									休炉
	2号炉	880	894	903	878	882	875	853	868	877	869	867	881	861	878	890	880	877	868			897	864	861	890	
12	1号炉							921	888	950	964	949	951	902	912	899	901	892	843	913	920	908	895	887	立ち上げ～定常運転	
	2号炉	893	872	861	870	864	865	856	867	864	762	861	856	878	895	879	808	819	861	894	903	895	875	897	905	8:59～9:44給じん停止
13	1号炉	900	982	905	932	896	912	924	900	922	933	958	934	946	987	955	936	919	853	823	856	945	938	866	901	
	2号炉	897	914	887	889	901	907	909	903	889	909	907	882	864	916	861	857	864	853	862	869	865	858	853	858	
14	1号炉	910	850	923	904	876	875	866	907	892	907	913	901	995	959	947	950	939	968	921	984	898	923	932	961	
	2号炉	852	863	876	869	879	857	861	833	872	861	841	851	851	883	860	891	941	924	966	935	923	936	927	924	
15	1号炉	953	963	915	920	942	933	875	936	935	903	940	941	907	938	956	953	919	936	939	916	951	936	897	897	
	2号炉	910	923	931	882	897	915	915	919	910	903	882	897	897	902	918	883	911	909	891	874	872	879	863	870	

7月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	910	936	924	899	909	937	917	972	949	928	928	940	934	942	908	900	905	903	915	961	945	936	930	915	
	2号炉	862	873	852	868	874	846	890	870	873	900	899	876	870	854	868	875	856	844	874	846	881	879	887	901	
17	1号炉	920	948	967	987	940	962	967	960	948	918	930	907	889	872	909	946	893	922	908	921	964	861	888	876	
	2号炉	898	892	878	887	855	869	864	862	872	862	851	858	874	865	854	859	884	866	887	870	864	861	866	846	
18	1号炉	883	902	937	892	929	930	866	923	909	924	960	969	935	928	932	901	919	900			1,025	927	909	879	
	2号炉	863	853	844	831	850	840	859	831	872			868	863	849	854	837	833	864	865	864	876	873	857	872	
19	1号炉	907	888	929	901	972	912	925	886	929	824	938	971	931	959	946	939	941	918	885	875	888	939	911	941	
	2号炉	895	880	881	871	901	875	861	857	878	743	848	881	887	880	860	876	880	878	853	848	854	838	856	851	9:16~10:14給じん停止
20	1号炉	993	944	940	964	952	998	994	1,046	995	984	1,003	995	993	965	967	973	898	914	925	904	935	940	922	893	
	2号炉	867	870	864	870	875	857	856	836	807	902	924	929	928	909	868	901	868	861	877	873	889	881	855	862	
21	1号炉	883	926	885	874	898	903	917	883	892	918	919	909	916	926	899	902	910	951	935	930	947	937	967	967	
	2号炉	864	872	852	851	918	858	860	859	860	854	854	872	854	861	842	857	918	914	908	903	899	915	918	915	
22	1号炉	937	948	934	974	953	924	943	975	938	927	953	946	960	969	980	990	950	959	922	936	944	949	985	993	
	2号炉	907	922	901	901	912	904	900	903	900	903	884	893	882	885	924	896	885	894	897	895	890	879	899	892	
23	1号炉	965	969	955	991	958	971	943	955	951	984	962	978	978	943		932	921	940	935	943	943	954	943	948	
	2号炉	901	889	880	898	899	887	892	886	900	881	876	877	889	880	871	882	872	883	867	871	867	876	882	913	
24	1号炉	960	930	946	946	942	966	938	935	950	939	953	975	1,003	936	937	938	909	947	921	944	934	980	959	959	
	2号炉	906	909	899	913	939	936	959	931	935	931	920	930	956	935	909	875	879	885	884	884	899	903	904	913	
25	1号炉	957	924	935	930	917	948	913	891	870			917	894	887	905	889	892	912	883	904	890	890	913	895	
	2号炉	916	893	890	875	898	889	903	911	886	887	905	885	877	886	896	896	880	879				931	905	915	
26	1号炉	903	900	891	908	885	896	912	908	864	821	880	881	886	882	895	907	916	942	968	915	813	903	977	903	
	2号炉	903	908	904	914	897	892	892	897	894	807	887	899	885	890	882	888	877	887	919	906	866		875	880	
27	1号炉	951	898	884	896	921	901	873	885	877	887	929	921	896	922	935	925	918	904	869	917	887	894	882	879	
	2号炉	868	879	867	877	863	852	854	846	850	847	866	845	828	917	898	917	895	920	906	901	929	899	886	906	
28	1号炉	853	889	886	875	876	900	904	886	911	870	884	865	868	859	849	891	890	873	886	874	856	870	890	877	
	2号炉	901	882	896	866	873	876	909	871	892	874	860	855	868	874	862	895	870	860	861	861	847	857	870	855	
29	1号炉	908	888	887	880	877	890	892	872	872	903	890	888	879	877	879	866	875	869	872	891	883	907	938	884	
	2号炉	878	870	860	859	858	869	856	860	885	874	862	862	860	865	864	856	856	871	874	870	878	856	894	860	
30	1号炉	904	906	900	876	896	899	909	897	902	868	870	866	891	879	905	899	876	883	929	943	928	954	889	961	
	2号炉	869	883	877	877	885	908	884	941	893	867	869	871	873	870	891	887	868	878	881	887	887	889	891	891	
31	1号炉	909	918	926	926	896	909	883	864	909	839	902	905	881	856	891	838	875	873	866	828	851	845	899	900	
	2号炉	898	893	895	890	872	883	869	877	886	897	867	898	869	901	890	766	889	861	864	847	862	868	880	874	15:10~15:51給じん停止

8月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	858	860	874	877	845	857	856	871	851	774	860	858	850	849	862	899	891	872	885	868	860	900	861	868	8:49~9:37給じん停止
	2号炉																									
17	1号炉	863	846	845	864	882	857	844	846	885	887	869	861	869	866	827	793	853	880	877	855	880	880	794	931	14:47~15:18、 22:35~23:03給じん停止
	2号炉																									
18	1号炉	934	955	969	966	979	960	958	957	970	976	973	960	972	944	958	952	958	956	962	956	949	946	955	938	
	2号炉																									
19	1号炉	962	966	972	998	949	959	958	974	966	970	960	941	960	948	971	968	974	962	918	927	953	965	966	953	
	2号炉																									
20	1号炉	965	940	934	938	932	938	943	945	934	952	938	944	960	943	919	931	916	921	934	942	932	955	947	933	
	2号炉																									
21	1号炉	948	955	954	920	942	957	953	942	944	951	936	916	942	936	911	919	933	920	892	898	908	911	881	860	
	2号炉																									
22	1号炉	908	891	896	895	883	869	863	904	953	909	989	979	988	960	981	931	967	939			943	947	933	949	
	2号炉																									
23	1号炉	958	961	939	965	951	968	922	948	946	872	950	967	1,009	981	970	983	983	944	931	923	959	912	925	949	
	2号炉																									
24	1号炉	950	939	978	966	970	968	922	937	955	973	934	931	938	964	931	929	942	961	979	958	960	964	966	954	
	2号炉																									
25	1号炉	983	965	992	946	908	962	946	962	944	945	969	946	943	936	918	946	920	921	915	927	947	908	935	933	
	2号炉																									
26	1号炉	962	962	906	921	917	887	918	889	889	914	926	919	897	911	956	985	929	937	900	927	930	929	903	927	
	2号炉																									
27	1号炉	892	885	881	880	872	927	946	956	952	974	961	973	961	965	979	971	967	983	983	999	1,037	1,003	996	954	
	2号炉																									
28	1号炉	964	962	958	993	974	989	932	993	981	976	1,012	1,006	1,019	998	925	972	932	920	935	945	936	923	964	975	
	2号炉																									
29	1号炉	971	944	942	928	955	930	940	942	969	974	988	984	988	991	971	1,004	966	984	984	981	1,013	1,015	1,003	1,027	
	2号炉																									
30	1号炉	1,017	989	1,005	1,020	972	964	982	991	964		949	957	932	787	944	953	959	966	962	953	943	906	924	966	13:16~13:50給じん停止
	2号炉																	866	889	883	888	902	889	913	878	立ち上げ~定常運転
31	1号炉	918	948	980	983	902	911	932	943	951	937	910	920	929	878	875	906	924	913	751						18:11~翌日3:56給じん停止
	2号炉	899	956	966	947	917	937	927	976	997	943	988	942	944	961	964	947	967	935	925	950	957	959	924	933	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

平成29年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

9月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉				670	831	832	868	872	874	921	904	901	899	905	890	924	906	903	961	940	937	947	962	927	前日18:11~3:56給じん停止
	2号炉	930	942	907	920	975	975	951	969	940	993	964	1,002	990	960	986	975	962	975	965	958	956	946	932	931	
2	1号炉	953	944	940	996	991	1,030	976	1,005	962	950	905	939	951	934	923	945	964	987	950	984	1,018	1,012	992	1,004	
	2号炉	908	905	952	962	983	974	924	952	971	971	963	962	940	989	963	964	997	972	944	919	947	955	1,002	971	
3	1号炉	1,044	1,025	979	941	955	948	987	917	978	956	968	971	937	977	994	997	971	991	973	919	938	949	972	976	
	2号炉	958	948	961	900	1,012	982	987	1,004	988	934	968	968	982	970	976	992	1,012	996	935	935	945	958	969	984	
4	1号炉	960	984	962	1,017	970	964	950	896	934	937	950	990	917	972	947	950	958	992	965	944	954	972	1,017	977	
	2号炉	960	980	989	1,003	999	993	972	952	939	968	983	933	929	930	939	943	946	937	910	915	905	937	918	989	
5	1号炉	980	943	932	904	914	926	911	893	915		910	927	909	897	932	914	906	881	854	863	835	885	943	955	
	2号炉	927	989	976	984	966	958	951	945	978	957	1,008	992	972	953	977	964	975	985			916	947	901	971	
6	1号炉	1,004	972	969	965	986	963	976	974	975	830	968	966	1,006	990	975	974	1,025	980	947	954	993	969	1,011	984	
	2号炉	962	961	944	960	945	939	937	924	937	882	1,013	966	947	951	942	962	920	951	940	969	1,009	980	962	972	
7	1号炉	977	982	965	936	963	904	965	964	979	1,024	1,010	959	950	952	955	971	1,010	946	922	922	957	923	903	975	
	2号炉	963	980	940	962	956	934	935	943	956	986	994	961	968	936	968	986	978	932	977	916	963	941	893	963	
8	1号炉	953	973	965	917	962	962	948	960	940	945	971	970	1,054	973	989	1,023	1,004	969	948	972	906	956	940	961	
	2号炉	914	942	919	944	926	940	932	970	950	971	975	956	953	959	936	934	926	898	973	968	968	922	926	914	
9	1号炉	952	909	939	929	987	975	945	907	898	871	875	858	840	934	936	904	865	838	866						定常運転~立ち下げ
	2号炉	944	903	906	912	938	922	910	898	867	958	938	927	936	952	982	1,012	953	1,003	952	1,027	960	917	981	946	
10	1号炉																									休炉
	2号炉	974	1,031	950	878	980	989	983	967	968	937	936	993	984	972	935	949	955	961	960	954	969	991	967	955	
11	1号炉																									休炉
	2号炉	987	990	970	958	967	991	968	984	977	986	1,037	998	1,011	913	988	953	947	894	929	916	975	954	929	974	
12	1号炉																									休炉
	2号炉	964	982	975	960	973	960	968	933	944	934	938	975	945	926	967	954	943	932				931	957	922	
13	1号炉																									休炉
	2号炉	915	933	911	975	926	966	917	917	923	874	831	887	880	855	931	957	885	895	919	998	965	938	899	947	
14	1号炉																									休炉
	2号炉	976	973	964	957	924	919	929	928	944	961	952	984	1,022	970	943	958	969	949	929	925	949	970	964	990	
15	1号炉																									休炉
	2号炉	992	950	939	934	941	903	967	949	928	944	957	963	974	958	956	951	956	965	942	841					定常運転~立ち下げ

9月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考		
16	1号炉																										休炉	
	2号炉																											休炉
17	1号炉										851	897	868	884	867	865	874	882	922	916	907	896	936	886	927		立ち上げ～定常運転	
	2号炉																											休炉
18	1号炉	918	924	902	892	903	898	925	940	929	932	911	883	913	889	886	874	881	884	904	907	891	887	896	905			
	2号炉																											休炉
19	1号炉	931	934	933	904	925	949	945	970	937	923	909	930	1,056	1,010	965	940	945	970	982	962	955	952	954	955			
	2号炉																											休炉
20	1号炉	921	928	921	953	938	983	964	910	928	921	949	930	950	1,072	1,056	989	944	928	976	920	904	941	912	937			
	2号炉																											休炉
21	1号炉	953	928	931	921	976	926	959	926	935	937	900	927	947	895	863	879	881	877	911	916	898	918	913	958			
	2号炉																											休炉
22	1号炉	907	852		927	898	908	884	881	877	900	917	905	901	929	913	952	921	893	886	893	897	905	927	922			
	2号炉																											休炉
23	1号炉	936	910	923	894	897	892	936	896	887	863	893	885	878	891	918	914	907	955	969	925	926	909	869	950			
	2号炉																											休炉
24	1号炉	907	887	897	931	947	921	930	941	931	897	910	906	907	912	916	941	929	927	935	918	951	954	961	958			
	2号炉						797	903	933	923	930	953	954	917	902	891	905	925	918	912	945	940	933	910	907		立ち上げ～定常運転	
25	1号炉	965	981	964	934	946	927	904	919	936	936	950	964	935	928	945	887	916	939	961	933	928	894	920	915			
	2号炉	954	931	912	926	931	910	905	895	934	947	956	953	907	918	911	912	903	929	948	935	897	910	868	940			
26	1号炉	949	887	906	889	940	942	943	908	913	933	907	910	919	895	886	909	900	868		944	890	866	894	875			
	2号炉	928	918	902	922	939	929	942	908	912	926	964	912	907	905	900	1,011	965	971	966	956	965	944	924	941			
27	1号炉	874	899	876	875	903	909	887	875	890	816	885	877	887	913	881								859	895	903		
	2号炉	954	974	947	947	953	956	951	953	945	892	983	963	981	953	974	968	916	979	995	949	952	970	980	955			
28	1号炉	897	948	945	912	928	959	941	938	957	968	959	965	948	951	942	964	983	815					898	971	1,025		
	2号炉	964	915	925	915	927	961	943	932	999	921	963	953	965	933	972	1,006	946	976	952	972	939	934	951	887			
29	1号炉	1,032	974	971	960	947	963	938	967	937	939	1,006	1,005	971	1,013	1,001	956	946	970	972	961	969	926	892	991			
	2号炉	804	848	833	902	938	931	924	937	948	834	986	960	947	948	915	960	971	932	914	928	918	895	874	975			
30	1号炉	953	915	948	962	957	918	927	919	915	948	960	966	931	929	940	878	883	941	971	1,048	1,000	970	994	955			
	2号炉	937	843	860	903	920	890	842	818	897	923	919	917	934	904	894	895	958	906	927	847	876	982	955	940			