

平成29年度 排ガス中のばい煙濃度等

10月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	90	10	65.5	34	1	19	2	0	0.5	8	2	4
2	0	0	0	79	27	52	38	12	26	1	0	0	5	2	3.5
3	0	0	0	73	8	41.5	36	0	23.5	1	0	0	4	1	2.5
4	0	0	0	69	25	45.5	35	9	24.5	3	0	0.5	4	1	2.5
5	0	0	0	78	28	52	38	11	26	1	0	0	6	2	3
6	0	0	0	79	25	50	35	1	24	1	0	0	5	1	3
7	0	0	0	88	15	62.5	38	8	23	1	0	0	8	2	5
8	0	0	0	79	18	44.5	39	6	26	0	0	0	7	2	4.5
9	0	0	0	94	5	52	35	4	23.5	1	0	0	8	1	4.5
10	0	0	0	85	5	51.5	37	0	20	1	0	0	6	1	3.5
11	0	0	0	88	12	60	34	1	16.5	2	0	0.5	6	1	4
12	0	0	0	83	16	52.5	38	3	22.5	1	0	0	6	1	3
13	0	0	0	86	21	56	40	7	25.5	1	0	0	5	1	2.5
14	0	0	0	81	11	54	56	1	25.5	1	0	0	8	0	3
15	0	0	0	82	3	43.5	36	0	17.5	1	0	0	7	1	2.5
16	0	0	0	84	10	53	56	1	20.5	1	0	0	6	0	2.5
17	0	0	0	74	3	42.5	48	1	29.5	3	0	0	7	0	2.5
18	0	0	0	78	15	48	49	10	31	3	0	0	4	2	3
19	0	0	0	80	26	50	45	16	31	0	0	0	4	1	2.5
20	0	0	0	64	1	41.5	35	7	25.5	0	0	0	4	2	3
21	0	0	0	73	8	39	35	4	21.5	0	0	0	4	2	3
22	0	0	0	92	3	50.5	35	1	18.5	0	0	0	8	1	4
23	0	0	0	88	5	48.5	56	13	37.5	0	0	0	7	2	4
24	0	0	0	76	1	39	48	2	33.5	1	0	0	4	0	3
25	0	0	0	84	7	44	43	5	24.5	4	0	0	5	2	3
26	0	0	0	77	6	45	34	4	22	1	0	0	7	1	3
27	0	0	0	87	1	37.5	34	0	17.5	0	0	0	6	0	3
28	0	0	0	81	3	56	31	1	20	0	0	0	6	0	4
29	0	0	0	95	43	69	31	10	22	0	0	0	7	2	5
30	0	0	0	88	48	70	29	7	20	0	0	0	7	3	5
31	0	0	0	85	38	60	32	6	24	0	0	0	6	2	4

平成29年度 排ガス中のばい煙濃度等

11月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	95	24	71	37	7	22	0	0	0	4	2	4
2	0	0	0	90	49	66	51	13	33	0	0	0	5	3	3
3	0	0	0	79	38	61	31	2	23	0	0	0	4	2	2
4	0	0	0	92	4	62.5	35	2	20.5	2	0	0.5	4	0	3
5	0	0	0	91	25	67	33	6	23.5	1	0	0	5	1	3
6	0	0	0	94	28	73.5	31	1	15.5	2	0	0.5	9	1	4.5
7	0	0	0	92	2	54.5	37	0	21	2	0	0	6	1	4
8	0	0	0	86	15	51.5	35	3	22.5	1	0	0	5	2	3.5
9	0	0	0	85	5	61	39	0	20.5	1	0	0	6	2	4
10	0	0	0	78	16	55	42	14	27	1	0	0	5	1	2.5
11	0	0	0	85	15	46	40	1	25.5	0	0	0	6	1	3
12	0	0	0	91	14	56	41	9	30	1	0	0	6	2	3.5
13	0	0	0	84	23	53	47	2	31	0	0	0	5	2	3.5
14	0	0	0	61	2	37.5	42	3	29	0	0	0	4	0	3
15	0	0	0	90	26	58.5	38	2	21.5	1	0	0	6	2	4
16	0	0	0	90	8	53.5	38	4	26.5	0	0	0	6	2	3.5
17	0	0	0	82	3	35	45	1	29.5	2	0	0	5	0	2.5
18	0	0	0	92	3	53	37	4	27	0	0	0	5	2	3
19	0	0	0	89	19	50	37	8	24	1	0	0	5	2	3
20	0	0	0	74	22	42	53	14	29	1	0	0	5	3	4
21	0	0	0	53	1	22	52	2	25	0	0	0	4	0	3
22	0	0	0	77	7	45	50	5	25	2	0	0	11	2	3
23	0	0	0	81	12	55	32	13	24	0	0	0	4	2	3
24	0	0	0	59	11	32	38	17	28	0	0	0	4	2	3
25	0	0	0	47	1	24	43	26	35	0	0	0	4	0	3
26	0	0	0	59	9	35	41	17	29	0	0	0	3	2	2
27	0	0	0	66	11	33	52	22	34	0	0	0	3	2	2
28	0	0	0	63	1	37	51	8	31	0	0	0	5	1	3
29	0	0	0	89	13	48	49	4	27	1	0	0	5	2	4
30	0	0	0	75	15	36	37	11	30	0	0	0	5	3	4

平成29年度 排ガス中のばい煙濃度等

12月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	82	16	46	39	4	25	0	0	0	5	2	4
2	0	0	0	66	5	34	49	21	36	0	0	0	4	3	3
3	0	0	0	60	7	34	43	19	33	0	0	0	5	3	4
4	0	0	0	78	11	42.5	52	15	36	15	0	1.5	5	1	3
5	0	0	0	55	1	27	50	2	33.5	0	0	0	4	0	3
6	0	0	0	71	3	33	50	13	32.5	2	0	0	5	2	3.5
7	0	0	0	82	18	47.5	59	13	31	1	0	0	5	3	3.5
8	0	0	0	82	14	38.5	61	6	29.5	1	0	0	7	3	4
9	0	0	0	85	13	42	44	6	33	0	0	0	8	3	4.5
10	0	0	0	86	11	41.5	39	12	29	0	0	0	11	2	4.5
11	0	0	0	90	22	48	41	10	26	1	0	0	7	2	3.5
12	0	0	0	71	1	33.5	47	2	31.5	1	0	0	5	0	2.5
13	0	0	0	78	2	37	50	15	33	0	0	0	7	1	3
14	0	0	0	58	7	26.5	47	9	34.5	0	0	0	4	1	2.5
15	0	0	0	42	5	24.5	52	22	38	0	0	0	4	2	2.5
16	0	0	0	53	29	41	37	26	33	0	0	0	4	3	3
17	0	0	0	75	30	48	39	24	31	0	0	0	6	3	5
18	0	0	0	74	22	40	39	22	33	0	0	0	6	0	2
19	0	0	0	55	19	35	43	25	33	0	0	0	6	2	3
20	0	0	0	55	20	39	40	19	33	0	0	0	5	2	3
21	0	0	0	61	22	41	38	29	33	0	0	0	6	3	4
22	0	0	0	72	31	49	38	28	34	0	0	0	6	3	4
23	0	0	0	79	32	51	38	30	35	0	0	0	8	3	5
24	0	0	0	65	27	50	38	28	35	0	0	0	5	3	4
25	0	0	0	69	10	38	41	7	27.5	12	0	3.5	4	1	3
26	0	0	0	83	8	39.5	64	14	31.5	7	0	2.5	5	1	3.5
27	0	0	0	83	18	47	35	9	25	5	0	2.5	5	1	2.5
28	0	0	0	84	18	52.5	40	11	27.5	8	0	2.5	5	2	3
29	0	0	0	80	3	47	42	2	26.5	6	0	2.5	5	0	2.5
30	0	0	0	96	5	45.5	38	3	23.5	6	0	2.5	5	0	2.5
31	0	0	0	88	6	41.5	36	20	28.5	6	0	2.5	8	3	5

平成29年度 排ガス中のばい煙濃度等

1月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	85	23	53	39	20	26.5	5	0	2.5	7	4	5
2	0	0	0	89	0	47	36	1	25.5	6	0	2.5	7	0	3.5
3	0	0	0	83	5	47	33	1	24	6	0	2.5	6	2	4
4	0	0	0	88	21	49.5	34	19	26	5	0	2.5	8	3	5
5	0	0	0	79	6	40.5	38	22	29	6	0	2.5	9	2	5
6	0.01	0	0	70	6	33	39	18	30	6	0	2.5	5	2	3
7	0.02	0	0.01	67	19	38	39	20	29	6	0	2.5	5	2	3.5
8	0.02	0	0.01	71	4	34.5	38	19	29	6	0	2.5	7	3	4
9	0.03	0	0.01	53	3	26.5	51	1	28	6	0	2.5	4	0	2.5
10	0.02	0	0.01	78	4	45	34	11	26.5	6	0	2.5	7	1	4
11	0.02	0.01	0.01	74	2	24	33	20	28	6	4	6	12	3	6
12	0.02	0	0.01	39	1	19	30	8	26	6	0	1	4	1	3
13	0.02	0	0.01	55	6	30	31	24	26	0	0	0	5	3	4
14	0.02	0.01	0.02	72	23	43	29	24	26	0	0	0	6	3	5
15	0.03	0	0.02	65	2	31	39	3	27	0	0	0	8	1	5
16	0.04	0	0.02	61	1	35	29	12	25	0	0	0	7	1	5
17	0	0	0	55	16	32	30	25	27	0	0	0	4	3	3
18	0	0	0	50	5	26	35	21	27	0	0	0	4	2	3
19	0	0	0	60	16	37	32	25	28	0	0	0	4	2	3
20	0	0	0	53	12	31	33	19	28	0	0	0	4	2	3
21	0	0	0	43	9	20.5	33	21	25.5	6	0	3	4	3	3
22	0	0	0	61	6	33.5	60	1	29	0	0	0	5	1	3.5
23	0	0	0	76	4	34.5	41	13	30	0	0	0	7	1	3.5
24	0	0	0	77	9	38	40	23	30.5	0	0	0	5	2	3.5
25	0	0	0	67	12	37	39	26	31.5	0	0	0	6	3	4
26	0	0	0	64	4	28.5	47	13	31.5	0	0	0	6	1	3.5
27	0	0	0	70	17	34.5	39	23	30.5	0	0	0	6	3	4
28	0	0	0	87	26	52	33	16	28	0	0	0	7	3	4.5
29	0	0	0	68	10	37.5	42	9	29.5	0	0	0	6	3	4
30	0	0	0	64	3	28.5	39	1	29	0	0	0	8	2	4.5
31	0	0	0	84	3	40.5	38	2	27	0	0	0	6	0	3.5

平成29年度 排ガス中のばい煙濃度等

2月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	63	17	33.5	38	24	29	0	0	0	5	1	2.5
2	0	0	0	67	8	37	39	14	28	0	0	0	5	1	3
3	0	0	0	80	16	41	39	11	29	0	0	0	7	2	4.5
4	0	0	0	46	4	25	39	25	32.5	0	0	0	9	3	5.5
5	0	0	0	54	2	22	42	26	33.5	0	0	0	7	2	3.5
6	0	0	0	74	0	26.5	39	2	28	0	0	0	5	0	2.5
7	0	0	0	63	7	26.5	39	18	31	0	0	0	5	1	3
8	0	0	0	63	8	28	43	23	32.5	0	0	0	6	1	4
9	0	0	0	35	1	15.5	61	16	32	0	0	0	8	2	4
10	0	0	0	55	2	29	40	2	27	0	0	0	4	0	3.5
11	0	0	0	63	18	31	38	11	27.5	0	0	0	10	2	5.5
12	0	0	0	44	4	25	33	3	20.5	0	0	0	8	2	4.5
13	0	0	0	48	2	22.5	64	0	23	0	0	0	6	1	4
14	0	0	0	57	4	23	65	0	22	0	0	0	6	1	3.5
15	0	0	0	77	7	35	30	1	19	0	0	0	8	0	3.5
16	0	0	0	76	6	37.5	37	0	18.5	0	0	0	6	1	3
17	0	0	0	68	4	32	32	4	20	0	0	0	4	0	2
18	0	0	0	70	9	33	28	0	16	0	0	0	3	1	2
19	0	0	0	43	5	22	39	1	17	0	0	0	5	1	3
20	0	0	0	66	6	31	30	1	16	0	0	0	6	1	2
21	0	0	0	69	12	37	26	2	15	0	0	0	5	1	2
22	0	0	0	72	21	43	32	1	17	3	0	0	8	2	4
23	0	0	0	91	25	53	28	0	14	1	0	0	5	2	3
24	0	0	0	65	23	44	35	8	25	18	0	10	9	3	6
25	0	0	0	53	22	38	36	16	28	0	0	0	8	3	4
26	0	0	0	69	24	42	49	18	33	0	0	0	7	3	4
27	0	0	0	66	34	48	35	5	26	0	0	0	7	2	3
28	0	0	0	54	22	35	34	22	29	0	0	0	6	2	3

平成29年度 排ガス中のばい煙濃度等

3月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	51	22	34	35	20	30	0	0	0	5	1	2
2	0	0	0	55	24	36	37	12	30	0	0	0	4	1	2
3	0	0	0	12	6	9	38	24	33	0	0	0	7	1	4
4	0	0	0	67	27	45	40	25	32	0	0	0	5	3	4
5	0	0	0	62	22	43	36	17	29	0	0	0	4	1	2
6	0	0	0	54	15	30	39	10	28	0	0	0	3	1	2
7	0	0	0	35	21	28	39	24	34	0	0	0	3	2	3
8	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20	0	0	0	65	2	23	44	4	31	3	0	0	7	1	4
21	0	0	0	56	11	32	42	30	35	0	0	0	5	2	4
22	0	0	0	41	1	26	59	28	42	0	0	0	5	3	4
23	0	0	0	68	6	31	60	32	47	0	0	0	6	0	3
24	0	0	0	61	8	34.5	61	40	51.5	0	0	0	7	1	4.5
25	0	0	0	79	15	37.5	60	18	46.5	0	0	0	8	3	5
26	0	0	0	74	1	32.5	59	3	44	0	0	0	6	1	4
27	0.02	0	0	73	4	40.5	54	1	38	0	0	0	8	2	5
28	0	0	0	73	10	39.5	60	6	41.5	0	0	0	7	2	4.5
29	0	0	0	71	13	41.5	55	0	39.5	0	0	0	9	2	5
30	0	0	0	80	7	43	58	6	39	0	0	0	10	2	6
31	0	0	0	86	11	46.5	37	11	27.5	0	0	0	11	3	6.5