

平成30年度 排ガス中のばい煙濃度等

4月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	69	1	28.5	36	0	28.5	0	0	0	9	2	6
2	0	0	0	67	1	31.5	35	2	24.5	0	0	0	11	1	6
3	0	0	0	80	0	29.5	39	0	24	0	0	0	11	1	5
4	0	0	0	70	8	43	38	0	23	1	0	0	8	3	5
5	0	0	0	68	6	38	51	1	27.5	0	0	0	11	2	7
6	0	0	0	86	10	43	39	5	27	1	0	0	16	3	7.5
7	0	0	0	70	2	42	43	1	27.5	1	0	0	15	2	7.5
8	0	0	0	86	10	46.5	43	6	31	1	0	0	12	4	8.5
9	0	0	0	64	11	32	48	22	34	0	0	0	9	4	6
10	0	0	0	48	1	23.5	45	4	31.5	0	0	0	8	1	3
11	0	0	0	63	1	23	47	0	27.5	0	0	0	4	1	2.5
12	0	0	0	60	9	33.5	52	15	30.5	1	0	0	6	1	3.5
13	0	0	0	58	5	29.5	51	9	32	0	0	0	6	1	3
14	0	0	0	84	7	41	46	6	32	0	0	0	13	2	5
15	0	0	0	75	4	44.5	42	5	26.5	1	0	0	11	2	6.5
16	0	0	0	75	5	38.5	43	9	28	0	0	0	10	1	4
17	0	0	0	49	1	22.5	45	2	34.5	0	0	0	7	1	3
18	0	0	0	63	5	29.5	40	8	29.5	0	0	0	6	2	3
19	0	0	0	59	11	32.5	37	20	31	0	0	0	10	2	5
20	0	0	0	65	10	31.5	39	2	27	1	0	0	8	2	4
21	0	0	0	79	5	35.5	37	4	25.5	0	0	0	9	1	5
22	0	0	0	66	1	26.5	40	1	28.5	0	0	0	9	1	4
23	0	0	0	77	0	27.5	40	12	30	0	0	0	7	2	3.5
24	0	0	0	51	4	21.5	40	10	30.5	0	0	0	9	2	4
25	0	0	0	71	3	24	58	1	34	1	0	0	10	1	5.5
26	0	0	0	86	3	29	40	2	27	0	0	0	15	1	5.5
27	0	0	0	54	2	18.5	39	16	32	0	0	0	10	2	5.5
28	0	0	0	47	7	22	37	9	29	0	0	0	6	2	4
29	0	0	0	70	3	37	48	5	29	0	0	0	6	2	4
30	0	0	0	55	1	29	38	24	30	0	0	0	6	3	4

平成30年度 排ガス中のばい煙濃度等

5月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	72	3	32	38	8	30	0	0	0	5	1	3
2	0	0	0	91	6	45	40	4	24	1	0	0	5	2	3
3	0	0	0	58	19	38	37	20	31	0	0	0	7	3	4
4	0	0	0	75	10	32	35	12	28	0	0	0	7	2	4
5	0	0	0	62	7	31	38	13	30	0	0	0	6	2	3
6	0	0	0	66	0	32	38	2	25	0	0	0	6	0	4
7	0	0	0	60	13	34	34	15	27	0	0	0	6	2	4
8	0	0	0	39	0	21	41	5	31	0	0	0	5	0	3
9	0	0	0	71	9	27	42	13	30	0	0	0	4	2	3
10	0	0	0	47	8	23	40	20	33	0	0	0	3	1	2
11	0	0	0	59	0	24	42	1	29	0	0	0	3	0	2
12	0	0	0	66	13	39	43	21	34	0	0	0	9	2	4
13	0	0	0	81	6	30	38	24	33	0	0	0	6	3	4
14	0	0	0	84	3	40	39	8	27	2	0	0	24	3	8
15	0	0	0	57	2	25	42	7	31	0	0	0	25	3	8
16	0	0	0	73	1	29	49	3	29.5	0	0	0	7	0	3.5
17	0	0	0	76	6	28.5	40	7	27.5	0	0	0	10	3	5
18	0	0	0	71	9	29.5	36	14	29	0	0	0	9	2	5
19	0	0	0	68	17	47	38	11	28	0	0	0	14	4	9
20	0	0	0	73	1	32	36	14	27	0	0	0	14	2	6
21	0	0	0	65	1	28	33	0	25	0	0	0	12	2	5
22	0	0	0	44	2	25	36	1	26	0	0	0	6	1	3
23	0	0	0	54	2	22	35	11	25	0	0	0	3	1	2
24	0	0	0	35	3	18	36	15	30	0	0	0	5	2	3
25	0	0	0	54	8	34	38	17	30	0	0	0	5	2	3
26	0	0	0	74	1	36.5	38	0	18	0	0	0	8	2	4.5
27	0	0	0	68	10	31	36	6	25	0	0	0	7	2	5
28	0	0	0	45	1	18	37	20	28	0	0	0	6	3	4
29	0	0	0	64	0	23.5	45	0	17.5	1	0	0	6	1	3
30	0	0	0	73	10	39	35	2	23	1	0	0	7	2	4
31	0	0	0	54	8	31.5	40	15	28	0	0	0	6	3	4.5

平成30年度 排ガス中のばい煙濃度等

6月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	82	12	41	37	5	25.5	1	0	0	8	2	5
2	0	0	0	87	19	42.5	35	11	28	0	0	0	10	3	6
3	0	0	0	87	10	44	36	9	25.5	0	0	0	11	3	5
4	0	0	0	68	16	44.5	37	10	28.5	0	0	0	11	4	6.5
5	0	0	0	71	1	34	39	8	29.5	0	0	0	12	1	5.5
6	0	0	0	70	4	41.5	61	0	26.5	1	0	0	7	1	4.5
7	0	0	0	61	3	32.5	35	10	27	0	0	0	7	2	4.5
8	0	0	0	76	13	34	34	11	26.5	0	0	0	9	2	5
9	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	0	0	0	82	21	48	31	4	16	2	1	0	4	1	2
11	0	0	0	69	0	31	34	1	23	0	0	0	6	0	3.5
12	0	0	0	72	3	32.5	37	0	26	0	0	0	5	1	3
13	0	0	0	64	1	29	36	5	26	0	0	0	6	1	3
14	0	0	0	66	9	35	39	6	26.5	0	0	0	7	1	4
15	0	0	0	84	1	41.5	39	0	25	0	0	0	8	1	5
16	0	0	0	87	17	59.5	35	1	23	1	0	0	17	3	7.5
17	0	0	0	83	11	55	35	0	22.5	1	0	0	14	2	8
18	0	0	0	73	5	37.5	37	5	25	1	0	0	12	3	5.5
19	0	0	0	75	0	27	36	0	23.5	0	0	0	9	1	4.5
20	0	0	0	73	1	31.5	36	2	23	1	0	0	10	3	4.5
21	0	0	0	89	4	36.5	36	1	24.5	1	0	0	7	3	4
22	0	0	0	93	1	42	41	0	24	1	0	0	9	0	4.5
23	0	0	0	94	19	61	53	1	26	4	0	0.5	25	3	14.5
24	0	0	0	98	22	57	55	0	20	1	0	0	15	2	6
25	0	0	0	91	6	47.5	34	0	18	1	0	0	12	2	7
26	0	0	0	64	4	28.5	35	0	23.5	1	0	0	10	0	5
27	0	0	0	78	7	39	37	4	19.5	2	0	0	8	1	4
28	0	0	0	86	15	47	39	4	21.5	1	0	0	19	2	6
29	0	0	0	93	14	40.5	37	3	21	1	0	0	9	1	4.5
30	0	0	0	79	12	49	31	1	14	1	0	0	6	1	4

平成30年度 排ガス中のばい煙濃度等

7月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	84	21	55	28	3	12	1	0	0	9	2	5
2	0	0	0	82	29	52	28	5	15	1	0	0	8	2	4
3	0	0	0	77	1	38	35	0	20	0	0	0	8	1	5
4	0	0	0	68	12	44	30	3	16	2	0	0	6	1	3
5	0	0	0	60	25	43	33	16	26	1	0	0	8	2	4
6	0	0	0	61	9	32	34	21	28	0	0	0	7	3	4
7	0	0	0	53	1	26	37	2	26	0	0	0	6	0	4
8	0	0	0	69	2	28.5	36	12	24	1	0	0	8	2	4.5
9	0	0	0	49	2	20.5	33	11	25.5	0	0	0	6	1	3.5
10	0	0	0	57	2	24.5	38	2	25	0	0	0	7	1	3.5
11	0	0	0	61	2	30.5	36	2	23.5	2	0	0	11	1	4
12	0	0	0	84	2	41.5	36	8	25	0	0	0	8	1	3.5
13	0	0	0	74	2	40.5	33	7	23.5	1	0	0	6	2	3
14	0	0	0	87	1	49.5	35	0	22	1	0	0	15	1	9
15	0	0	0	81	30	55	47	5	29	0	0	0	13	4	7
16	0	0	0	89	17	52	30	3	18.5	1	0	0	13	2	6
17	0	0	0	85	3	44.5	36	2	23	1	0	0	7	2	4
18	0	0	0	88	26	55	35	2	22	4	0	0.5	11	3	6.5
19	0	0	0	71	6	39.5	37	11	28	1	0	0	9	3	5
20	0	0	0	62	8	30	35	8	24	0	0	0	8	3	5
21	0	0	0	63	12	41	33	15	26	0	0	0	8	2	5
22	0	0	0	46	7	24	33	8	24	0	0	0	6	2	3
23	0	0	0	56	2	24	35	9	23	0	0	0	8	2	4
24	0	0	0	41	9	22	36	5	26	0	0	0	7	2	4
25	0	0	0	56	10	22	35	6	24	0	0	0	5	2	3
26	0	0	0	54	9	25	33	15	25	0	0	0	3	1	2
27	0	0	0	39	5	27	34	14	25	0	0	0	5	2	3
28	0	0	0	34	8	23	34	18	27	0	0	0	5	2	3
29	0	0	0	40	6	23	35	22	29	0	0	0	6	3	4
30	0	0	0	73	1	37	59	2	33	1	0	0	7	0	4
31	0	0	0	71	11	43	15	0	5	1	0	0	4	1	2

平成30年度 排ガス中のばい煙濃度等

8月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	70	23	52	22	12	18	0	0	0	5	3	4
2	0	0	0	76	34	57	24	10	18	1	0	0	5	2	3
3	0	0	0	77	34	58	32	11	21	1	0	0	21	2	6
4	0	0	0	93	42	64	36	17	25	1	0	0	9	3	6
5	0	0	0	68	24	48	38	20	31	1	0	0	6	3	5
6	0	0	0	71	23	47	37	18	28	0	0	0	7	3	5
7	0	0	0	67	1	42	36	1	26	1	0	0	5	0	3
8	0	0	0	74	38	56	31	15	22	2	0	0	4	1	3
9	0	0	0	88	28	56	32	16	23	1	0	0	5	2	4
10	0	0	0	79	25	63	32	13	20	1	0	0	5	2	4
11	0	0	0	80	43	61	36	18	26	1	0	0	6	3	4
12	0.02	0	0	94	17	63	35	12	24	1	0	0	8	2	6
13	0	0	0	90	4	46.5	50	4	28.5	1	0	0	9	1	4
14	0	0	0	67	4	32.5	47	6	31	1	0	0	9	0	4
15	0	0	0	89	12	42	39	17	28.5	2	0	1	8	2	4.5
16	0	0	0	82	14	43.5	47	16	34	3	0	1	6	2	3.5
17	0	0	0	70	9	39.5	47	22	35	4	0	1	8	2	3.5
18	0	0	0	93	11	47.5	48	16	35	6	0	2	6	3	4
19	0	0	0	82	2	48	41	0	30	3	0	1	6	1	4.5
20	0	0	0	91	6	40	44	5	31	4	0	1	8	2	5
21	0	0	0	64	0	28.5	40	11	30.5	2	0	0.5	6	1	3.5
22	0	0	0	88	6	38.5	38	10	26	1	0	0.5	5	2	3
23	0	0	0	71	5	33.5	39	16	29.5	2	0	0	8	2	3.5
24	0	0	0	71	3	37.5	37	19	30	2	0	0.5	7	2	4.5
25	0	0	0	81	8	44.5	37	10	26.5	1	0	0	8	1	5.5
26	0	0	0	74	18	47	39	12	28	2	0	0.5	10	4	6.5
27	0	0	0	87	0	42.5	37	0	26.5	2	0	0.5	11	2	5.5
28	0	0	0	61	0	27.5	65	1	32	2	0	0.5	8	0	4
29	0	0	0	4	3	3.5	7	5	6	0	0	0	0	0	0
30	0	0	0	77	5	40.5	31	0	17.5	1	0	0	12	2	5.5
31	0	0	0	79	5	40.5	35	0	14.5	2	0	0	8	1	5.5

平成30年度 排ガス中のばい煙濃度等

9月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	90	7	49.5	37	4	21.5	2	0	0	12	4	8
2	0	0	0	82	0	46	35	0	23.5	1	0	0	13	1	7.5
3	0	0	0	85	9	48	36	1	18.5	1	0	0	10	2	6
4	0	0	0	76	0	36	32	0	14.5	3	0	0	7	0	4.5
5	0	0	0	77	7	44	35	1	22	1	0	0.5	7	2	4
6	0	0	0	85	8	44.5	39	8	24.5	2	0	0.5	10	3	5.5
7	0	0	0	98	17	52	35	1	24	1	0	0	11	2	6
8	0	0	0	70	12	37	39	11	28	2	0	0.5	8	3	5
9	0	0	0	79	18	48.5	36	12	27.5	2	0	0.5	9	4	6
10	0	0	0	93	2	44	39	6	26	3	0	1	14	2	5
11	0	0	0	79	0	34	40	5	27	4	0	1.5	5	1	3.5
12	0	0	0	87	3	45	41	6	29.5	5	0	2	18	3	8
13	0	0	0	78	2	33.5	42	18	31.5	5	0	2	17	4	9
14	0	0	0	70	8	38.5	45	18	32	4	0	2	7	3	5
15	0	0	0	68	8	40.5	41	15	33	5	0	2	11	4	5
16	0	0	0	85	13	49.5	40	12	30	4	0	2	11	4	6
17	0	0	0	86	10	53.5	36	4	26	5	0	2	11	3	6
18	0	0	0	83	3	44	50	0	28.5	5	0	1	10	0	5
19	0	0	0	85	13	41.5	34	0	16	1	0	0	8	0	4
20	0	0	0	87	0	39	35	1	20	1	0	0	12	2	5
21	0	0	0	90	0	36.5	34	0	14.5	1	0	0	5	1	3.5
22	0	0	0	86	35	66	30	7	21	1	0	0	9	3	6
23	0	0	0	95	44	74	26	0	11	2	0	0	12	2	7
24	0	0	0	76	8	47	31	5	19	1	0	0	8	3	5
25	0	0	0	77	19	46	31	1	18	2	0	0	4	2	3
26	0	0	0	82	28	56	34	7	19	1	0	0	6	2	4
27	0	0	0	89	12	48	33	7	22	1	0	0	5	2	3
28	0	0	0	58	23	40	33	11	21	1	0	0	3	2	2
29	0	0	0	66	27	46	36	14	26	1	0	0	4	2	3
30	0	0	0	83	5	50	35	1	24	0	0	0	4	1	3