

平成30年度 排ガス中のばい煙濃度等

10月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	65	23	45	34	15	25	0	0	0	5	2	3
2	0	0	0	87	31	51	34	5	19	2	0	0	6	3	4
3	0	0	0	91	24	56	33	1	19	1	0	0	7	3	4
4	0	0	0	82	6	42.5	35	1	19.5	1	0	0	6	0	2
5	0	0	0	55	5	37	36	2	25.5	0	0	0	6	1	3
6	0	0	0	68	16	39	36	16	27	0	0	0	6	2	4
7	0	0	0	65	12	41	36	18	29	0	0	0	8	3	5
8	0	0	0	63	3	30	36	18	28	0	0	0	7	1	4
9	0	0	0	40	3	18	36	7	27	0	0	0	4	2	3
10	0	0	0	62	8	29	37	12	28	0	0	0	11	2	5
11	0	0	0	57	13	37	35	20	29	0	0	0	8	2	5
12	0	0	0	75	3	26	37	15	28	0	0	0	5	2	3
13	0	0	0	65	6	37	36	17	28	0	0	0	9	3	5
14	0	0	0	78	13	37	38	20	31	0	0	0	6	2	4
15	0	0	0	50	5	21	40	28	34	0	0	0	6	3	4
16	0	0	0	60	8	30	39	1	32	0	0	0	7	2	4
17	0	0	0	93	4	49.5	49	6	30.5	2	0	0.5	9	1	4
18	0	0	0	87	8	49.5	65	5	31.5	1	0	0	8	3	5
19	0	0	0	91	17	53	52	2	22.5	3	0	0.5	9	2	4
20	0	0	0	93	54	76	28	4	14	2	0	1	9	3	5
21	0	0	0	97	14	71	27	1	15	2	0	0	8	2	5
22	0	0	0	96	10	70	28	2	14	3	0	1	13	2	6
23	0	0	0	92	2	70	31	0	12	2	0	0	12	1	6
24	0	0	0	85	0	49	50	0	19.5	1	0	0	11	0	6.5
25	0	0	0	94	8	46	40	1	25	2	0	0	12	2	6
26	0	0	0	95	4	48.5	37	2	22.5	2	0	0	7	2	5
27	0	0	0	92	46	76	24	4	12	1	0	0	7	3	5
28	0	0	0	83	5	54	32	0	17	1	0	0	6	1	4
29	0	0	0	83	21	57	30	3	12	2	0	0	8	1	4
30	0	0	0	82	14	49	34	7	20	1	0	0	5	1	3
31	0	0	0	88	37	69	24	3	13	1	0	0	7	2	4

平成30年度 排ガス中のばい煙濃度等

11月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0	0	0	92	4	48	37	4	23.5	4	0	0	7	1	4
2	0	0	0	78	21	47	38	5	27	0	0	0	7	2	4.5
3	0	0	0	92	17	49.5	38	9	28	3	0	0	8	1	4
4	0	0	0	90	17	55	38	5	25.5	2	0	0	7	2	4.5
5	0	0	0	89	8	50.5	42	0	22	2	0	0	12	1	5
6	0	0	0	90	2	43.5	46	2	26	1	0	0	6	1	4.5
7	0	0	0	85	8	43	48	3	27.5	1	0	0	5	1	3
8	0	0	0	74	7	45	56	7	28	2	0	0	7	2	4.5
9	0	0	0	93	6	49.5	54	0	25	2	0	0	10	2	4
10	0	0	0	87	2	38.5	51	5	32.5	1	0	0	8	1	4
11	0	0	0	91	23	60.5	37	3	20	3	0	0.5	13	4	7
12	0	0	0	90	5	48.5	42	3	25	2	0	0	15	3	7
13	0	0	0	69	0	26.5	46	13	31	0	0	0	10	2	5
14	0	0	0	72	0	32	55	1	33	1	0	0	7	1	4.5
15	0	0	0	94	11	49.5	53	3	26.5	1	0	0	8	3	5
16	0	0	0	82	5	34.5	50	11	33	2	0	0	9	3	4
17	0	0	0	86	9	46.5	38	15	30	3	0	0	12	4	6.5
18	0	0	0	84	9	47.5	37	12	28	3	0	0	14	1	5.5
19	0	0	0	90	0	40	56	5	28	2	0	0	12	1	5.5
20	0	0	0	48	0	17.5	44	0	34.5	0	0	0	6	1	2.5
21	0	0	0	78	0	30	62	12	35.5	1	0	0	8	2	3
22	0	0	0	80	11	39	54	14	36.5	2	0	0	15	2	5
23	0	0	0	82	10	41	56	5	35	1	0	0	19	2	6
24	0	0	0	85	1	33.5	41	1	23	1	0	0	13	1	5
25	0	0	0	87	1	45.5	38	0	26	1	0	0	8	0	5
26	0	0	0	96	3	46	39	1	27	1	0	0	10	2	6
27	0	0	0	66	0	26	43	5	28	0	0	0	9	0	4
28	0	0	0	84	4	35.5	45	8	29.5	1	0	0	6	2	3.5
29	0	0	0	72	0	26.5	45	23	36	0	0	0	10	2	4
30	0	0	0	71	2	29	45	16	36	2	0	0	8	3	5

平成30年度 排ガス中のばい煙濃度等

1月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	0	0	0	85	6	58	35	6	21	2	0	0	5	2	4
6	0	0	0	76	16	53.5	46	22	32.5	0	0	0	6	2	3.5
7	0	0	0	95	29	64.5	49	4	24.5	0	0	0	7	1	4
8	0	0	0	76	2	38.5	62	14	36.5	0	0	0	6	2	3
9	0	0	0	93	38	62	39	9	26	1	0	0	7	2	4
10	0	0	0	86	24	59.5	42	6	28	1	0	0	6	2	3.5
11	0	0	0	82	3	51.5	55	3	32.5	0	0	0	7	1	4.5
12	0	0	0	89	6	61.5	41	6	28.5	1	0	0	8	1	4.5
13	0	0	0	91	3	59.5	42	2	26	0	0	0	9	2	5.5
14	0	0	0	92	36	66	39	11	27	2	0	0	9	3	5.5
15	0	0	0	88	2	61	42	1	23.5	1	0	0	8	1	4
16	0	0	0	90	23	68	40	3	20.5	2	0	0	9	2	5.5
17	0	0	0	83	15	46	55	3	34.5	1	0	0	10	1	3
18	0	0	0	74	6	39	58	4	34.5	1	0	0	6	1	3.5
19	0	0	0	77	14	45.5	49	5	32.5	0	0	0	7	1	3.5
20	0	0	0	83	1	52	52	1	31	1	0	0	9	1	5
21	0	0	0	88	16	60.5	57	3	31.5	0	0	0	6	2	4
22	0	0	0	70	1	39	57	0	33	0	0	0	6	0	3.5
23	0	0	0	92	12	50	57	2	34	2	0	0	9	3	4
24	0	0	0	77	17	43	56	17	42	1	0	0	7	3	5
25	0	0	0	76	20	46.5	65	13	40	1	0	0	7	3	5
26	0	0	0	91	18	52	62	13	41.5	0	0	0	12	4	6
27	0	0	0	91	20	58	62	9	34.5	0	0	0	18	4	6.5
28	0	0	0	89	5	43.5	62	5	37	0	0	0	9	3	5.5
29	0	0	0	64	2	30.5	65	7	44	0	0	0	7	1	4
30	0	0	0	70	12	37.5	64	12	41	2	0	0	11	3	5.5
31	0	0	0	73	16	47	58	19	38	0	0	0	15	4	6.5

平成30年度 排ガス中のばい煙濃度等

3月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	0	0	0	78	14	48	31	7	18	0	0	0	4	0	2
3	0	0	0	63	28	42	36	20	28	0	0	0	7	1	5
4	0.01	0	0.01	59	6	33	35	15	25	0	0	0	6	2	4
5	0.01	0	0	44	4	23	44	21	32	0	0	0	6	2	4
6	0.01	0	0	71	4	42.5	44	1	21	0	0	0	6	0	3
7	0.01	0	0.01	95	5	46.5	46	10	27	0	0	0	17	3	6.5
8	0.01	0	0	86	5	50.5	38	2	23	0	0	0	9	1	5.5
9	0.01	0	0	83	7	37.5	48	10	33	0	0	0	10	3	7
10	0.01	0	0.01	82	20	51	43	9	28	0	0	0	9	4	6
11	0.01	0	0	80	3	44.5	42	3	28.5	0	0	0	10	4	6.5
12	0.01	0	0	59	2	27	41	5	32	0	0	0	8	3	5.5
13	0.01	0	0	75	12	40.5	38	2	26	0	0	0	7	2	4
14	0.01	0	0	75	14	43	46	3	26.5	0	0	0	7	1	3
15	0.01	0	0	82	16	37	45	16	32	0	0	0	5	2	3.5
16	0.01	0	0	73	1	41	45	2	28.5	0	0	0	6	2	4
17	0.01	0	0.01	76	1	39	47	13	31.5	0	0	0	6	2	4.5
18	0.01	0	0.01	63	8	39.5	46	5	28.5	0	0	0	5	1	3
19	0.01	0	0.01	65	2	31	41	6	30.5	0	0	0	6	1	3.5
20	0.01	0	0.01	71	2	32	56	2	29.5	1	0	0	5	1	3
21	0.01	0	0.01	78	16	41.5	37	7	25.5	0	0	0	7	2	4.5
22	0.01	0	0.01	97	10	48.5	40	1	20.5	0	0	0	6	1	3.5
23	0	0	0	77	19	46.5	40	14	29.5	0	0	0	4	2	3
24	0	0	0	78	33	53.5	36	5	27	0	0	0	4	2	3
25	0.01	0	0	66	12	37.5	54	5	34	0	0	0	5	2	3.5
26	0.01	0	0.01	71	6	36	47	8	30.5	0	0	0	6	2	4
27	0.01	0	0	86	3	34	47	0	29.5	1	0	0	5	3	4
28	0.01	0	0	75	13	41.5	48	4	27	0	0	0	7	1	3
29	0.01	0	0	80	6	40	47	5	30	0	0	0	6	1	3
30	0.01	0	0.01	75	0	44.5	45	2	27	0	0	0	4	0	2.5
31	0.01	0	0	96	20	50.5	40	7	28.5	0	0	0	6	2	4