

令和元年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

4月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0	385	8	162	45	5	31	0	0	0	8	2	3.5	278.50	42.50	156.70
2	0.01	0	0	386	18	185.5	48	8	31	0	0	0	7	2	3.5	287.50	107.50	195.10
3	0.01	0	0	386	46	175.5	48	11	30	0	0	0	4	2	2.5	320.00	52.75	168.98
4	0.01	0	0	509	27	230.5	41	4	29	0	0	0	8	3	4.5	386.75	70.00	239.49
5	0.01	0	0.01	467	73	261.5	61	19	32	0	0	0	8	2	4.5	372.00	83.00	252.12
6	0.01	0	0	451	9	221.5	41	0	25.5	0	0	0	8	2	4.5	404.00	88.25	220.79
7	0.01	0	0.01	490	15	240.5	45	13	29.5	0	0	0	8	3	4.5	398.75	131.25	241.79
8	0.01	0	0.01	376	32	169	47	1	29	0	0	0	6	2	3.5	330.25	70.00	171.55
9	0.01	0	0.01	411	0	199.5	44	11	29.5	0	0	0	5	2	3.5	352.00	103.00	208.83
10	0.01	0	0.01	467	69	258.5	43	5	28	0	0	0	5	3	3.5	429.75	130.75	256.93
11	0.01	0	0.01	544	46	213	57	13	33	0	0	0	7	2	4	439.75	87.75	215.62
12	0	0	0	407	37	185	51	17	32	0	0	0	5	1	3	342.00	82.00	178.63
13	0.01	0	0	491	85	332	43	16	26	0	0	0	5	2	3	442.50	228.00	330.67
14	0	0	0	517	82	367	25	6	18	0	0	0	8	2	5	458.75	268.75	358.60
15	0.01	0	0	512	44	282	59	6	26	0	0	0	6	2	3	398.75	106.50	296.03
16	0.01	0	0	450	12	232	68	16	45	0	0	0	3	2	2	370.00	159.00	242.87
17	0.01	0	0	492	87	302	58	7	32	0	0	0	5	3	4	423.25	170.75	304.03
18	0.01	0	0	471	102	311	50	16	33	0	0	0	7	3	4	382.25	188.25	308.85
19	0.01	0	0	470	59	269	62	7	30	0	0	0	9	3	5	371.25	120.25	261.14
20	0.01	0	0	418	185	312	102	17	35	0	0	0	6	3	5	372.25	214.50	301.05
21	0.01	0	0	492	108	306	33	15	24	0	0	0	7	3	5	415.00	195.50	309.51
22	0.01	0	0	424	0	170	42	2	28	0	0	0	6	4	4	312.50	17.25	172.38
23	0.01	0	0	397	0	254	34	12	26	0	0	0	7	4	5	352.25	105.00	257.34
24	0.01	0	0	498	121	327	36	11	22	0	0	0	7	3	5	437.75	190.75	333.79
25	0.01	0	0	433	127	268	40	14	27	0	0	0	8	4	5	337.25	167.25	261.36
26	0.01	0	0	438	59	265	40	10	26	0	0	0	7	3	5	347.25	130.50	263.82
27	0.01	0	0	532	44	341	34	16	23	0	0	0	9	2	5	427.75	174.25	356.82
28	0.01	0	0	391	85	277	40	13	24	0	0	0	7	3	4	358.00	122.50	268.51
29	0.01	0	0	511	102	279	33	12	21	0	0	0	5	3	4	436.50	171.50	284.70
30	0.01	0	0.01	573	55	318.5	33	0	13	1	0	0	5	1	3	464.50	172.75	314.27

令和元年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

5月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0.01	509	0	324	24	0	13.5	0	0	0	5	0	3	414.75	218.50	325.68
2	0.01	0	0.01	375	41	189	72	13	36	0	0	0	9	2	4	363.25	82.00	198.36
3	0.01	0	0.01	272	56	141	34	18	26	0	0	0	5	2	3	233.00	84.00	143.92
4	0.01	0	0.01	273	89	168	33	2	24	0	0	0	7	3	4	220.50	115.00	172.18
5	0.01	0	0.01	372	2	174	34	13	23	0	0	0	5	2	4	240.75	80.00	169.18
6	0.01	0	0.01	236	60	149	34	14	25	0	0	0	5	3	4	221.50	93.75	152.49
7	0.01	0	0.01	349	76	162	33	5	24	0	0	0	6	4	5	224.00	113.25	158.81
8	0.01	0	0.01	494	56	252	30	2	19	5	0	0	10	5	7	413.00	159.75	246.79
9	0.01	0	0.01	367	10	220	35	3	17	1	0	0	13	4	7	336.25	80.75	225.55
10	0.01	0	0.01	341	92	188	32	9	20	0	0	0	11	4	7	251.50	106.75	178.20
11	0.01	0	0.01	344	7	203	33	1	19	0	0	0	11	5	8	291.75	94.00	207.94
12	0.01	0	0	456	0	240	32	0	14	0	0	0	10	0	5	326.25	142.50	227.71
13	0.01	0	0.01	393	85	210	34	2	19	0	0	0	8	2	5	328.50	163.25	224.77
14	0.01	0	0.01	336	9	166	34	4	23	0	0	0	16	2	6	268.50	103.00	172.38
15	0.01	0	0.01	391	166	252	33	1	14	4	0	0	12	2	5	316.00	189.75	244.89
16	0.01	0	0.01	291	37	156	35	6	22	0	0	0	10	3	6	315.25	55.00	167.74
17	0.01	0	0.01	398	105	227	33	1	14	0	0	0	10	4	6	304.00	138.50	227.02
18	0.01	0	0.01	411	122	262	30	2	18	0	0	0	12	3	7	351.25	167.00	246.41
19	0.01	0	0.01	401	40	245.5	33	3	12	0	0	0	12	1	4.5	366.75	238.50	285.26
20	0.01	0	0.01	549	9	264	40	0	20.5	0	0	0	11	1	4	521.50	44.50	269.08
21	0.01	0	0.01	319	55	197	41	5	28.5	0	0	0	6	1	3.5	278.00	104.00	193.99
22	0.01	0	0.01	411	62	236	44	8	27	0	0	0	7	1	4	342.25	98.50	234.23
23	0.01	0	0.01	467	53	219.5	41	3	26	0	0	0	9	2	5.5	345.00	118.00	225.32
24	0.01	0	0.01	401	17	196.5	43	3	28.5	1	0	0	7	1	3.5	317.50	65.00	194.04
25	0.01	0	0.01	457	17	250.5	39	5	25	0	0	0	12	2	6.5	413.00	87.75	247.39
26	0.01	0	0.01	541	64	314	35	4	20	0	0	0	16	4	9.5	425.00	206.00	317.46
27	0.01	0	0.01	407	94	226.5	38	4	22.5	1	0	0	9	0	3.5	355.75	162.25	225.24
28	0.01	0	0.01	405	0	188.5	42	5	25.5	4	0	0	6	1	3	327.00	87.00	194.38
29	0.01	0	0.01	431	77	233.5	39	2	26	0	0	0	6	2	3.5	381.00	100.75	233.61
30	0.01	0	0.01	464	13	236.5	41	4	26.5	0	0	0	9	2	5	391.00	65.75	243.15
31	0.01	0	0.01	410	15	163	69	9	32	0	0	0	7	2	4.5	309.50	28.75	167.98

※ 6月12日の数値について、①は0～11時、②は12～24時の数値です。

令和元年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

6月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0.01	342	9	108	61	10	31	0	0	0	10	2	5	244.50	35.00	97.49
2	0.01	0	0.01	396	42	178.5	39	4	28	0	0	0	16	4	7.5	324.25	64.50	184.47
3	0.01	0	0.01	296	6	81	44	13	33	1	0	0	9	3	5.5	170.00	25.75	88.71
4	0.01	0	0.01	70	0	17	50	0	35	0	0	0	6	0	3	36.25	0.50	19.51
5	0.01	0	0.01	182	0	29.5	60	10	38.5	2	0	0	5	1	3	95.00	2.25	27.95
6	0.01	0	0.01	138	0	35	49	11	33.5	0	0	0	7	2	4	88.75	8.25	34.97
7	0.01	0	0.01	178	0	33.5	55	9	37.5	0	0	0	5	2	3.5	101.00	10.25	34.13
8	0.01	0	0.01	126	0	31	64	8	40	0	0	0	6	2	3.5	84.75	7.75	31.66
9	0.01	0	0.01	154	0	51	62	24	39	0	0	0	8	2	4.5	87.50	15.00	50.27
10	0.01	0	0.01	126	2	56.5	64	18	40	0	0	0	11	2	5.5	96.50	20.00	59.21
11	0.01	0	0.01	98	0	23	63	0	38.5	0	0	0	10	0	2.5	64.00	0.00	23.94
12①	0.01	0	0.01	144	5	41.5	55	20	34.5	2	0	0	5	1	3	70.75	10.25	33.01
12②	0.01	0	0.01	102	3	28	56	9	33.5	1	0	0	5	1	2.5	57.00	23.00	39.11
13	0.01	0	0.01	109	1	36	71	9	34	0	0	0	6	1	3	68.50	7.75	33.74
14	0.01	0	0.01	73	0	19.5	42	0	27	0	0	0	5	0	2	60.25	4.25	24.54
15	0.01	0	0.01	65	0	20	44	1	33	0	0	0	5	0	3	44.25	5.25	20.42
16	0.01	0	0.01	66	0	23.5	54	20	36.5	0	0	0	6	2	3.5	42.00	5.00	23.54
17	0.01	0	0.01	64	0	22	56	0	29.5	1	0	0	4	1	2.5	37.50	5.75	23.26
18	0.01	0	0.01	91	0	24	48	3	31	0	0	0	5	0	3	43.75	0.25	21.93
19	0.01	0	0.01	276	0	27	48	1	28.5	22	0	0.5	5	0	3	80.00	0.00	27.84
20	0.01	0	0.01	99	0	20	39	6	29	0	0	0	4	1	2.5	38.00	1.50	20.07
21	0.01	0	0.01	41	0	9	50	0	29.5	0	0	0	4	0	2	30.25	0.25	11.05
22	0.01	0	0	104	0	31	55	6	30	1	0	0	4	1	2	45.50	7.75	30.96
23	0.01	0	0	87	0	32	46	5	33	0	0	0	5	1	3	60.25	0.25	31.36
24	0.01	0	0	90	0	20	41	9	32	0	0	0	7	1	3	55.00	2.75	21.50
25	0.01	0	0	62	0	9	46	13	34	1	0	0	4	1	2	22.00	0.00	6.93
26	0.01	0	0	51	0	18	51	12	36	1	0	0	4	2	3	30.00	7.00	18.21
27	0.01	0	0	73	0	29	45	10	33	0	0	0	3	1	2	47.25	7.75	29.48
28	0	0	0	39	0	13	50	30	39	0	0	0	4	2	3	23.75	0.25	13.83
29	0	0	0	52	0	15	54	25	39	0	0	0	5	2	3	34.00	1.00	15.55
30	0	0	0	64	0	18	47	1	34	0	0	0	4	1	3	30.75	4.50	17.11

令和元年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

7月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.01	0	0	54	0	27	49	28	36	0	0	0	4	2	3	37.25	13.25	24.84
2	0.44	0	0.14	76	0	24	51	7	35	0	0	0	15	2	3	43.00	6.25	24.58
3	0.49	0.08	0.33	38	0	11	53	3	34	0	0	0	4	1	3	30.25	0.25	12.95
4	0.63	0.09	0.25	80	0	24.5	49	0	20	0	0	0	7	0	2.5	31.00	0.50	20.23
5	0.82	0.05	0.38	67	0	32	45	0	22.5	0	0	0	8	0	3	53.75	1.25	32.60
6	1.14	0	0.41	94	0	24	50	0	27.5	0	0	0	7	0	3.5	61.25	0.25	22.44
7	0.93	0.06	0.46	65	0	17	57	9	37	0	0	0	7	1	4.5	55.25	0.25	17.48
8	1.07	0	0.48	69	0	18	63	0	34.5	0	0	0	11	0	3	52.75	0.00	18.66
9	1.00	0.01	0.46	62	0	12.5	55	4	36	0	0	0	4	0	2	35.50	0.00	13.66
10	0.93	0.03	0.47	81	0	18.5	59	8	35	0	0	0	4	1	2.5	47.25	0.00	18.57
11	0.99	0.08	0.48	52	0	13.5	58	11	38.5	0	0	0	4	1	2.5	37.25	0.75	14.59
12	0.98	0.06	0.49	74	0	11.5	55	8	36.5	0	0	0	6	1	3.5	30.25	0.00	11.49
13	0.85	0.02	0.46	48	0	7	57	2	34.5	0	0	0	6	0	3.5	25.25	0.00	7.42
14	0.85	0	0.42	74	0	18.5	54	1	37	0	0	0	6	0	4	38.25	0.00	17.62
15	0.85	0	0.41	59	0	17	52	4	33.5	0	0	0	9	1	5	39.25	1.25	16.06
16	0.90	0.02	0.41	62	0	17.5	46	0	32	0	0	0	5	0	4	37.25	2.75	17.68
17	0.94	0	0.46	56	0	10.5	67	0	36	0	0	0	6	0	3.5	41.50	0.00	11.43
18	0.97	0.05	0.47	64	0	14.5	49	9	36.5	0	0	0	8	1	4.5	39.50	0.00	13.18
19	0.90	0.03	0.47	64	0	8	47	16	37	0	0	0	6	1	3.5	39.50	0.00	8.11
20	0.99	0	0.44	88	0	11	47	0	31.5	0	0	0	7	0	3.5	29.50	0.00	10.30
21	0.95	0.02	0.44	69	0	22.5	43	3	27.5	0	0	0	8	0	5	42.50	6.25	23.86
22	0.99	0.05	0.49	74	0	10.5	58	20	37.5	0	0	0	6	1	4	40.75	0.25	10.22
23	1.00	0.03	0.46	33	0	3.5	49	1	34.5	0	0	0	5	0	2	13.00	0.00	3.85
24	1.00	0.01	0.49	53	0	11	63	4	36	0	0	0	4	0	2	27.75	0.50	11.21
25	1.00	0.03	0.5	54	0	8.5	43	12	34	0	0	0	3	1	2	27.50	0.00	7.18
26	1.00	0.05	0.47	42	0	7	55	8	35.5	0	0	0	3	0	1.5	16.00	0.50	6.89
27	0.77	0.02	0.3	65	0	3.5	43	0	18.5	0	0	0	3	0	1	20.75	0.25	3.99
28	0.31	0.01	0.17	29	0	6	44	0	21	0	0	0	3	0	2	19.75	0.00	5.88
29	0.45	0.02	0.17	41	0	6	49	1	30	0	0	0	3	0	2	21.50	0.00	5.26
30	1.00	0	0.31	78	0	19.5	42	0	14	28	0	1	3	0	1.5	45.00	0.00	20.54
31	1.00	0.01	0.42	74	0	14	65	0	30.5	0	0	0	5	0	3	39.50	0.00	14.73

令和元年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

8月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	1.00	0.01	0.40	80	0	21.5	42	2	20	0	0	0	6	0	3.5	56.25	0.00	22.75
2	1.00	0.10	0.51	68	0	14.5	42	5	27.5	0	0	0	9	2	3	51.25	0.00	13.67
3	0.96	0.03	0.45	87	0	17.5	42	0	20	0	0	0	6	1	2.5	52.25	0.00	18.40
4	0.85	0.22	0.72	61	5	35	42	9	34	0	0	0	8	1	4	51.00	12.75	33.73
5	0.95	0.30	0.71	71	3	35	44	14	34	0	0	0	5	1	4	50.75	15.75	35.51
6	0.95	0.07	0.70	74	0	28	43	3	34	0	0	0	4	0	3	52.50	11.75	28.82
7	0.90	0.15	0.76	75	0	22	44	4	37	0	0	0	9	1	4	48.00	0.00	23.57
8	0.95	0.2	0.67	51	0	24	47	9	33	0	0	0	5	1	3	42.75	3.25	22.57
9	0.90	0.32	0.76	78	0	25	63	12	38	0	0	0	4	1	3	65.00	0.00	23.89
10	0.95	0.16	0.66	76	3	31	41	7	32	0	0	0	5	0	2	54.00	7.00	29.67
11	0.85	0.08	0.52	58	1	31	42	3	25	0	0	0	6	0	2	55.00	13.50	32.16
12	0.87	0.12	0.47	82	10	41	41	5	22	0	0	0	5	0	2	55.00	23.50	40.15
13	0.96	0	0.38	76	0	22	45	1	30	0	0	0	6	0	2	43.25	9.00	24.68
14	0.97	0.04	0.42	66	0	28	51	4	32.5	0	0	0	4	0	2.5	57.00	11.75	28.35
15	1.01	0.08	0.43	86	0	26	55	12	34.5	0	0	0	4	1	3	47.00	1.75	26.98
16	1.02	0.08	0.48	74	0	26.5	59	14	42.5	0	0	0	6	1	3	52.75	7.25	26.61
17	0.95	0.01	0.4	90	0	22.5	50	1	34.5	0	0	0	6	0	2.5	57.50	0.25	21.44
18	0.93	0.05	0.41	73	0	26	56	11	36.5	0	0	0	6	1	2.5	58.75	1.25	26.71
19	0.95	0.05	0.38	72	0	13.5	57	3	37	0	0	0	5	0	2	48.00	0.00	14.79
20	1.00	0.05	0.46	50	0	9	61	5	44	0	0	0	18	1	4	37.25	0.00	7.62
21	0.98	0.04	0.47	77	0	21.5	50	3	37.5	0	0	0	23	1	5.5	46.50	0.00	21.09
22	0.95	0.07	0.48	90	0	20	56	9	41.5	0	0	0	4	0	2	44.75	0.00	20.52
23	0.97	0.08	0.48	82	0	20	66	7	45.5	0	0	0	6	0	3	62.50	0.25	19.87
24	0.85	0.10	0.46	78	0	15.5	58	15	43	0	0	0	5	1	2.5	35.50	0.00	15.59
25	0.84	0	0.39	52	0	17	64	4	38.5	0	0	0	5	0	2	39.25	0.00	18.41
26	0.90	0.05	0.45	63	0	16.5	54	30	44	0	0	0	4	1	2.5	39.75	0.25	16.18
27	0.85	0.03	0.47	65	0	21.5	58	2	41	0	0	0	5	0	2.5	45.75	0.50	21.77
28	0.90	0.05	0.39	74	0	19	66	5	38.5	0	0	0	4	0	2	47.00	2.00	19.87
29	0.96	0.04	0.43	83	0	19	59	2	37	0	0	0	4	0	2.5	53.25	0.00	18.46
30	0.90	0.08	0.48	73	0	15.5	57	4	33	0	0	0	5	0	3	50.25	0.00	15.93
31	0.89	0.07	0.43	62	0	24	54	5	34.5	0	0	0	5	1	2.5	59.00	0.00	24.10

令和元年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

9月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.85	0.02	0.39	75	0	20	59	1	32	1	0	0	5	0	2.5	43.25	0.50	21.40
2	0.94	0.05	0.45	86	0	24	53	12	38	0	0	0	5	1	3	53.75	0.00	23.29
3	0.90	0.03	0.44	48	0	14.5	63	3	38.5	0	0	0	3	0	2	34.25	0.25	15.69
4	0.95	0	0.50	59	0	12.5	59	2	37	2	0	0	4	0	2.5	42.00	0.25	12.69
5	0.95	0.10	0.49	68	0	16.5	46	10	33.5	3	0	0	4	1	2.5	52.75	0.25	16.57
6	0.89	0.08	0.51	49	0	15.5	54	11	32	1	0	0	4	1	3	28.25	0.00	14.68
7	0.45	0.05	0.28	54	0	11	42	3	32	0	0	0	3	0	3	36.00	0.00	12.02
8	0.40	0.11	0.24	81	0	14	56	12	28	0	0	0	4	2	3	23.50	0.00	13.24
9	0.47	0.15	0.29	94	0	18	55	17	36	0	0	0	5	2	3	49.25	0.00	17.55
10	0.46	0	0.21	45	0	11	64	0	38	0	0	0	4	0	3	26.75	0.00	11.88
11	0.38	0.04	0.24	53	0	12	59	7	36	0	0	0	5	1	4	30.25	2.50	12.06
12	0.55	0.15	0.29	35	0	7	46	16	26	0	0	0	5	3	4	16.00	0.00	5.64
13	0.51	0.01	0.33	70	0	13	43	0	27	0	0	0	4	0	3	39.75	1.75	14.31
14	0.39	0.10	0.22	14	0	3	59	12	32	0	0	0	5	2	3	8.25	0.00	3.34
15	0.84	0.02	0.29	72	0	25	42	1	20.5	0	0	0	9	0	4	52.75	0.00	24.59
16	0.95	0.01	0.37	79	0	23	40	0	24.5	0	0	0	7	0	3	53.25	0.00	23.78
17	0.94	0.01	0.47	58	0	11	45	0	33	0	0	0	6	0	3	40.75	0.00	11.39
18	0.86	0	0.45	72	0	23	62	0	32	0	0	0	5	0	2	53.50	0.00	20.33
19	0.80	0.01	0.39	84	0	15	50	0	27.5	0	0	0	6	0	2.5	51.25	3.50	17.47
20	0.70	0.02	0.40	74	0	15	55	0	34	0	0	0	3	0	2	44.00	1.75	12.21
21	0.78	0.02	0.43	78	0	20.5	49	5	34	0	0	0	5	0	3	61.25	0.50	20.73
22	0.88	0.07	0.36	52	0	19.5	47	2	26.5	0	0	0	5	0	2.5	42.25	0.25	20.84
23	0.93	0.05	0.45	39	0	9.5	45	1	32	0	0	0	4	0	3	35.50	0.50	10.50
24	0.81	0.09	0.40	56	0	8.5	47	1	30.5	0	0	0	4	0	2.5	37.50	0.00	9.53
25	0.77	0	0.44	69	0	18.5	60	0	31	0	0	0	6	0	3	48.25	0.50	17.87
26	0.87	0.04	0.41	80	0	22.5	51	4	30.5	0	0	0	9	1	4.5	54.75	1.25	23.50
27	0.90	0.10	0.49	48	0	10	63	0	36.5	0	0	0	5	1	3.5	27.00	0.00	9.13
28	0.70	0.19	0.61	58	0	15	61	4	37	0	0	0	5	1	3	42.00	5.25	17.07
29	0.80	0.01	0.58	41	0	14	43	0	31	0	0	0	4	0	3	25.25	0.75	14.46
30	0.72	0.40	0.61	16	0	3	44	23	37	0	0	0	5	2	3	12.00	0.25	3.92