

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	972	970	976	972	971	961	961	975	979									1001	997	980	989	1043	993	982	
	2号炉																							1193	1240	立ち上げ～定常運転
2	1号炉	956	957	958	952	948	947	956	953	964	971	991	992	958	958	962	960	985	969	979	963	978	964	963	965	
	2号炉	976	962	994	971	970	964	968	970	976	969	955	964	962	966	967	972	964	973	975	961	993	969	975	955	
3	1号炉	969	966	956	956	965	942	955	946	956	982	916	975	1017	993	974	1024	1084	960	924	953	961	986	978	1005	
	2号炉	957	978	979	986	966	947	958	949	993	949	945	937	933	925	919	934	896	922	910	914	917	924	925	959	
4	1号炉	965	961	959	958	856	931	960	967	961	965	966	966	965	968	944	962	947	970	958	957	982	946	961	976	
	2号炉	954	950	944	943	954	920	941	945	992	971	943	982	998	940	952	945	950	955	955	959	980	972	954	949	
5	1号炉	1014	1025	1008	995	987	976	977	988	988	997	1025	957	987	1004	1028	1013	982	1015	988	991	962	959	947	931	
	2号炉	954	964	963	953	953	956	952	960	959	966	961	955	976	980	998	1013	1010	950	1000	977	971	984	973	956	
6	1号炉	944	1003	981	975	972	989	940	835	868				936	977	955	963	961	961	979	967	963	976	947	963	
	2号炉	953	977	1004	968	968	975	965	976	980	1006	972	1000	1007	1016	996	973	961	966	966	958	964	967	964	988	
7	1号炉	964	953	965	959	954	954	967	972	981	977	984	971	966	964	966	942	953	968	970	969	965	992	961	958	
	2号炉	982	952	956	960	966	960	961	962	909			954	947	951	954	959	958	965	959	945	971	955	961	960	
8	1号炉	960	967	977	976	971	965	959	984	959	956	969	955	966	971	968	987	1006	984	998	989	981	963	925	941	
	2号炉	968	971	965	967	965	961	959	972	950	932	971	953	972	966	958	952	962	959	969	960	967	966	957	963	
9	1号炉	934	959	934	952	949	964	976	957	967	980	987	966	954	970	961	939		765	942	951	944	958	953	960	15:58～17:42給じん停止
	2号炉	957	962	952	965	959	960	962	952	960	979	998	980	986	989	955	958	976	965	968	971	956	965	954	965	
10	1号炉	961	971	971	964	969	962	980	871	984	973	993	993	999	965	1034	1032	1031	1014	986	963	965	964	1002	882	
	2号炉	951	955	960	953	961	980	953	954	968	963	968	958	980	980	995	987	1025	976	963	978	965	958	956	969	
11	1号炉	968	1010	992	987	970	981	970	961	918	968	964	954	972	972	952	971	997	960	968	957	947	950	962	953	
	2号炉	966	973	969	971	972	959	971	962	960	982	975	980	964	965	975	987	1012	974	959	956	962	965	981	986	
12	1号炉	869	951	1047	989	972	979	975	958	990	976	985	974	972	1002	1014	992	963	962	970	965	986	959	947	994	
	2号炉	998	990	972	936	961	980	987	1024	1017	975	974	979	976	1019	986	1013	981	956	962	967	965	976	969	961	
13	1号炉	952	971	961	967	959	970	977	962	949	961	991	993	968	993	984	1000	963	983	1006	979	1009	967	941	956	
	2号炉	977	992	982	975	968	964	966	968	967	967	981	979	1019	973	1008	957	949	968	976	961	968	958	968	968	
14	1号炉	890	883	933	970	962	955	955	906	952	969	965	947	976	975	1013	993	983	961	969	966	957	959	953	967	
	2号炉	968	966	962	959	957	968	972	964	936			939	960	954	949	954	955	955	955	958	958	961	958	961	
15	1号炉	965	959	959	959	960	954	967	971	903	764	967	977	965	896	926		927	972	964	933	956	976	972	964	8:35～9:28給じん停止
	2号炉	965	985	949	930	939	956	957	954	958	961	973	989	977	963	974	969	979	971	961	961	947	963	969	941	

4月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	997	967	660	944	1022	926	936	889	972	908	945	966	972	975	993	964	932	988	898	949	937	929	958	954	14:48～2:48給じん停止
	2号炉	958	967	980	964	962	960	962	950	940	949	949	966	953	966	968	964	968	968	958	961	960	964	964	965	
17	1号炉	835	958	955	948	957	958	963	953	949	958	967	973	970	949	969	669	876	881	866	842	889	932	952	915	15:02～15:49給じん停止
	2号炉	957	962	954	957	961	961	966	929	965	956	967	961	962	937	945	943	938	924	933	959	953	962	929	945	
18	1号炉	946	913	953	962	961	959	969	977	900	886	940	969	954	961	952	963	974	967	964	967	969	959	964	969	
	2号炉	977	957	958	956	965	962	957	965	965	986		1080	967	982	988	963	964	974	961	967	967	959	975	966	
19	1号炉	949	960	1018	980	981	981	942	963	965	953	961	968	960	952	969	964	965	967	962	970	966	993	929	931	
	2号炉	969	963	970	961	971	966	968	967	955	883	944	1005	964	962	955	976	946	963	996	959	947	970	966	961	
20	1号炉	966	971	966	965	969	970	977	964	968	977	980	962	965	967	959	959	975	921		926	961	950	939	960	
	2号炉	972	949	948	947	958	959	958	944	949	964	941	948	956	963	943	950	961	957	956	935	936	943	948	962	
21	1号炉	964	948	954	949	960	955	948	945	959	967	970	970	970	834	961	970	970	963	960	956	961	965	918	841	
	2号炉	962	957	953	944	959	955	975	955	883			962	919	959	969	937	944	959	861	922	963	931	923	956	
22	1号炉	943	960	969	916	961	963	942	950	961	938	960	960	966	963	968	962	933	960	960	963	953	947	944	945	
	2号炉	967	933	974	963	944	956	977	972	958	969	995	991	967	963	968	964	965	964	950	939	951	960	952	941	
23	1号炉	955	920	962	940	961	955	920	945	920	972			921	952	952	956	954	956	944	935	949	929	936	939	
	2号炉	944	954	966	973	959	923	986	974	955	979	962	933	930												定常運転～立ち下げ
24	1号炉	946	922	945	945	957	950	953	955	958	932	958	931	949	946	916	968	933	947	934	939	943	960	916	944	
	2号炉																									休炉
25	1号炉	942	938	950	959	949	965	933	955	952	888	888	957	965	971	956	965	938	966	962	968	962	961	954	944	
	2号炉																									休炉
26	1号炉	936	950	948	955	960	961	922	796	957	967	967	971	971	964	963	964	962	971	965	958	960	963	952	964	6:45～7:30給じん停止
	2号炉																									休炉
27	1号炉	955	956	946	962	965	955	819	943	963	983	944	957	961	899	943		548	962	913	956	930	951	654	666	14:36～16:55給じん停止 22:10～23:47給じん停止
	2号炉																									休炉
28	1号炉	938	913	974	945	959	962	969	939	903	866	957	980	973	972	971	975	988	1002	951	975	956	952	953	966	
	2号炉										904	917	942	944	972	958	939	950	941	940	948	946	936	947	924	立ち上げ～定常運転
29	1号炉	957	953	959	977	970	963	971	978	977	971	913	978	969	961	971	988	965	985	899	953	952	997	768	944	22:10～23:00給じん停止
	2号炉	939	950	965	970	954	969	947	944	942	951	939	954	940	975	961	969	955	950	943	964	951	953	941	963	
30	1号炉	944	979	962	970	952	971	971	962	966	981	960	979	969	967	972	937	955	923	740	917	963	965	961	967	17:46～18:35給じん停止
	2号炉	983	974	949	960	957	962	955	948	967	956	966	980	971	967	967	956	962	953	948	949	955	971	987	978	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	970	965	954	954	961	941	957	944	958	967	966	894	960	970	977	902	935	959	959	974	962	955	957	956	
	2号炉	1008	941	946	953	955	951	958	963	951	954	1002	1024	1035	993	1007	1011	1039	974	962	952		889	871	883	
2	1号炉	955	953	948	954	960	951	964	949	889	956	952	962	958	959	962	968	971	956	889	889	949	951	944	945	
	2号炉	955	960	945	959	1013	972	969	954	966	960	964	962	944	951	964	980	972	986	982	989	977	969	941	957	
3	1号炉	956	958	964	971	904	953	999	977	954	944	956	949	955	959	951	956	964	957	955	955	951	967	962	950	
	2号炉	993	977	1007	997	1006	1048	1084	1102	1125	1189	1134	946	957	975	996	970	985	954	955	966	959	955	949	946	
4	1号炉	950	960	958	977	969	957	957	951	948	972	961	911	962	934	952	960	972	954	955	965	917	955	958	960	
	2号炉	952	950	957	954	975	983	975	958	975	994	978	967	964	965	964	964	966	966	955	968	945	956	960	960	
5	1号炉	965	971	965	949	963	959	960	957	965	968	958	966	968	968	967	964	965	969	971	969	969	972	968	969	
	2号炉	954	963	976	960	952	961	961	968	968	957	961	964	968	974	964	957	986	968	968	967	963	955	960	962	
6	1号炉	960	984	981	971	973	957	961	963	968	971	968	964	963	973	957	959	950	960	959	956	952	951	944	937	
	2号炉	963	964	967	963	976	993	973	991	982	1004	1008	1008	1010	989	982	982	973	962	968	962	954	955	961	972	
7	1号炉	949	948	959	953																					定常運転～立ち下げ
	2号炉	958	963	941	931	959	973	963	971	974	973	961	961	960	956	971	964	988	955	927	962	925	957	957	977	
8	1号炉																									休炉
	2号炉	955	930	947	947	943	931	938	975	959	955	955	966	959	950	954	969	968	936	879	958	896	941	932	935	
9	1号炉																									休炉
	2号炉	961	941	942	948	956	948	925	955	945	989	1007	975	992	975	945	932	959	970	904	910	886	945	921	936	
10	1号炉																									休炉
	2号炉	951	947	968	969	961	951	945	953	952	977	984	953	958	961	963	958	961	951	965	944	969	957	951	989	
11	1号炉																									休炉
	2号炉	937	954	951	954	960	957	957	960	956	952	941	878	918	984	960	964	990	958	944	938	924	945	941	941	
12	1号炉																									休炉
	2号炉	938	945	949	951	934	948	944	951	893	702	977	1012	1028	998	1011	1001	999	988			942	898	877	950	8:34～9:35給じん停止
13	1号炉																									休炉
	2号炉	942	907	963	964	962	963	967	961	959	963	955	974	1039	1043	1000	979	963	993	959	945	942	953	941	939	
14	1号炉																									休炉
	2号炉	946	947	957	952	946	942	927	970	972	970	985	973	980	984	988	983	1036	982	965	949	937	956	955	931	
15	1号炉																									休炉
	2号炉	937	961	979	983	985	967	956	938	937	978	1045	992	976	974	1047	1010	1038	983	1001	971	974	955	953	962	



燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	888	948	952	943	941	944	930	927	957	959	941	915	945	962	967	960	963	965	982	978	950	924	920	955	
	2号炉																									休炉
2	1号炉	978	949	934	937	925	949	934	940	864	862	913	947	965	935	945	942	938	927		932	935	940	933	931	
	2号炉																									休炉
3	1号炉	937	936	932	950	944	936	921	923	936	931	933	973	962	957	983	989	971	983	986	937	926	943	940	950	
	2号炉																									休炉
4	1号炉	946	942	957	926	907	940	948	952	963	1002	1015	967	962	924	916	944	947	952	953	946	934	919	925	931	
	2号炉																									休炉
5	1号炉	934	928	937	836	920	928	965	935	940	922	935	951	921	918	922	931	983	939	949	919	917	922	921	936	
	2号炉																									休炉
6	1号炉	923	971	944	944	924	932	917	935	941	951	924	925	908	953	965	925	944	945	922	925	915	910	923	928	
	2号炉										881	850	887	912	927	940	931	925	938	917	899	941	942	970		立上げ～定常運転
7	1号炉	929	930	958	967	937	946	917	947	979	956	970	958	977	957	906	909	909	911	912	918	906	941	939	923	
	2号炉	930	923	942	989	955	927	946	943	935	969	943	960	947	931	952	944	919	966	962	971	970	970	967	968	
8	1号炉	915	903	907	897	893	897	892	875	876	893	906	895	908	932	922	937	945	899	901	905	942	933	965	947	
	2号炉	956	964	967	962	958	948	924	956	950	936	942	965	967	968	964	965	997	960	959	959	972	963	952	957	
9	1号炉	924	941	928	984	947	979	961	966	950				1008	953	1040	1050	909								
	2号炉	960	963	956	959	946	946	944	964	967	958	959	962	967	971	970	965	973								
10	1号炉																								913	
	2号炉																						966	991	939	
11	1号炉	935	952	957	945	929	949	957	958	956	940	934	953	967	933	947	944	1019	878	949	952	959	980	965	955	
	2号炉	901	969	980	988	977	860	912	963	989	989	994	993	985	954	976	982	991	962	931	961	982	967	993	990	
12	1号炉	959	958	956	960	964	963	957	964	987	1046	965	981	1002	1051	1043	1058	941	953	980	976	968	953	916	985	
	2号炉	992	979	968	976	980	963	981	967	983	955	964	962	960	970	956	961	958	975	954	976	992	969	953	973	
13	1号炉	978	1002	981	959	961	955	975	960	970	972	960	962	959	976	967	960	978	988	964	972	968	1014	952	959	
	2号炉	973	953	968	974	977	957	961	956	933	913	839				882	978	985	966	987	999	982	1014	957	964	
14	1号炉	965	997	1029	1000	954	951	961	962	975	967	953	948	968	974	978	964	972	997	980	975	982	982	995	960	
	2号炉	949	971	966	987	990	987	968	964	940	941	997	985	963	995	997	1009	987	973	985	994	980	974	968	969	
15	1号炉	971	965	961	971	979	984	973	974	944	951	945	981	1007	1027	968	959	978	987	968	953	949	982	974	960	
	2号炉	982	963	965	985	977	973	970	952	968	966	960	975	973	970	967	973	975	977	974	973	978	981	965	970	

6月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	951	1003	974	975	983	1031	945	996	988	1002	975	961	953	926		935	961	949	956	960	967	982	989	985	
	2号炉	977	980	974	947	836	931	915	958	880			965	956	975	980	963	964	975	972	983	982	988	971	967	
17	1号炉	1000	965	974	980	931	953	976	976	967	963	985	980	961	960	994	1002	998	980	969	969	952	956	950	950	
	2号炉	982	934	969	988	977	989	973	979	991	977	978	959	1005	978	990	961	984	969	964	978	968	964	965	974	
18	1号炉	958	1009	1001	1022	986	980	975	984	913			1077	954	977	1008	954	900	1033	957	910	860	932	858	873	
	2号炉	972	969	963	958	977	974	987	979	976	988	972	972	968	1008	977	970	1001	952	960	932		904	986	992	
19	1号炉	956	998	1009		866	945	956	959	956	957	972	938	954	954	960	960	1003	1006	898	960	954	1022	985	967	
	2号炉	975	984	1002	963	981	973	960	955	976	980	971	962	960	968	975	977	970	964	987	975	972	988	978	971	
20	1号炉	968	984	977	970	961	956	958	952	956	958	974	939	954	965	955	976	969	987	966	966	960	972	950	958	
	2号炉	958	985	985	973	976	984	991	979	969	996	992	980	978	985	977	995	960	960	990	989	983	973	954	947	
21	1号炉	939	956	952	954	948	957	948	940	969	979	1009	990	1014	982	984	977	957	956	946	958	983	972	971	1055	
	2号炉	958	972	991	973	965	964	985	966	961	917	932	983	976	951	947	962	983	952	955	957	931	946	953	964	
22	1号炉	1010	943	936	959	954	953	960	960	951	1022	1018	1038	964	970	973	960	969	946	938	972	947	959	987	986	
	2号炉	977	952	949	954	948	953	955	953	943	977	977	1000	975	936	931	940	943	932	934	946	935	932	931	948	
23	1号炉	989	956	962	943	946	944	945	937	916	904	935	943	986	992	972	950	960	941	949	945	937	940	946	950	
	2号炉	934	937	927	919	918	922	910	921	850				926	967	996	978	948	834							8:34~12:33給じん停止 定常運転~立ち下げ
24	1号炉	943	937	949	959	948	943	932	925	956	953	997	994	1006	1006	919	874	904	875	946	954	941	919	966	964	
	2号炉																									休炉
25	1号炉	973	960	941	951	945	949	944	960	958	939	937	826	688	926	924	938	965	921	945	949	939	920	923	961	11:30~12:50給じん停止
	2号炉																									休炉
26	1号炉	949	928	941	950	948	943	961	937	942	948	958	947	966	957	959	977	968	959	954	941	939	939	956	945	
	2号炉											977	939	933	930	968	960	918	931	988	973	964	954	961	957	立上げ~定常運転
27	1号炉	948	932	952	925	933	969	941	927	927	935	940	943	956	969	962	960	916	929	926	942	944	956	959	961	
	2号炉	968	932	961	981	979	971	892	874	864	955	969	969	987	987	985	977	939	865	945	980	961	988	976	979	
28	1号炉	943	957	975	963	939	933	921	926	927	947	970	945	940	977	991	966	981	955	940	924	924	945	940	925	
	2号炉	974	876	941	964	963	974	968	982	974	945	884	942	930	955	930	953	984	972	967	946	990	977	970	948	
29	1号炉	929	934	959	944	947	935	952	937	937	934	933	915	944	966	966	942	953	948	933	909	950	933	948	948	
	2号炉	844	968	967	981	976	963	971	979	967	885	965	959	993	990	987	936	973	933	966	1017	1004	978	986	894	
30	1号炉	965	946	942	943	931	915	914	894	937	962	963	959	939	931	934	951	940	930	924	921	937	932	921	922	
	2号炉	942	983	996	970	956	997	895		843			926	968	976	964	968	965	985	962	968	976	982	971	993	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	915	922	929	920	923	930	932	929	920	924	938	939	1001	987	956	983	957	932	912	927	938	928	923	910	
	2号炉	966	971	968	961	964	952	959	996	935	975	982	963	983	980	960	979	980	958	918	965	934	956	969	963	
2	1号炉	913	931	920	931	924	933	913	942	927	932	937	933	892	896	921	928	932	907	903	911	914	890	903	914	
	2号炉	965	974	961	958	966	951	963	967	967	971	971	964	939	948	973	949	940	953	956	958	954	946	944	955	
3	1号炉	816	904	904	903	915	912	919	898	891	726															9:36給じん停止 定常運転～立ち下げ
	2号炉	958	968	950	951	963	946	959	960	961	961	962	969	990	978	952	1007	1012	978	940	952	984	947	954	963	
4	1号炉																									休炉
	2号炉	945	956	984	961	971	952	954	943	959	968	956	951	952	950	959	956	946	967	966	956	955	948	973	966	
5	1号炉																									休炉
	2号炉	962	982		808	997	976	957	1002	924	980	962	971	967	977	990	869	966	968	973	971	958	956	776	857	22:02～23:43給じん停止
6	1号炉																									休炉
	2号炉	967	970	978	973	934	819	938	961	985	963	966	957	934	983	951	960	961	957	932	956	945	957	962	961	
7	1号炉																									休炉
	2号炉	966	970	970	956	966	955	996	954	934	725	959	971	970	966	965	965	966	965	957	950	957			1043	8:45～9:38給じん停止
8	1号炉																									休炉
	2号炉	957	976	975	978	984	998	992	996	989	974	982	1003	991	967	974	965	964	980	966	971	963	969	970	967	
9	1号炉																									休炉
	2号炉	952	967	973	952	989	958	958	947	959	976	988	970	977	967	958	972	962	976	954	967	988	966	973	950	
10	1号炉																									休炉
	2号炉	957	958	961	967	959	969	955	957	950	976	956	945	911	977	964	960	950	960	963	951	955	944	959	963	
11	1号炉																									休炉
	2号炉	929	956	968	964	958	961	964	965	953	956	965	965	957	964	945	963	966	971	968	970	971	958	951	969	
12	1号炉																									休炉
	2号炉	967	968	968	966	965	967	963	964	965	937	978	957	973	954	952	949	979	961	971	970	969	963	973	981	
13	1号炉																									休炉
	2号炉	966	963	965	965	950	949	963	949	958	958	950	960	968	988	959	953	962	975	957	945	941	934	953	946	
14	1号炉																									休炉
	2号炉	939	944	950	943	952	949	951	941	885			985	863	943	964	958	965	953	957	951	951	953	962	957	
15	1号炉																									休炉
	2号炉	957	930	962	964	947	967	955	963	951	949	960	950	948	957	972	948	945	931	928	952	959	944	941	957	

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉																									休炉
	2号炉	957	954	947	971	935	959	968	995	960	974	967	971	975	983	978	985	953	960	956	943	951	963	966	955	
17	1号炉																									休炉
	2号炉	967	965	965	950	963	967	987	977	965	964	961	963	966	965	960	966	931	961	956	973	967	955	948	960	
18	1号炉																880	964	969	945	956	955	922	950	立上げ～定常運転	
	2号炉	951	954	924	960	949	964	961	953	959	970	958	965	953	964	943	963	951	964	959	959	960	964	957	961	
19	1号炉	944	962	882	942	944	921	934	941	902	925	872	869	827	796	930	936	922	930	935	960	940	914	927	931	12:38～13:49給じん停止
	2号炉	969	964	970	973	963	977	960	962	965	968	948	954	969	946	953	961	934	948	948	958	961	949	959	934	
20	1号炉	934	927	883	920	926	915	945	942	938	903	930	935	946	964	941	911	907	874	919	931	951	945	948	976	
	2号炉	951	953	960	957	952	943	949	945	958	933	945	954	959	952	936	927	932	971	931	943	866		911	955	
21	1号炉	959	935	908	901	901	919	920	917	925	931	922	927	915	916	926	912	917	914	929	923	937	956	901	937	
	2号炉	981	948	948	952	928	975	964	953	823			968	944	970	962	963	965	976	959	983	975	976	945	974	
22	1号炉	924	906	899	931	913	911	906	904	920	936	933	956	937	920	914	917	792	1028	1028	1021	1028	1012	1036	1018	15:52～16:31給じん停止
	2号炉	970	956	960	964	940	951	942	952	952	961	969	967	957	972	956	944	970	943	955	912	960	965	969	907	
23	1号炉	1043	1018	1018	1036	1035	1009	1024	1024	1020	1038	1085	1088	1065	1080	1073	1059	1044	1054	1053	1054	1062	1048	1051	1047	
	2号炉	951	957	941	962	943	950	938	955	950	944	954	931	971	962	928	950	932	930	943	950	934	955	964	980	
24	1号炉	948	976	956	962	963	952	940	957	967	977	965	949	955	960	947	954	909	955	960	953	968	916	884	965	
	2号炉	955	975	954	951	962	946	952	954	942	964	957	979	964	978	975	998	964	959	949	933	941	947	939	936	
25	1号炉	957	919	914	905	954	976	891	903	957	957	950	929	939	949	950	942	936	870		927	941	957	931	935	
	2号炉	952	938	937	917	947	955	815	834	952	955	946	960	951	937	949	936	939	929	946	937	947	948	895	950	
26	1号炉	945	910	893	936	916	946	891	923	949	942	941	933	929	950	938	937	893	938	943	929	941	963	978	952	
	2号炉	943	935	912	926	948	929	942	944	840	961	981	925	952	975	953	1002	923	964	959	980		923	982	988	
27	1号炉	971	969	947	926	942	950	956	949	934	950	900	930	951	952	961	968	966	959	946	924	915	930	909	943	
	2号炉	966	965	960	970	961	972	956	957	960	974	963	948	960	957	958	960	963	962	953	932	947	937	942	950	
28	1号炉	910	886	932	942	929	878	946	893	846			917	927	913	918	940	944	949	925	929	935	903	920	928	
	2号炉	954	946	937	952	879	953	962	931	939	957	918	940	934	957	963	965	942	957	954	952	969	913	925	951	
29	1号炉	921	908	930	917	925	914	906	933	920	916	921	938	934	905	922	920	921	916	908	907	896	895	898	897	
	2号炉	947	921	950	950	937	954	973	889	951		946	960	956	964	958	958	961	966	944	931	936	943	953	936	
30	1号炉	899	910	906	923	903	872	899	908	916	927	940	906	936	921	912	912	886	913	920	947	919	917	924	917	
	2号炉	944	942	949	937	944	943	956	935	940	941	953	934	946	953	946	957	941	928	948	934	937	930	937	926	
31	1号炉	918	892	885	899	891	906	906	885	953	966	961	969	982	947	954	972	1009	949	940	961	958	973	963	955	
	2号炉	850		898	935	939	920	956	951	882																0:36～2:01給じん停止 定常運転～立ち下げ



燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	870	961	963	948	970	956	949	951	952	950	977	943	966	959	957	953	931	943	981	956	999	986	962	959	
	2号炉																									休炉
2	1号炉	954	965	956	963	975	954	944	950	956	937	923	948	1,004	1,003	951	957	924	940	966	974	980	966	960	912	
	2号炉																									休炉
3	1号炉	922	962	969	971	948	957	963	978	982	959	967	929	955	972	968	965	884	913		937	972	967	956	973	
	2号炉																									休炉
4	1号炉	986	967	953	977	970	982	978	967	955	952	960	961	995	1,006	1,004	990	1,004	978	946	952	980	970	949	957	
	2号炉																									休炉
5	1号炉	956	955	971	961	953	980	996	1,003	898	835	989	1,002	877	897	917	945	971	971	968	942	934	966	960	984	
	2号炉																									休炉
6	1号炉	951	948	955	967	951	948	949	932	943	981	965	974	963	952	949	961	977	960	964	960	965	951	965	993	
	2号炉																									休炉
7	1号炉	983	969	962	956	957	960	967	979	985	987	983	976	964	980	969	968	971	962	969	968	967	959	958	958	
	2号炉																									休炉
8	1号炉	965	950	951	948	957	941	924	937	930	944	961			549	963	969	968	950	962	958	951	957	957	947	10:50~13:56給じん停止
	2号炉																									休炉
9	1号炉	955	902	952	969	954	983	974	983	982	964	948	976	962	969	967	996	968	966	961	972	967	954	970	956	
	2号炉																									休炉
10	1号炉	943	959	962	907	840	988	940	915	960	979	979	962	971	944	967	977	976	971	928	982	987	1,032	928	983	
	2号炉																									休炉
11	1号炉	992	975	988	991	962	957	963	972	950	826	963	966	995	988	989	965	1,003	937		931	925	970	1,009	966	
	2号炉																									休炉
12	1号炉	966	958	982	967	958	957	952	957	966	980	997	993	1,048	1,034	1,048	1,017	987	956	957	973	957	968	945	965	
	2号炉																									休炉
13	1号炉	981	961	950	978	958	983	960	956	970	966	972	967	961	969	968	975	960	962	953	955	956	980	973	965	
	2号炉															918	876				925	948	974	962	942	立上げ~定常運転 15:19~19:04給じん停止
14	1号炉	971	954	945	962	965	950	970	951	949	990	995	939	958	952	957	960	956	946	958	939	969	982	969	972	
	2号炉	937	932	940	932	940	944	937	948	950	945	961	939	947	942	941	947	946	931	937	933	942	937	941	938	
15	1号炉	957	984	980	943	942	951	958	966	921	965	970	980	961	954	963	958	968	967	962	937	963	952	932	958	
	2号炉	950	932	933	934	924	942	935	926	947	948	951	955	925	936	933	947	944	928	929	940	941	937	938	925	

8月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	备	考
16	1号炉	956	963	964	952	958	951	960	963	979	980	961	973	939	979	954	973	915	874	934	986	979	946	917	962		
	2号炉	929	933	924	941	924	927	919	915	939	947	936	950	937	944	939	950	948	930	925	935	935	918	927	936		
17	1号炉	978	966	956	959	965	955	898	936	948			974	945	979	966	938	959	953	954	946	949	924	930	961		
	2号炉	929	925	918	925	923	927	927	915	917	945	950	930	928	919	926	913	922	934	925	919	911	921	923	928		
18	1号炉	955	962	937	948	952	962	966	918	912	952	957	972	959	950	954	957	946	963	939	972	955	959	946	957		
	2号炉	940	935	920	912	924	924	926	939	912	941	935	931	948	945	925	943	937	937	929	924	928	930	924	927		
19	1号炉	956	956	956	947	961	980	954	967	949	959	959	933	884	960	960	954	958	955	962	956	958	949	957	946		
	2号炉	926	932	937	924	929	907	941	932	924	932	940	963	869	904	925	948	942	931	919	920	923	916	920	935		
20	1号炉	932	930	956	931	956	965	953	956	962	973	959	947	952	954	966	950	945	939	927	937	922	954	932	946		
	2号炉	938	935	947	953	942	926	932	938	940	968	958	953	946	958	955	970	967	962	878	917	945	944	941	949		
21	1号炉	948	942	943	953	946	941	930	934	938	949	950	966	964	951	955	967	958	955	923	948	948	937	946	979		
	2号炉	954	946	930	935	926	933	936	913	929	946	951	926	917	926	930	924	908	912	882	918	876		882	918		
22	1号炉	956	950	943	949	941	956	945	950	942	953	959	965	958	953	967	961	956	959	949	958	951	948	960	948		
	2号炉	915	918	909	910	928		1,007	915	916	938	926	922	925	911	909	900	902	910	902	938	952	929	942	952		
23	1号炉	960	924	937	947	944	947	947	950	941	958	957	957	950	948	937	933	942	935	930	951	947	972	922	934		
	2号炉	926	944	944	930	935	921	929	924	916	922	957	934	917	932	942	940	936	906	943	952	964	986	1,018	987		
24	1号炉	950	960	958	943	954	948	943	942	956	970	944	956	956	979	939	973	951	969	965	949	968	931	945	966		
	2号炉	963	946	941	928	908	895	925	878	964	934	955	958	1,000	957	953	941	947	1,009	956	957	981	958	967	971		
25	1号炉	959	952	955	948	952	953	951	935	890					952	952	956	956	946	934	933	923	955	975	956		
	2号炉	955	945	937	952	952	948	941	940	939	953	951	953	954	947	947	945	947	950	944	939	939	951	949	943		
26	1号炉	935	959	965	944	965	931	926	940	924	962	955	963	961	956	968	964	954	955	937	881	897	962	978	971		
	2号炉	931	923		868	899	862	912	945	853				1,043	947	956	952	951	941	966	951	931	949	951	954		
27	1号炉	969	965	925	964	916	956	964	956	936	969	972	960	967	952	960	956	948	955	932	953	963	950	946	956		
	2号炉	946	941	917	933	954	949	945	923	935	950	947	944	951	924	933	949	960	940	934	940	941	945	945	954		
28	1号炉	962	951	948	939	919	933	950	962	990	971	967	980	947	959	959	959	951	922	923	933	952	949	957	952		
	2号炉	944	926	902	931	958	903	937	929	917	947	944	949	927	913	944	950	945	942	949	945	942	948	959	950		
29	1号炉	939	943	955	940	953	950	939	946	945	942	944	952	963	967	952	953	919	930	955	945	951	951	941	933		
	2号炉	930	921	940	949	935	936	946	952	954	937	956	933	932	926	961	932	948	954	959	960	956	931	936	941		
30	1号炉	958	961	974	975	944	921	933	956	979	944	959	984	978	979	934	959	935	942	950	940	931	945	942	962		
	2号炉	939	944	925	936	924	953	954	929	945	979	923	928	907	908	939	940	942	947	956	940	939	954	948	949		
31	1号炉	970	953	957	950	948	959	950	946	945	965	944	940	936	931	959	965	960	931	933	951	962	954	943	948		
	2号炉	948	961	950	934	936	934	936	926	934	948	937	945	932	944	933	934	939	944	936	933	943	936	951	948		



9月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	977	961	944	941	958	953	963	975	968	968	968	969	962	985	969	987	1001	1011	1000	985	972	971	1003	1005	
	2号炉																									
17	1号炉	981	958	950	952	958	945	946	956	940	966	989	961	958	960	964	921	950	961	981	955	969	970	924	971	
	2号炉																									
18	1号炉	967	984	998	985	930	941	980	981	951	961	957	968	998	966	960	976	966	973	981	956	963	950	956	971	
	2号炉																									
19	1号炉	977	976	958	969	976	967	959	977	1000	977	956	968	979	995	963	955	950	971	963	960	972	957	977	996	
	2号炉									927	936	970	939	946	936	954	969	935	952	948	959	959	952	952	958	立上げ～定常運転
20	1号炉	969	958	961	968	932	966	974	1001	945	961	973	958	972	974	974	989	968	965	950	956	963	965	968	972	
	2号炉	934	941	964	948	956	951	939	966	978	961	967	951	944	995	959	921	934	957	956	953	950	946	965	957	
21	1号炉	949	957	974	970	972	908	860	887	931	975	949	965	949	973	965	970	969	980	964	893	936	912	1057	943	
	2号炉	915	932	964	949	1005	919	913	994	963	969	876	958	965	936	947	951	937	945	927	937	925	957	990	919	
22	1号炉	951	985	975	906	960	972	961	953	825			973	949	963	956	964	968	940	948	966	947	954	939	941	
	2号炉	894	957	951	942	952	963	954	950	953	917	954	968	925	957	938	906	936	938	940	952	936	911	840	947	
23	1号炉	932	938	938	940	934	924	927	941	944	937	960	950	960	966	961	934	952	953	909	940	923	915	928	949	
	2号炉	902	923	945	947	947	900	897	939	923			890	925	956	948	942	938	939	925	931	922	917	919	943	
24	1号炉	911	886	911	933	912	918	911	916	917	910	907	903	928	912	934	904	925	957	923	912	913	934	903	883	
	2号炉	932	918	921	929	933	921	931	922	901	908	915	914	929	932	932	935	927	922	918	900	930	908	940	898	
25	1号炉	890	905	919	901	917	886	911	935	933	969	962	960	978	977	957	944	958	981	969	961	957	1002	971	986	
	2号炉	909	905	919	914	910	918	938	952	963	958	964	966	957	958	947	989	946	966	950	958	956	954	957	956	
26	1号炉	968	971	980	965	952	932	972	967	965	1000	984	961	960	983	958	969	959	939	977	972	962	976	969	972	
	2号炉	942	935	934	937	934	963	951	952	950	947	964	971	965	964	956	964	960	936	939	959	942	937	947	950	
27	1号炉	964	988	957	1008	953	967	957	968	965	948	951	970	966	962	957	957	964	973	975	993	963	956	954	962	
	2号炉	962	936	948	929	941	922	962	973	917	945	942	943	957	943	890	940	954	950	936	941	954	951	935	942	
28	1号炉	958	990	976	971	961	957	950	974	932	973	954	965	965	980	974	940	956	956	963	967	948	960	954	960	
	2号炉	941	951	958	927	956	906	911	918	927	941	937	950	948	944	941	929	922	938	938	932	913	931	932	937	
29	1号炉	957	957	962	963	954	972	987	981	939	997	982	1003	956	969	973	972	962	957	965	972	927	964	965	963	
	2号炉	938	929	896	927	922	941	945	918	850				927	914	915	929	930	938	919	924	909	920	911	952	
30	1号炉	970	969	974	968	963	988	963	956	918				939	954	970	961	975	912	959	948	946	960	952	952	
	2号炉	962	928	912	968	973	957	963	956	957	967	950	951	957	964	953	958	958	963	918	952	954	942	955	950	