

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

10月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	941	947	946	954	958	964	940	961	949	977	964	968	940	939	964	1000	963	953	938	919	865	844	818	964	
	2号炉	949	945	941	961	958	946	958	952	943	951	963	955	974	950	956	949	954	938	955	956	923	938	935	962	
2	1号炉	973	954	974	943	973	946	956	849	913	964	961	959	946	957	956	951	950	945	955	961	961	985	961	952	
	2号炉	953	956	950	960	958	947	931		851	998	961	950	944	954	947	952	951	938	941	939	960	944	959	957	
3	1号炉	935	934	922	935	904	953	942	944	939	941	945	951	934	951	960	942	928	932	937	939	941	949	964	961	
	2号炉	960	946	949	950	960	942	948	931	945	950	963	933	928	939	936	948	949	952	959	950	942	952	950	941	
4	1号炉	929	949	970	964	971	964	944	961	962	961	958	952	955	957	971	956	952	968	976	999	956	970	943	974	
	2号炉	944	939	969	946	950	956	965	960	953	958	949	955	947	947	950	942	957	967	960	962	956	963	959	963	
5	1号炉	989	970	958	969	980	950	956	962	977	960	951	984	1008	984	991	989	987	994	1028	984	966	1005	960	840	
	2号炉	958	963	959	944	963	962	944	936	948	948	931	976	949	947	948	952	949	950	950	952	935	947	949	941	
6	1号炉	890	957	959	959	970	952	955	951	955	950	962	979	1003	973	975	995	1003	1028	988	974	974	973	996	1000	
	2号炉	929	946	947	954	950	947	938	927	851				888	972	694			766	949	953	937	949	943	956	14:09~17:51給じん停止
7	1号炉	994	970	941	974	980	968	954	959	863			953	975	957	962	967	973	958	986	948	970	977	943	939	
	2号炉	941	950	937	883	915	947	945	948	949	946	948	952	944	939	941	952	934	945	930	920	938	919	922	929	
8	1号炉	926	937	937	958	957	943	973	970	973	975	955	961	956	963	957	958	967	969	944	984	954	961	943	972	
	2号炉	947	935	944	935	937	937	944	938	935	926	925	933	934	924	931	946	936	942	935	946	928	922	928	929	
9	1号炉	965	976	973	969	918	961	956	957	972	961	962	968	960	974	948	952	960	954	956	957	969	980	957	967	
	2号炉	926	946	948	914	934	936	936	925	941	946	944	943	938	945	930	924	937	930	930	934	925	934	940	933	
10	1号炉	954	964	968	948	959	960	962	956	960	957	977	955	959	973	958	966	980	967	988	955	947	993	970	966	
	2号炉	931	930	928	922	913	926	917	914	929	908	919	915	926	933	918	915	924	921	929	931	922	932	926	921	
11	1号炉	973	987	985	981	965	970	955	958	976	959	982	984	972	972	973	932	946	957	956	972	959	981	963	975	
	2号炉	915	905	927	923	912	899	919	921	908	914	922	921	924	928	901	906	915	917	924	929	915	906	914	920	
12	1号炉	954	957	1018	1016	986	965	983	956	966	954	972	988	979	1000	973	961	956	956	943	949	963	945	956	897	
	2号炉	935	901	903	913	916	908	918	906	908	935	918	916	913	931	926	916	919	912	918	912	911	919	892	897	
13	1号炉	922	950	956	993	972	982	993	963	960	979	988	994	955	968	901	905	970	988	971	961	959	972	918		
	2号炉	907	904	884	916	898	904	915	901	841					945	951	969	966	942	934	928	933	936	936	953	
14	1号炉				777	736	759	709																		前日~3:28給じん停止 3:48~4:50給じん停止 5:05~5:54給じん停止 定常運転6:09~立ち下げ
	2号炉	935	933	942	934	931	934	940	943	936	953	948	938	943	943	953	946	945	931	917	926	923	928	929	922	
15	1号炉																									休炉
	2号炉	918	931	911	910	949	955	970	965	963	964	983	947	961	973	969	976	967	954	957	936	953	930	942	912	



燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉																									休炉
2	1号炉																									休炉
	2号炉																									休炉
3	1号炉																									休炉
	2号炉																									休炉
4	1号炉																									休炉
	2号炉		962	944	968	942	946	921	918	954	946	962	949	956	914		846	970	944	961	967	964	967	942	938	立上げ～定常運転
5	1号炉																									休炉
	2号炉	961	964	958	954	970	968	968	967	960	965	963	962	967	979	969	964	699		932	964	969	960	946	948	16:10～18:02給じん停止
6	1号炉																									休炉
	2号炉	956	949	960	965	968	973	972	972	967	963	964	964	953	963	969	959	964	961	969	967	960	951	964	974	
7	1号炉																									休炉
	2号炉	966	953	968	961	966	970	961	970	968	993	978	965	982	976	984	1003	1006	1002	987	984	980	976	975	981	
8	1号炉																									休炉
	2号炉	976	977	990	983	980	978	977	984	977	947	948	945	948	977	973	962	959	959	946	969	964	968	968	967	
9	1号炉																									休炉
	2号炉	967	961	967	978	978	980	967	974	970	942	951	954	942	937	948	950	953	951	961	972	970	951	945	944	
10	1号炉																									休炉
	2号炉	940	960	966	965	954	959	967	970	964	975	957	969	956	939	952	971	951	948	943	962	960	953	955	949	
11	1号炉																									休炉
	2号炉	945	974	967	971	945	954	937	935	933	966	951	934	931	954	935	952	938	949	948	949	952	933	945	947	
12	1号炉																									休炉
	2号炉	950	943	931	952	953	960	928	967	895		924	947	939	926	932	935	950	916	939	936	941	946	938	942	
13	1号炉																									休炉
	2号炉	942	932	922	948	966	977	950	944	938	948	958	971	953	947	956	952	957	946	940	941	948	933	957	956	
14	1号炉																									休炉
	2号炉	949	934	952	940	942	933	950	945	938	956	952	943	951	956	950	967	965	945	938	955	946	953	957	958	
15	1号炉																									休炉
	2号炉	958	958	951	957	937	933	943	970	945	962	963	974	962	949	960	963	943	935	951	960	960	970	956	931	

11月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉																										休炉
	2号炉	950	938	941	942	949	954	950	938	958	942	947	949	951	943	953	945	947	945	953	950	957	954	963	966		
17	1号炉								910	981	1008	988	908	957	964	965	932	968	951	954	949	956	953	947	949		立上げ～定常運転
	2号炉	965	959	952	949	950	953	953	952	946	933	925	934	965	956	951	953	940	957	959	950	939	953	949	939		
18	1号炉	968	948	956	951	940	966	964	973	933	982	937	925	905	944	938	923	923	953	951	953	978	941	948	941		
	2号炉	946	956	911	952	934	940	930	918	931	850		919	837	900	971	951	967	945	970	970	948	984	959	987		
19	1号炉	942	952	963	948	948	958	953	952	950	953	944	944	949	953	928	930	952	951	949	965	962	956	964	962		
	2号炉	977	951	957	974	978	950	939	952	948	947	942	950	956	949	955	949	947	949	944	941	944	953	956	965		
20	1号炉	967	957	941	948	958	942	936	951	940	948	928	932	947	948	949	954	953	947	958	953	959	948	942	949		
	2号炉	957	974	981	962	948	947	964	956	961	951	956	942	935	949	964	913	950	955	946	944	955	952	948	942		
21	1号炉	936	948	936	940	941	946	965	955	964	959	963	971	954	960	963	963	961	970	960	966	963	965	963	970		
	2号炉	921	934	937	945	947	941	953	946	949	937	952	948	945	945	941	950	944	951	955	964	959	937	958	962		
22	1号炉	965	956	970	968	972	969	970	966	972	963	965	960	973	972	976	974	975	960	958	971	963	951	981	960		
	2号炉	949	936	937	942	959	945	955	930	935	950	943	949	946	940	948	951	942	943	953	962	957	942	957	945		
23	1号炉	969	956	961	964	961	959	970	959	961	966	955	912	951	967	974	973	956	956	950	961	951	964	957	940		
	2号炉	948	973	962	945	935	938	939	946	947	944	947	959	942	946	948	949	942	937	941	940	940	941	935	936		
24	1号炉	962	967	964	969	953	955	970	966	893		970	956	963	952	953	953	930	949	940	948	950	944	963			
	2号炉	941	953	945	940	940	965	942	956	951	950	939	943	941	937	934	941	942	935	931	941	939	940	933	930		
25	1号炉	912	968	968	956	946	948	965	956	956	944	945	939	936	933	928	933	928	938	935	934	936	919	914	943		
	2号炉	929	941	934	930	931	934	927	922	867		899	933	946	926	930	933	931	933	944	944	939	927	946	946		
26	1号炉	938	928	1007	950	909	943	952	955	943	949	946	955	946	940	983	945	939	939	934	946	931	952	953	962		
	2号炉	936	931	954	938	905	931	937	938	931	933	948	953	931	933	930	932	940	930	735						18:01～翌日 給じん停止	
27	1号炉	954	897	954	952	952	959	941	966	941	950	952	959	953	948	967	945	926	926	930	951	943	920	949	953		
	2号炉		792	907	947	924	920	917	945	969	964	962	974	973	972	975	984	958	944	953	949	952	956	949	975	前日～1:34 給じん停止	
28	1号炉	949	956	937	947	965	949	943	956	940	950	954	938	953	958	943	937	953	957	947	937	947	954	948	953		
	2号炉	954	953	950	955	943	948	961	962	957	952	962	960	965	963	964	966	959	955	949	950	955	955	959	969		
29	1号炉	962	958	953	965	948	963	956	972	942	943	930	947	949	960	948	962	951	953	950	960	941	940	924	938		
	2号炉	966	962	940	956	946	954	945	957	951	963	947	966	928	947	942	941	951	947	938	933	949	948	959	956		
30	1号炉	948	944	945	946	952	948	923	965	942	963	957	960	970	950	949	936	957	935	954	939	935	941	956	953		
	2号炉	951	934	950	925	919	912	906	909	905	909	913	917	897	890	891	920	942	940	938	936	926	926	920	919		

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和2年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	939	950	940	924	940	937	943	948	873				872	993	947	943	942	978	953	941	942	965	947		
	2号炉	925	920	914	905	901	910	907	897	889	899	914	878	966	943	957	961	963	969	963	956	948	950	954	966	
2	1号炉	935	959	947	941	944	932	938	929	939	908		830	941	946	954	934	941	928	947	942	938	927	936	953	
	2号炉	958	942	960	957	955	941	965	952	864				938	958	980	974	965	977	969	969	955	948	947	943	
3	1号炉	969	923	938	966	945	930	935	960	950	948	948	946	937	954	959	943	963	945	950	940	932	943	927	943	
	2号炉	950	957	932	952	948	954	954	945	947	952	963	955	952	926	942	960	973	940	937	944	937	952	965	955	
4	1号炉	946	940	930	953	953	956	946	921	942	951	952	929	949	948	951	928	949	928	942	937	933	940	969	948	
	2号炉	962	955	965	972	973	958	957	948	959	973	959	953	961	945	951	952	955	958	963	961	958	954	946	973	
5	1号炉	952	938	925	946	926	931	963	937	945	956	957	919	937	939	918	920	935	924	942	946	941	951	947	952	
	2号炉	969	964	958	955	938	948	999	969	957	950	954	957	946	953	975	960	956	954	949	951	952	951	956	953	
6	1号炉	954	938	926	928	902	924	918	936	942	940	930	927	940	914	912	932	950	946	948	939	927	928	935	922	
	2号炉	953	960	959	965	948	953	965	974	967	972	972	959	958	973	983	974	967	955	977	1000	937	937	954	962	
7	1号炉	919	940	922	939	924	920	936	943	932	910	907	904	939	921	917	924	917	904	911	901	908	924	893	921	
	2号炉	964	961	948	951	956	957	966	956	964	954	955	964	972	970	960	961	957	959	951	962	975	952	952	959	
8	1号炉	908	912	944	905	957	965	953	958	863			949	942	969	970	962	963	945	900	975	959	923	922	964	
	2号炉	964	943	955	945	944	942	960	965	954	952	958	968	971	952	951	959	955	955	958	947	955	941	909	944	
9	1号炉	964	969	967	951	962	948	952	959	951	959	954	964	963	961	952	966	962	930	943	951	952	961	961	956	
	2号炉	962	959	957	968	950	961	923	948	853									871	969	970	960	949	957	939	955
10	1号炉	953	963	956	950	953	952	939	943	938	966	954	952	956	975	985	970	925	937	957	952	953	958	949	951	
	2号炉	951	940	942	941	953	946	964	954	957	949	953	948	956	953	948	953	955	959	958	959	953	959	950	959	
11	1号炉	944	962	959	959	952	964	963	926	941	960	950	937	899	938	959	920	941	959	963	931	966	949	955	960	
	2号炉	955	948	951	957	954	1010	984	975	980	963	970	985	990	988	987	970	971	978	964	956	959	958	956	957	
12	1号炉	957	920	921	961	952	921	936	927	941	892	858	984	964	951	963	950	919	963	960	956	959	961	966	972	
	2号炉	960	946	940	964	949	961	959	971	952	967	969	985	966	961	967	968	961	973	973	969	970	972	975	965	
13	1号炉	960	967	964	967	959	950	962	940	950	954	978	956	967	946	953	948	937	924	932	958	947	959	957	956	
	2号炉	962	973	970	971	999	948	958	981	960	997	968	965	952	965	971	976	970	981	1000	972	977	1000	986	971	
14	1号炉	956	917	919	949	959	946	939	938	936	950	964	933	929	923	961	965	955	912	940	937	951	948	930	953	
	2号炉	965	977	995	977	969	974	982	982	996	1002	986	981	983	987	976	964	978	970	969	956	955	958	969	967	
15	1号炉	931	911	915	944	941	941	860	926	850				907	968	976	970	940	969	975	902	835	829	907	939	
	2号炉	963	965	964	977	946	944	969	950	949	940	966	986	962	941	950	952	952	946	946	945	960	936	966	971	

12月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備	考
16	1号炉	951	973	930	965	958	947	958	947	944	954	958	973	972	1030	1044	964	995	973	977	973	961	952	987	959		
	2号炉	962	962	961	954	990	969	981	971	904			942	945	952	944	948	950	957	958	960	938	943	948	927		
17	1号炉	981	956	968	962	949	967	951	986	933	922	953	956	906	898	967	971	946	939	943	902	946	958	943	953		
	2号炉	928	930	942	962	951	932	950	952	939	943	934	942	907	939	943	966	918	944	943	917		869	933	950		
18	1号炉	972	970	962	954	959	955	962	961	947	949	945	979	964	951	945	993	948	921	935	960	956	938	851	913		
	2号炉	954	966	959	955	944	931	931	950	948	944	907	893	952	924	935	950	937	933	947	956	951	895	870	931		
19	1号炉	947	946	946	954	969	964	984	926				875	965	975	991	995	987	928	966	977	977	980	942	978		
	2号炉	921	928	947	946	944	928	946	939	952	982	977	970	959	961	949	964	964	948	958	968	959	955	949	966		
20	1号炉	949	979	967	968	961	969	967	992	972	956	967	930	960	962	968	954	977	956	965	958	945	977	978	973		
	2号炉	950	944	953	965	953	943	958	975	957	968	961	952	946	956	966	959	960	947	942	963	951	952	935	935		
21	1号炉	957	978	967	955	982	968	953	968	967	948	949	963	952	956	962	966	949	962	939	971	953	947	936	969		
	2号炉	950	941	932	932	931	941	946	967	954	964	962	952	957	961	961	962	957	951	946	950	954	957	957	954		
22	1号炉	950	967	972	979	948	955	962	959	938	944	964	956	946	962	1023	938	974	954	946	960	953	945	945	973		
	2号炉	956	924	942	955	936	941		925	866			940	924	930	927	930	930	884	833	947	959	942	947	949		
23	1号炉	937	926	914	961	937	924	918	937	824			934	958	921	924	929	937	933	942	928	961	928	954	953		
	2号炉	932	926	928	922	920	942	917	929	947	939	949	929	952	936	938	938	939	950	950	940	936	931	945	953		
24	1号炉	963	921	954	909	927	940	931	897	923	948	945	919	962	932	939	943	953	934	939	943	947	958	944	959		
	2号炉	948	947	961	937	939	915		910	928	923	955	944	926	934	934	930	936	939	935	936	944	926	935	947		
25	1号炉	964	941	952	938	951	964	938	946	951	939	957	948	942	939	944	953	952	963	961	937	955	951	948	969		
	2号炉	934	931	942	941	933	946	959	952	952	945	955	952	942	950	946	956	954	957	959	934	939	957	955	952		
26	1号炉	958	931	912	953	963	958	954	947	943	964	978	961	961	960	957	943	933	946	939	949	971	946	936	946		
	2号炉	949	942	940	943	943	944	932	946	932	938	950	945	950	960	934	937	939	947	931	923	932	944	948	956		
27	1号炉	938	938	954	949	947	951	940	942	953	926	970	941	953	941	937	944	968	931	940	944	939	932	962	950		
	2号炉		877	952	952	938	948	936	930	947	953	948	935	943	924	936	943	947	957	958	962	939	931	945	939		
28	1号炉	951	946	948	949	959	953	946	953	871						924	981	956	943	940	944	938	950	968	967		
	2号炉	939	954	887	926	940	948	939	941	943	946	947	939	948	842			943	901	849	897	952	936	947	950		
29	1号炉	976	955	968	950	928	961	962	957	958	949	963	933	968	964	940	947	956	942	935	936	961	942	988	961		
	2号炉	952	959	958	960	972	959	950	948	952	951	946	946	954	968	997	994	994	943	954	960	965	977	969	965		
30	1号炉	923	954	988	962	959	966	975	952	960	963	988	1001	973	950	967	961	975	958	970	986	901	976	989	977		
	2号炉	896			961	961	967	949	940	942	969	957	1005	972	948	967	957	946	930	965	957	954	861	846	937		
31	1号炉	966	874	945	977	962	952	982	970	930	973	978	915	961	969	943	950	952	906	954	946	967	921	931	952		
	2号炉	925	845	965	940	949	959	935	940	958	937	948	950	945	966	989	948	961	952	945	942	952	949	938	921		



1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉	925	941	927	931	935	933	948	928	939	938	931	939	950	951	940	950	923	957	948	956	935	950	952	885	
	2号炉																									休炉
17	1号炉	952	943	948	941	933	937	957	944	941	929	937	901	914	936	919	938	930	945	939	948	934	943	955		
	2号炉																									休炉
18	1号炉		840	914	960	940	919	936	940	939	936	935	933	944	891		606	912	941	926	936	918	928	919	927	13:04~15:58給じん停止
	2号炉																									休炉
19	1号炉	939	912	940	932	926	938	906	925	923	907	941	930	928	933	935	914	922	895	900	914	885	900	830		
	2号炉																									休炉
20	1号炉	823	895	911	885	889	916	920	925	924	917			958	934	731										定常運転~立ち下げ(15:11~)
	2号炉																									休炉
21	1号炉																									休炉
	2号炉									925	907	914	917	927	918	919	921	931	942	940	914	930	930	934		立上げ~定常運転
22	1号炉																									休炉
	2号炉	935	934	939	931	922	935	941	959	975	947	929	929	961	952	946	956	963	956	949	938	931	944	934	938	
23	1号炉																									休炉
	2号炉	932	922	950	956	972	970	969	960	953	960	967	961	945	954	979	961	958	952	953	937	950	930	935	925	
24	1号炉																									休炉
	2号炉	933	948	957	951	948	946	945	955	961	971	955	964	960	961	972	964	956	935	949	959	963	943	928	931	
25	1号炉																									休炉
	2号炉	949	973	967	972	955	960	959	968	962	936	943	957	955	945	938	927	925	934	949	936	944	956	937	950	
26	1号炉																									休炉
	2号炉	946	955	948	922	946	929	950	950	956	943	949	923	922	938	934	922	932	929	949	967	949	949	940	934	
27	1号炉																									休炉
	2号炉	950	955	952	945	929	938	949	960	988	929	919	943	948	954	947	962	959	970	952	955	954	962	957	981	
28	1号炉																									休炉
	2号炉	946	940	916	911	926	969	947	935	881		908	923	929	931	919	923	919	934	963		933	928	926	935	
29	1号炉																									休炉
	2号炉	948	923	898	924	930	943	918	915	928	922	919	925	949	950	933	927	929	921	929	926	923	911	931	913	
30	1号炉																									休炉
	2号炉	906	910	922	920	901	920	939	907	906	903	909	910	909	923	904	916	919	943	928	933	913	943	954	929	
31	1号炉																									休炉
	2号炉	943	914	925	936	976	928	930	940	944	934	936	916	936	931	926	903	840	904	942	957	922	930	929	912	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和3年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	913	907	910	914	933	942	926	904	916	924	922	901	919	912	926	915	907	907	946	928	930	929	912	906	
2	1号炉																									休炉
	2号炉	912	904	898	905	911	898	890	924	906	896	903	921	924	931	925	936	915	899	925	914	898	934	907	923	
3	1号炉																									休炉
	2号炉	901	903	950	951	940	943	948	957	956	954	958	957	999	973	963	985	968	955	953	951	949	967	962	946	
4	1号炉																									休炉
	2号炉	949	959	961	981	969	952	950	956	860				951	968	959	956	961	955	947	946	965	979	950	969	
5	1号炉																									休炉
	2号炉	964	953	955	952	949	955	949	958	950	935	951	956	939	949	937	950	946	954	978	980	960	959	956	949	
6	1号炉																									休炉
	2号炉	954	960	968	967	971	973		938	965	964	965	978	962	973	961	963	968	971	970	959	918	976	1010	969	
7	1号炉																									休炉
	2号炉	961	964	964	961	958	954	951	954	954	973	1006	999	872	979	994	976	976	971	993	979	976	989	970	969	
8	1号炉																									休炉
	2号炉	968	974	972	965	972	989	974	1010	969	949	947	965	970	974	974	969	964	953	966	954	956	972	968		
9	1号炉																									休炉
	2号炉	924	946	940	947	952	965	963	960	948	951	959	963	941	944	947	933	941	952	964	962	962	954	951	963	
10	1号炉																									休炉
	2号炉	962	972	865	960	961	954	955	947	953	959	961	957	979	974	955	942	944	958	968	962	986	971	941	955	
11	1号炉																									休炉
	2号炉	963	969	947	951	939	949	949	964	943	944	952	950	973	964	949	954	950	975	961	960	962	953	908	954	
12	1号炉																									休炉
	2号炉	973	968	964	966	959	967	963	961	922			969	949	951	939	950	951	967	961	974	959	971	978	983	
13	1号炉																	994	977	990	968	973	961	961	987	立上げ～定常運転
	2号炉	924	957	953	948	957	948	963	954	967	965	946	970	958	956	952	954	961	954	977	950	973	967	972	973	
14	1号炉	959	988	946	986	956	972	965	971	1014	988	983	987	984	975	960	996	999	974	987	984	980	989	990	991	
	2号炉	969	978	972	973	965	962	958	961	959	974	963	956	957	963	967	959	975	962	974	978	975	977	980	973	
15	1号炉	990	978	976	973	996	956	970	959	948	952	966	960	948	933	969	957	960	966	955	950	967	972	969	972	
	2号炉	967	972	964	981	967	965	976	973	891			957	956	953	942	936	940	979	957	950	953	953	937	934	

2月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	964	996	987	964	961	969	962	979	973	990	970	961	959	958	955	968	962	975	968	977	980	977	971	970	
	2号炉	946	957	956	934	964	952	960	950	966	966	952	956	931	944	937	942	937	960	969	970	951	952	961	966	
17	1号炉	985	976	974	977	983	963	937	993	963	950	959	948	968	960	971	969	971	968	930	982	970	971	976	971	
	2号炉	967	972	972	969	985	968	976	964	961	960	963	949	962	968	972	981	969	965	932	946	961	971	964	958	
18	1号炉	954	971	968	991	978	971	974	968	969	960	968	961	966	961	996	986	967	966	958	970	976	965	959	966	
	2号炉	950	950	959	957	961	951	962	966	970	945	961	963	945	928	934	939	936	949	966	959	964	963	975	974	
19	1号炉	956	969	971	973	971	984	952	970	971	950	947	957	969	983	982	965	973	972	965	975	976	957	977	975	
	2号炉	964	971	975	953	932	955	960	949	862								921	963	919	946	957	945	945	950	
20	1号炉	964	964	966	979	980	970	979	993	975	966	1005	984	966	988	973	963	986	969	991	982	979	979	971	969	
	2号炉	946	941	934	938	933	931	932	934	936	942	956	954	957	932	940	943	955	954	948	966	936	956	950	947	
21	1号炉	973	970	964	972	976	988	973	961	966	976	973	967	988	976	965	1004	977	986	965	1001	979	983	978	998	
	2号炉	943	944	951	947	943	975		950	949	938	949	952	967	959	963	975	960	962	958	955	952	951	949	948	
22	1号炉	981	997	1000	1009	990	981	1014	995	937				973	956	969	965	975	971	965	965	967	968	981	957	
	2号炉	954	951	974	965	956	952	954	940	950	957	943	957	960	710		936	946	957	944	951	948	952	949	954	13:16~15:41給じん停止
23	1号炉	976	958	971	957	991	983	946	998	962	962	967	959	964	971	970	965	969	966	975	985	971	980	985	963	
	2号炉	951	939	935	942	948	932	941	935	941	939	949	948	935	927	954	942	933	946	943	932	954	958	947	943	
24	1号炉	989	978	970	973	968	978	978	971	968	958	962	959	947	954	965	971	975	966	972	978	975	965	972	992	
	2号炉	945	943	940	947	948	939	951	930	945	947	946	940	951	942	945	953	949	946	942	940	927	941	941	939	
25	1号炉	980	989	982	970	968	991	979	990	958	964	958	965	971	977	960	961	966	968	944	919	906	961	971	980	
	2号炉	929	919	936	951	937	946	947	937	838			968	946	944	939	943	953	944	945	955	942	938	911	897	
26	1号炉	989	962	985	964	962	989	974	976	971	962	971	979	977	953	978	978	962	968	970	959	962	964	959	973	
	2号炉	942	935	958	933	950	932	948	941	958	970	955	951	959	943	932	929	925	935	938	927	934	931	934	941	
27	1号炉	958	967	966	979	964	962	965	969	959	966	970	962	968	978	963	956	964	971	987	985	974	960	981	962	
	2号炉	932	935	930	933	940	931	951	935	929	929	927	938	936	943	923	938	928	930	917	923	917	931	930	921	
28	1号炉	989	958	980	968	968	983	973	964	974	973	979	986	972	982	990	968	982	957	975	967	991	971	979	966	
	2号炉	924	933	930	931	919	935	930	923	928	927	929	933	949	938	934	941	966	941	950	933	949	944	940	943	



3月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	955	971	944	892	957	964	975	965	853	756	943	963	964	976	969	952	949	936			959	961	947	948	8:35～9:43給じん停止
	2号炉																									
17	1号炉	947	971	973	960	959	972	993	966	975	942	953	957	968	1001	993	1032	990	943	972	938	989	955	1002	988	
	2号炉																									
18	1号炉	967	979	961	953	978	960	964	958	965	940	938	935	948	953	948	973	974	966	986	999	960	930	953	957	
	2号炉																									
19	1号炉	959		982	982	968	974	986	975	971	964	951	974	988	948	959	1000	982	962	983	961	961	954	985	993	熱電対不良のため 2時台計測不能
	2号炉																									
20	1号炉	944	990	985	1016	1000	977	977	982	909									943	976	993	978	983	986	988	
	2号炉																					997	989	978	962	1003
21	1号炉	987	996	985	978	970	976	955	961	962	1012	1000	1027	984	968	964	971	967	987	972	985	966	979	966	972	
	2号炉	983	987	995	975	963	976	963	952	953	977	961	969	964	957	961	969	961	960	980	969	961	970	970	965	
22	1号炉	979	959	960	955	956	961	995	971	970	989	975	967	993	970	965	964	973	984	977	984	970	976	959	976	
	2号炉	954	947	955	950	944	941	936	957	950	940	944	935	941	944	954	940	945	951	968	966	953	963	951	944	
23	1号炉	971	962	960	973	962	966	953	973	857					706	989	987	979	972	996	987	985	1016	999	982	8:33～13:45給じん停止
	2号炉	949	954	970	968	970	959	961	960	966	972	972	959	957	956	951	957	953	953	977	957	956	955	966	951	
24	1号炉	981	961	961	979	965	987	978	993	960	941	964	955	962	962	967	957	968	974	971	973	968	966	990	975	
	2号炉	961	955	969	971	961	963	951	960	953	954	959	948	957	960	948	955	958	970	985	994	971	965	969	974	
25	1号炉	972	957	972	967	974	974	959	966	965	958	954	969	971	955	971	962	999	961	962	960	964	949	967	943	
	2号炉	990	988	965	965	983	966	965	957	976	982	971	945	942	946	947	950	954	952	969	971	970	954	950	942	
26	1号炉	969	959	973	964	975	979	967	986	966	957	942	961	966	967	964	962	960	967	959	975	963	974	952	953	
	2号炉	948	957	963	952	955	957	959	981	965	958	959	934	948	953	954	946	961	968	982	970	962	965	961	958	
27	1号炉	951	964	964	1014	984	981	978	981	964	966	975	978	965	952	968	972	983	963	972	972	963	966	967	977	
	2号炉	959	977	984	989	1001	962	968	973	975	985	982	959	964	962	981	967	969	966	958	971	968	984	963	988	
28	1号炉	962	983	962	929	982	977	973	965	975	978	966	978	994	983	985	974	956	969	956	962	973	959	957	962	
	2号炉	982	983	1009	962	969	976	961	961	961	965	953	959	965	958	984	956	954	963	966	956	968	967	958	965	
29	1号炉	967	971	984	990	964	975	965	1001	976	976	973	975	980	967	964	982	994	968	959	957	960	967	965	970	
	2号炉	967	980	975	969	977	981	980	985	935				958	946	937	943	942	945	955	948	951	956	960	942	
30	1号炉	971	959	966	975	1006	979	973	958	853			1004	961	961	962	974	969	963	964	973	961	960	960	941	
	2号炉	958	951	954	952	958	954	961	962	953	954	950	946	960	948	944	967	961	962	956	964	961	953	961	961	
31	1号炉	976	963	953	945	951	963	963	977	985	965	979	968	967	945	955	1001	952	974	964	963	973	977	966	961	
	2号炉	962	970	960	962	974	957	961	948	973	974	967	962	960	957	945	943	944	910	945	954	955	959	945	956	