

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和3年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	964	962	971	975	972	959	955	957	948	945	946	934	940	932	945	945	954	950	974	947	971	960	952	966	
	2号炉	949	969	960	975	963	955	949	935	933	985	990	971	956	951	957	967	976	974	972	958	974	977	979	966	
2	1号炉	958	951	958	958	955	943	946	943	960	962	957	962	942	952	963		936	964	962	968	942	955	951	965	熱電対不良のため 16時台計測不能
	2号炉	974	962	956	951	965	958	965	953	980	968	961	968	954	961	951	959	949	964	967	980	981	954	960	972	
3	1号炉	953	959	968	966	960	962	952	956	953	959	961	950	971	933	971	1003	950	958	944	949	960	967	962	972	
	2号炉	965	965	973	973	942	938	970	947	954	984	962	965	957	967	957	963	962	956	948	967	974	972	965	963	
4	1号炉	968	952	957	961	961	961	955	949	934	963	955	967	956	954	968	961	947	948	964	954	961	958	952	965	
	2号炉	967	975	965	960	964	965	967	962	962	977	968	967	967	957	955	961	965	958	970	980	964	970	967	973	
5	1号炉	946	968	950	949	969	956	954	949	950	920	942	961	957	931	931	949	960	947	952	945	950	943	966	960	
	2号炉	990	990	981	987	972	976	980	979	969	965	934	961	970	956	961	942	937	946	960	952	946	952	925	925	
6	1号炉	970	943	960	953	947	956	968	955	964	960	953	960	956	971	940	987	958	953	944	949	948	961	948	951	
	2号炉	945	948	924	947	928	958	958	955					950	950	955	952	947	951	960	963	965	967	969	965	8:01~12:00給じん停止
7	1号炉	960	955	983	957	954	975	949	957	870			1019	964	979	956	969	971	960	956	971	988	977	970	957	8:35~11:34給じん停止
	2号炉	960	959	965	960	960	966	963	959	960	966	958	954	950	972	977	966	957	968	963	955	955	960	971	961	
8	1号炉	977	971	955	978	982	967	979	974	975	964	964	988	1006	990	964	964	946	950	1016	997	963	970	985	962	
	2号炉	964	955	960	968	969	956	975	967	965	951	956	961	959	948	939	952	944	953	964	958	960	974	953	959	
9	1号炉	964	947	953	965	965	969	951	968	965	945	945	987	989	978	977	975	954	962	956	972	949	957	967	976	
	2号炉	954	954	958	957	962	966	963	953	968	966	957	935	949	956	955	959	951	956	948	950	954	899	981	956	
10	1号炉	977	953	967	966	970	959	954	956	951	932	972	974	960	975	972	966	960	971	962	976	968	895	955	985	
	2号炉	954	936	948	966	960	952	965	965	959	963	953	974	959	963	982	974	976	954	953	970	966	967	969	964	
11	1号炉	985	960	970	963	982	974	974	972	987	989	974	985	974	988	971	972	961	980	979	971	965	963	986	959	
	2号炉	960	971	963	957	965	968	969	959	956	973	968	969	967	959	967	963	965	967	968	965	971	973	973	962	
12	1号炉	966	971	970	974	962	968	976	969	986	968	958	971	997	999	974	974	1005	954	965	962	959	978	955	981	
	2号炉	968	962	970	973	971	963	966	962	963	973	961	962	958	962	961	958	958	969	958	964	962	971	967	961	
13	1号炉	961	951	963	976	970	965	965	963	959	955	950	949	965	966	964	972	951	955	975	981	950	959	953	908	
	2号炉	966	967	962	963	956	971	962	965	878				958	953	962	947	943	955	966	954	954	963	954	956	8:34~12:01給じん停止
14	1号炉	971	969	965	972	930	957	972	972	953		960	960	1006	1035	977	1005	987	968	985	965	968	979	971	973	8:41~10:01給じん停止
	2号炉	953	964	951	949	956	958	958	950	949	959	965	962	954	961	952	948	945	966	958	966	955	962	952	959	
15	1号炉	974	961	983	982	970	969	979	966	967	959	956	947	970	973	967	977	977	963	955	964	974	948	954	959	
	2号炉	955	962	958	946	953	959	945	952	958	956	960	934	943	945	943	962	949	955	944	957	954	950	979	969	

4月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	954	956	958	962	975	946	958	988	905																	定常運転～立ち下げ(8:39～)
	2号炉	952	966	952	963	956	957	940	961	959	956	963	963	959	955	955	945	965	967	955	952	960	963	977	972		
17	1号炉																										休炉
	2号炉	970	969	963	954	965	963	961	956	960	958	966	960	972	967	967	972	958	956	961	965	962	963	939	939		
18	1号炉																										休炉
	2号炉	943	956	961	962	959	943	945	942	974	964	955	962	960	970	975	965	961	974	966	957	966	965	957	960		
19	1号炉																										休炉
	2号炉	951	949	962	960	962	962	960	964	958	955	952	962	965	956	955	951	945	956	959	961	961	957	948	950		
20	1号炉																										休炉
	2号炉	951	961	957	961	959	963	966	974	877		875	945	962	955	954	966	954	980		1025	942	931	949	962		
21	1号炉																										休炉
	2号炉	942	948	954	951	961	948	958	949	954	947	955	948	938	971	968	957	972	962	959	958	949	961	950	956		
22	1号炉																										休炉
	2号炉	945	952	938	940	941	965	971	958	966	962	955	958	943	946	957	955	953	960	958	948	953	966	959	961		
23	1号炉																										休炉
	2号炉	960	952	953	959	963	957	971	951	965	961	957	963	950	965	971	969	969	971	964	976	968	956	955	968		
24	1号炉																										休炉
	2号炉	960	964	960	961	961	954	968	963	960	950	961	958	958	957	969	971	956	948	959	955	963	953	959	961		
25	1号炉																										休炉
	2号炉	951	954	958	952	962	953	962	962	958	1024	1015	933	960	950	957	946	957	950	951	963	1098	1025	972	971		
26	1号炉																										休炉
	2号炉	966	967	977	969	968	950	963	964	955	962	966	958	960	966	948	948	950	962	962	961	957	957	957	970		
27	1号炉										1001	949	996	920	923	968	967	951	965	985	977	983	973	967	979		立上げ～定常運転
	2号炉	954	958	958	958	965	961	963	951	861			997	949	943	942	951	952	956	959	957	954	953	960	949		8:36～11:33給じん停止
28	1号炉	985	979	987	963	953	978	959	949	995	957	986	967	995	1038	1050	980	983	978	975	972	976	972	984	968		
	2号炉	967	956	959	956	962	961	962	953	955	964	973	965	958	966	961	960	968	954	966	957	963	958	967	962		
29	1号炉	976	984	1001	989	989	963	1010	958	941	978	1006	963	963	958	969	962	931	956	971	982	990	969	980	966		
	2号炉	960	979	964	962	960	966	964	957	966	986	969	967	972	963	967	955	982	959	960	949	959	973	965	969		
30	1号炉	992	949	954	956	968	973	955	974	969	959	953	969	986	964	979	1002	988	965	970	966	960	964	987	984		
	2号炉	970	965	964	957	954	956	968	965	967	956	965	953	962	968	971	981	981	964	961	958	968	959	951	960		

5月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	965	970	965	956	977	943	965	981	976	957	963	972	967	977	960	963	971	964	944	973	961	982	982	960	
	2号炉																									
17	1号炉	971	951	985	968	958	953	966	976	956	957	949	956	962	942	956	961	953	959	956	953	969	965	968	963	
	2号炉																									
18	1号炉	965	967	974	968	969	948	960	967	949	969	955	973	946	995	949	949	949	953	955	962	942	960	962	962	
	2号炉																									
19	1号炉	978	980	986	973	972	973	963	974	873		942	953	961	940	937	948	953	963		1029	963	958	932	950	8:33~10:15給じん停止 17:15~19:31給じん停止
	2号炉																									
20	1号炉	954	946	975	947	960	953	971	967	981	971	969	957	954	947	954	927	948	945	937	942	956	907	956	927	
	2号炉																									
21	1号炉	960	959	950	953	970	949	987	952	961	950	948	948	970	974	942	968	935	958	963	968	954	973	928	962	
	2号炉																									
22	1号炉	960	951	961	951	955	964	969	965	969	984	967	963	965	976	971	966	968	981	977	987	972	979	975	965	
	2号炉																									
23	1号炉	972	969	967	971	970	965	970	964	964	961	964	980	968	966	971	975	971	964	987	956	956	944	947	955	
	2号炉																									
24	1号炉	969	948	966	968	961	952	964	965	961	966	966	961	964	929	959	974	972	974	974	953	965	964	968	969	
	2号炉																									
25	1号炉	945	958	961	958	957	946	948	962	961	960	968	962	963	942	955	962	972	930	960	962	958	966	959	957	
	2号炉																									
26	1号炉	954	926	935	959	958	961	973	965	958	964	966	957	949	951	949	954	952	972	948	944	989	953	967	968	
	2号炉											946	953	956	947	942	971	967	987	975	998	984	961	960	991	立上げ~定常運転
27	1号炉	962	959	943	976	961	956	956	955	884					937	980	969	965	962	957	964	955	962	970	955	8:34~13:26給じん停止
	2号炉	927	1021	1035	944	965	976	960	965	957	964	951	963	961	962	959	958	963	963	955	961	968	973	964	964	
28	1号炉	961	960	968	967	965	956	955	952	963	979	971	977	979	972	977	969	960	959	969	974	962	975	977	970	
	2号炉	948	968	898	963	962	971	857				972	995	980	975	970	980	950	969	980	960	967	961	957		6:27~10:56給じん停止 22:54~24:01給じん停止
29	1号炉	984	960	971	981	960	974	970	959	967	959	963	974	964	996	970	972	972	958	973	971	963	971	971	967	
	2号炉	952	965	975	969	970	964	964	975	964	985	967	969	974	975	980	957	927	962	985	968	990	972	967	960	
30	1号炉	966	977	984	981	957	981	993	972	967	964	955	959	966	1001	981	977	982	979	962	969	971	960	962	959	
	2号炉	961	952	919	964	968	979	990	973	977	979	971	1017	958	984	975	884	958	962	968	979	974	965	966	961	
31	1号炉	960	973	960	979	968	983	971	973	958	971	954	963	971	973	975	981	980	999	978	963	965	960	989	1012	
	2号炉	963	966	966	970	968	959	975	954	964	977	965	958	960	959	963	961	964	958	976	984	984	978	995	977	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和3年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	984	969	993	980	976	980	981	987	982	995	999	984	990	1038	1022	1041	967	958	957	965	970	1004	967	991	
	2号炉	979	984	977	984	969	976	986	973	971	975	956	948	986	959	958	949	969	963	955		957	982	982	994	18:42~20:01給じん停止
2	1号炉	972	970	983	984	971	963	976	971	904			991	994	984	990	995	996	968	960	969	949	950	961	879	8:35~11:39給じん停止
	2号炉	922	980	972	964	969	969	986	972	986	980	943	958	967	1004	1003	992	962	949	924	953	954	950	956	909	
3	1号炉	911	952	962	956	971	956	965	973	973	951	971	936	958	968	978	1019	1003	975	962	978	966	989	986	959	
	2号炉				967	968	961	951	940	902			933	946	934	948	943	944	949	950	961	958	967	948	970	23:36~3:40給じん停止 8:35~11:35給じん停止
4	1号炉	989	957	973	990	967	971	965	976	962	963	963	942	948	960	976	959	948	983	996	988	975	969	966	966	
	2号炉	963	964	964	965	959	952	952	953	958	955	952	953	937	949	946			937	975	974	963	949	966	966	14:56~17:37給じん停止
5	1号炉	987	973	975	970	971	962	979	984	972	968	965	980	964	1019	931	964	971	974	962	956	971	996	966	961	
	2号炉	966	948	948	926	980	968	958	947	949	965	979	958	949	976	975	965	965	965	965	947	947	971	958	953	
6	1号炉	949	962	964	954	984	997	987	971	958	954	962	961	965	969	964	973	972	980	989	994	959	978	995	1002	
	2号炉	957	951	960	972	948	944	962	959	923	941	941	955	964	958	959	957	961	996	972	978	988	954	981	980	
7	1号炉	979	969	975	974	969	964	983	983	973	992	986	974	1016	1016	1029	1005	934	960	964	976	968	957	951	969	
	2号炉	976	963	961	981	976	982	968	960	956	950	964	973	962	953	942	940	928	946	943	944	952	946	952	949	
8	1号炉	941	965	961	968	971	965	951	975	969	974	966	962	972	985	975	966	955	965	965	961	957	962	965	965	
	2号炉	940	951	983	969	949	955	957	950	950	959	961	955	962	954	938	953	946	948	945	953	950	958	963	965	
9	1号炉	961	965	966	955	975	948	964	961	904			1053	962	949	945	952	944	973	970	968	964	960	956	959	8:35~11:44給じん停止
	2号炉	966	960	944	964	955	956	951	960	935	947	945	939	940	952	948	947	939	953	956	959	955	947	948	952	
10	1号炉	960	960	975	981	962	960	959	962	949	948	930	937	933	932	926	961	960	962	928	943	954	933	952	954	
	2号炉	935	931	948	950	950	954	942	940	885			927	897	924	937	936	932	927	945	951	939	940	949	933	8:35~11:42給じん停止
11	1号炉	970	954	951	951	967	962	968	968	976	961	958	943	935	920	927	983	964	961	945	951	941	916	968	961	
	2号炉	938	950	947	954	957	994	970	966	965	941	930	960	950	906	939	936	935	945	935	945	955	940	938	948	
12	1号炉	981	957	956	940	965	959	957	955	968	961	963	1000	931	965	990	983	987	989	951	976	944				20:53~翌日 給じん停止
	2号炉	947	919	944	936	944	945	941	928	942	968	985	966	970	939	939	957	941	954	947	892	870	909	929	932	
13	1号炉			973	930	965	961	942	946	924	869	926	968	917	929	898	941	948	930	863	945	951	950	931	939	前日~2:30 給じん停止
	2号炉	934	948	938	929	948	964	936	930	936	939	954	963	924	951	938	926	938	960	947	932	925	930	953	953	
14	1号炉	961	966	959	965	959	963	954	961	932	942	935	917	960	970	938	964	965	961	953	954	924	937	938	933	
	2号炉	947	943	924	922	923	970	984	977	966	983	938	894	907	899	952	953	944	965	968	963	973	963	943	947	
15	1号炉	958	961	954	949	963	963	968	976	958	987	970	962	952	898	967	947	978	920	953	911	952	932	976	958	
	2号炉	964	948	945	947	950	946	956	941	940	876	929	941	921	926	932	925	922	936	950	938	915	935	920	933	

6月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	957	956	958	990	943	912	960	964	955	950	920	937	926	952	963	952	953	960	948	983	963	934	951	954	
	2号炉	925	931	917	950	924	941	933	939	926	947	938	927	915	915	916	924	926	934	930	924	921	924	931	918	
17	1号炉	952	947	952	963	974	992	977	957	945	967															
	2号炉	938	906	921	933	915	920	919	910	909	931	937	939	927	945	912	926	924	916	916	928	920	921	922	912	定常運転～立ち下げ(950～)
18	1号炉																									休炉
	2号炉	914	911	922	914	914	914	922	916	867				926	895	903	907	909	911	956	953	954	950	945	948	8:35～12:01給じん停止
19	1号炉																									休炉
	2号炉	948	960	957	954	959	952	947	949	945	958	958	955	955	955	970	967	958	945	933	950	956	927	944	953	
20	1号炉																									休炉
	2号炉	949	947	949	950	943	943	949	948	947	950	947	949	938	934	922	1028	928	927	931	940	949	948	959	967	
21	1号炉																									休炉
	2号炉	947	955	957	928	959	961	950	952	966	949	925	956	948	954	954	971	968	950	939	952	942	935	953	944	
22	1号炉																									休炉
	2号炉	947	964	960	964	959	952	952	961	962	959	950	962	969	964	955	958	952	942	959	965	964	960	934	938	
23	1号炉																									休炉
	2号炉		951	950	951	950	955	942	958	954	966	968	953	934	949	943	943	946	950	966	955	955	956	959	957	23:11～1:07給じん停止
24	1号炉																									休炉
	2号炉	954	960	961	964	959	951	966	955	862	858	958	976	957	969	977	981	968	975			946	950	966	946	17:03～20:04給じん停止
25	1号炉																									休炉
	2号炉	950	946	952	948	947	953	954	956	949	927	943	932	954	951	958	949	950	952	956	959	954	961	950	957	
26	1号炉																									休炉
	2号炉	951	939	948		919	956	954	950	951	950	957	951	952	947	955	960	951	959	956	955	951	956	949	948	2:32～4:40給じん停止
27	1号炉																									休炉
	2号炉	947	946	950	946	954			1031	951	962	967	972	962	967	958	960	957	971	974	973	970	959	968	958	5:00～7:36給じん停止
28	1号炉																									休炉
	2号炉	961	966	956	965	954	958	963	962	966	946	955	958	949	962	943	970	965	969	950	955	956	954	953	959	
29	1号炉																									休炉
	2号炉	958	958	947	953	950	954	964	954	932	935	959	958	957	960	971	976	959	949	955	959	963	954	959	956	
30	1号炉																									休炉
	2号炉	968	956	952	965	963	961	964	959	880			964	947	951	950	953	936	953	950	954	957	964	957	956	8:35～11:19給じん停止

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和3年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉										944	961	989	967	977	967	964	945	950	955	967	967	948	918	立上げ～定常運転	
	2号炉	950	957	944	951	947	960	951	943	943	944	937	920	927	949	951	943	953	948	953	949	941	941	950	966	
2	1号炉	965	980	955	1004	973	968	978	989	984	963	954	946	953	958	945	965	953	954	961	938	918	999	896	851	
	2号炉	944	947	965	959	961	963	962	963	962	950	956	958	955	951	950	944	938	956	961	959	952	950	937	959	
3	1号炉		923	941	969	998	979	966	965	970	973	963	977	975	975	975	995	955	958	933	946	980	953	967	983	23:18～1:03給じん停止
	2号炉	862											944	973	967	954	968	958	945	936	960	959	958	959	963	24:17～11:35給じん停止
4	1号炉	977	984	970	976	981	966	944	929	996	964	969	969	984	988	984	962	965	874	948	939	968	960	946	968	
	2号炉																									保持運転～立ち下げ (0:01～)
5	1号炉	950	966	963	959	971	979	949	968	973	972	963	865										964	967	973	11:06～21:18給じん停止
	2号炉																									休炉
6	1号炉	963	952	961	946	961	962	967	952	965	966	960	961	953	960	973	973	976	966	968	951	961	949	984	976	
	2号炉																									休炉
7	1号炉	980	972	981	967	958	981	964	990	978	981	974	989	995	996	1006	1004	973	966	948	965	966	980	963	954	
	2号炉																1008	958	969	970	962	966	976	966	967	立上げ～定常運転
8	1号炉	955	957	960	982	981	921	910	959	870				929	921	971	977	969	966	973	972	974	963	983	965	8:33～12:03給じん停止
	2号炉	965	965	944	962	964	976	979	956	963	976	964	945	974	981	958	944	939	956	933	973	942	947	948	957	
9	1号炉	979	964	945	978	978	974	978	983	979	956	973	947	958	950	943	929		963	974	954	968	984	972	980	15:50～17:05給じん停止
	2号炉	948	929	953	941	939	944	943	952	940	940	923	949	943	930	937	941	934	941	925	944	938	937	941	935	
10	1号炉	972	1004	985	992	982	955	977	971	980	973	991	995	981	968	979	977	972	994	972	994	975	976	970	975	
	2号炉	941	939	941	942	934	942	898	933	948	932	975	961	934	929	947	923	924	925	942	933	926	936	919	934	
11	1号炉	971	990	978	960	982	998	967	968	953	955	984	959	943	945	985	978	995	973	976	974	984	983	987	970	
	2号炉	922	925	929	913	932	922	924	918	916	918	912	911	939	916	927	917	910	905	916	915	918	912	953	959	
12	1号炉	980	974	962	967	987	982	981	1000	986	955	960	942		966	972	942	942	969	957	976	963	970	983	975	11:49～13:08給じん停止
	2号炉	956	978	959	954	957	960	951	946	959	966	938	924		954	942	954	931	948	947	952	956	942	939	968	11:32～13:06給じん停止
13	1号炉	944	958	980	974	966	971	962	938	963	974	957	954	971	989	972	974	964	967	955	966	976	961	957	962	
	2号炉	952	955	956	954	955	955	945	941	942	939	941	950	935	936	938	953	946	936	938	964	938	959	953	949	
14	1号炉	963	966	965	963	955	965	966	969	887			982	952	970	969	970	968	956	966	971	972	969	953	962	8:34～11:45給じん停止
	2号炉	948	946	957	941	960	947	942	953	948	943	949	942	938	934	937	941	930	933	959	941	945	960	943	944	
15	1号炉	954	962	966	951	963	969	969	956	972	973	983	978	958	967	958	962	971	974	983	975	985	965	957	974	
	2号炉	943	952	932	934	950	934	946	937	886			933	930	930	935	940	935	937	938	949	943	951	955	960	8:34～11:03給じん停止

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和3年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	978	966	983	978	979	972	970	970	955	955	957	968	956	956	963	945	967		968	971	961	953	968	963	17:00~18:00給じん停止
	2号炉																									休炉
2	1号炉	968	980	965	959	952	963	973	950	970	980	958	966	950	971	957	970	967	957	963	963	960	981	965	967	
	2号炉																									休炉
3	1号炉	961	946	968	958	956	968	957	975	960	965	960	975	946	958	940	970	962	944	911	951	941	960	945	963	
	2号炉																									休炉
4	1号炉	964	954	969	962	955	953	962	954	959	962	954	938	981	962	969	986	985	984	962	967	958	928	950	950	
	2号炉																									休炉
5	1号炉	954	959	964	961	954	977	959	959	971	945	948	951	980						980	960	971	972	980	950	12:57~18:37給じん停止
	2号炉													970	960	975	936	941	950	953	959	969	972	1,000		立上げ~定常運転
6	1号炉	946	943	972	964	970	948	976	980	978	979	967	951	991	986	935	951	951	981	977	991	976	976	972	974	
	2号炉	954	958	964	970	970	962	965	954	950	952	949	968	947	954	946	944	955	983	977	972	985	980	971	967	
7	1号炉	963	990	970	957	971	958	967	968	972	951	974	958	1,004	975	968	954	978	989	963	952	965	980	965	968	
	2号炉	966	947	902			977	980	944	948	952	950	956	973	962	954	957	950	954	967	956	948	946	964	982	2:52~5:07給じん停止
8	1号炉	964	932	966	971	975	975	971	980	964	965	977	968	973	969	978	980	971	961	993	990	986	1,003	969	982	
	2号炉	950	943	950	947	935	959	944	945	955	957	955	962	962	962	965	957	963	980	983	985	957	952	991	933	
9	1号炉	951	951	961	970	954	969	972	973	966	976	973	994	965	964	959	975	966	969	977	975	965	963	984	969	
	2号炉	951	962	968	947	940	972	968	967	938	942	959	955	963	958	948	962	945	956	955	948	951	962	970	964	
10	1号炉	987	976	991	963	970	979	958	934	938	957	956	963	967	972	964	980	976	965	970	971	976	969	967	977	
	2号炉	960	954	956	966	965	954	940	947	947	955	946	945	938	942	978	952	949	961	951	965	961	957	972	941	
11	1号炉	993	976	975	956	973	980	968	972	972	955	970	995	968	970	979	1,001	1,006	956	964	961	958	968	971	980	
	2号炉	970	949	959	961	956	972	962	954	859			946	934	926	946	949	944	941	939	960	943	954	945	958	8:32~11:21給じん停止
12	1号炉	977	981	985	978	969	932	962	953	836				965	957	946	955	960	945	951	967	964	910	934	968	8:32~12:00給じん停止
	2号炉	947	967	959	962	941	947	970	967	967	954	948	938	947	935	943	939	956	929	968	944	944	945	969	954	
13	1号炉	960	980	975	952	971	970	961	956	969	963	964	952	958	972	964	955	956	961	964	944	961	950	975	968	
	2号炉	951	946	952	948	924	961	938	953	938	946	946	949	948	941	951	952	949	937	958	940	943	944	949	948	
14	1号炉	955	971	966	976	966	970	974	974	974	997	969	985	968	968	976	982	965	984	1,006	977	973	957	988	1,012	
	2号炉	930	948	953	952	946	963	953	960	966	978	959	981	979	980	956	949	967	988	959	932	951	959	968	941	
15	1号炉	961	947	1,008	1,006	989	970	973	956	976	937	953	946	954	968	963	940	958	960	973	966	976	954	988	931	
	2号炉	965	977	975	963	957	967	975	959	947	950	953	956	962	958	928	928	948	972	970	953	957	948	931	922	

8月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	950	960	971	987	961	969	982	986	963	959	960	979	954	963	953	962	964	942	949	940	985	967	967	1002	
	2号炉	959	958	960	961	965	957	978	948	952		971	951	939	943			926	920	956	928	958	980	967	970	8:49~10:21給じん停止 13:05~16:00給じん停止
17	1号炉	965	966	947	955	971	971	986	977	973	964	957	956	953	958	958	951	958	958	974	974	943	949	927	984	
	2号炉	971	957	961	952	960	965	954	956	965	953	946	941	950	949	953	952	945	972	988	984	969	972	968	964	
18	1号炉	963	966	946	970	959	973	946	973	958	960	970	975	981	947	949	959	972	967	960	959	979	953	963	966	
	2号炉	949	959	984	935	955	948	960	963	857			1,001	944	929	919	960	944	955	951	974	940	943	959	947	8:33~11:59給じん停止
19	1号炉	950	967	944	996	971	985	986	978	851				939	938	938	938	969	943	945	957	966	951	943	957	8:32~12:00給じん停止
	2号炉	965	944	963	971	934	941	937	951	942	952	948	967	954	942	949	941	949	962	967	959	948	959	951	944	
20	1号炉	948	949	938	940	962	954	967	962	955	947	949	970	955	966	954	961	972	948	976	974	966	967	962	966	
	2号炉	958	958	959	951	962	929	942	977	955	927	948	953	953	957	944	954	950	966	954	961	965	955	955	928	
21	1号炉	959	974	985	952	964	975	964	981	950	963	943	987	974	984	986	936	978	965	968	973	963	987	982	983	
	2号炉	707				1,001	980	972	988	968	956	947	961	959	953	965	971	977	956	963	976	959	959	956	976	24:16~4:01給じん停止
22	1号炉	985	976	961	981	951	977	971	940	960	969	967	978	971	970	973	970	974	961	957	971	989	974	978	985	
	2号炉	960	976	962	952	959	959	972	959	956	960	965	964	949	965	964	958	949	950	946	945	951	960	976	966	
23	1号炉	990	970	973	980	973	972	968	954	978	969	973	965	970	961	952	959	965	953	968	956	958	958	964	976	
	2号炉	948	929	938	946	964	968	969	975	972	955	979	938	952	956	954	953	948	951	996	954	964	970	982	965	
24	1号炉	962	977	960	958	930	983	970	942	963	950	966	946	948	965	967	970	953	958	967	940	960	958	969	971	
	2号炉	962	953	945	956	949	936	951	952	968	958	956	946	946	942	951	936	943	946	961	951	952	918	950	968	
25	1号炉	968	972	966	974	967	967	969	963	968	971	968	963	956	958	968	953	954	968	944	957	958	949	953	960	
	2号炉	972	953	962	954	948	946	949	947	901					830	964	960	961	938	964	923	950	945	955	935	8:34~13:40給じん停止
26	1号炉	972	970	959	955	939	955	956	957	949	960	950	948	946	957	950	952	947	957	951	949	967	963	963	942	
	2号炉	964	952	961	957	965	960	946	943	970	949	951	946	960	946	968	952	952	959	962	964	962	955	931	948	
27	1号炉	974	966	981	969	959	982	973	963	950																定常運転~立ち下げ (8:44~)
	2号炉	955	960	952	956	956	966	966	957	963	958	954	976	983	986	961	962	969	961	952	967	955	948	978	945	
28	1号炉																									休炉
	2号炉	944	955	966	969	954	936	923		923	962	958	966	967	959	961	984	969	983	984	997	991	958	958	953	6:50~8:41給じん停止
29	1号炉																									休炉
	2号炉	956	963	945	935	973	986	979	923	950	949	948	954	956	968	978	967	949	990	985	962	953	963	971	966	
30	1号炉																									休炉
	2号炉	966	952	959	960	957	969	959	969	964	967	952	960	965	961	963	976	958	957	958	970	980	979	957	961	
31	1号炉																									休炉
	2号炉	973	965	967	969	961	950	950	924	960	970	950	955	957	964	943	954	952	954	971	982	968	977	959	958	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和3年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

9月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	958	942	951	966	952	955	962	966	885		944	968	968	949	950	953	971	961		1085	937	940	957	959	8:34~10:00給じん停止 17:06~19:49給じん停止
2	1号炉																									休炉
	2号炉	957	960	956	955	947	940	950	937	950	964	937	959	954	946	954	942	940	956	949	948	949	946	950	949	
3	1号炉																									休炉
	2号炉	955	948	940	935	944	908	936	934	951	958	891	978	952	943	959	951	944	960	950	942	956	942	945	955	
4	1号炉												962	968	968	983	978	1005	986	954	964	984	979	972	立上げ~定常運転	
	2号炉	957	963	958	954	940	961	956	946	956	942	946	948	944	951	959	963	962	953	967	942	938	938	938	958	
5	1号炉	961	984	966	961	984	954	951	964	960	969	982	966	956	963	963	965	976	973	955	955	930	947	965	969	
	2号炉	957	964	962	964	954	966	961	966	959	956	964	964	966	961	960	960	961	961	961	956	941	951	947	936	
6	1号炉	968	963	979	998	955	965	968	956	992	943	961	974	963	962	971	955	971	961	931	913	964	946	996	954	
	2号炉	950	962	955	966	953	963	958	964	962	961	960	969	960	957	955	955	965	963	962	949	970	944	962	962	
7	1号炉	975	947	963	964	960	968	965	958	976	969	961	936	975	959	948	953	956	947	963	968	979	995	975	973	
	2号炉	971	968	953	952	961	950	954	939	954	955	945	970	956	956	950	951	947	932	915	955	964	961	962	961	
8	1号炉	977	977	952	973	966	955	932	962	989	991	965	965	946	972	955	983	959	964	960	939	992	984	968	956	
	2号炉	968	951	925	957	962	892					969	971	968	951	957	957	954	920		969	927	965	959	969	5:37~10:01給じん停止 17:43~19:36給じん停止
9	1号炉	956	980	979	960	963	936	957	946	959	950	958	937	957	964	952	948	954	953	953	952	950	966	953	963	
	2号炉	918		969	945	948	968	951	960	888			967	949	957	937	958	952	953	955	952	963	954	955	954	24:43~2:05給じん停止 8:35~11:20給じん停止
10	1号炉	956	953	970	946	956	957	985	969	871			971	962	964	943	959	970	962	966	978	963	954	974	954	8:32~11:02給じん停止
	2号炉	957	946	958	954	936	933	938	961	975	943	947	963	951	961	956	955	953	952	949	959	952	957	960	970	
11	1号炉	965	972	954	963	971	961	979	946	963	1004	997	969	988	978	963	972	955	962	967	992	962	953	937	970	
	2号炉	951	948	949	954	949	950	951	937	952	963	962	958	955	961	961	959	965	958	964	969	973	962	949	951	
12	1号炉	966	963	945	962	956	971	978	974	963	951	976	967	967	934	925	952	945	976	930	931	936	944	942	962	
	2号炉	966	958	964	946	964	959	959	961	961	961	969	975	958	950			930	957	974	963	965	967	951	959	13:48~16:00給じん停止
13	1号炉	935	923	929	931	911	919	933	909	915	885	892	954	951	951	945	947	946	967	947	955	957	958	961	939	
	2号炉	939	967	963	971	974	966	957	972	948	970	954	967	958	966	965	971	956	953	958	903	943	968	963	954	
14	1号炉	961	961	981	986	960	933	965	941	955	972	978	971	966	969	958	950	962	963	961	955	977	943	964	979	
	2号炉	921	950	953	966	959	955	952	942		947	955	967	949	952	956	951	956	944	962	957	976	958	966	962	7:43~9:06給じん停止
15	1号炉	964	957	959	963	967	951	967	983	981	940	947	945	961	952	959	943	938	903	981	937	960	946	949	982	
	2号炉	964	890			1124	965	969	976	871			979	960	966	958	970	971	960	953	980	952	939	963	976	1:10~4:47給じん停止 8:34~11:08給じん停止

9月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	926	956	956	967	968	965	934	958	858			1010	948	943	960	925	882	911	935	889	890			963	964	8:34~11:15給じん停止 20:45~22:10給じん停止
	2号炉	969	973	972	982	967	975	972	976	972	971	965	955	982	974	960	984	975	954	970	971	960	986	979	970		
17	1号炉	947	969	978	971	960	952	957	967	957	950	959	964	959	961	945	958	948	976	923	949	972	923	928	976		
	2号炉	979	959	971	999	988	967	971	970	978	985	962	970	968	980	966	976	965	968	956	998	977	965	985	978		
18	1号炉	945	968	962	951	948	953	948	900	944	971	960	932	975	944	979	968	969	943	918	972	945	944	961	962		
	2号炉	974	983	971	985	981	927	975	984	916	978	975	987	989	995	993	983	973	970	990	980	976	994	976	977		
19	1号炉	971	966	943	943	970	970	954	959	967	976	967	955	958	967	973	968	960	971	976	973	980	960	957	961		
	2号炉	998	1015	999	978	990	996	990	996	997	1017	985	978	989	986	973	980	980	1008		973	966	985	988	990	17:20~19:03給じん停止	
20	1号炉	970	954	967	974	939	975	986	993	980	955	963	959	960	959	928	965	975	949	954	960	953	946	968	984		
	2号炉	1014	989	982	973	971	986	988	998	986	979	993	989	974	976	978	965	983	992	975	989	975	983	983	972		
21	1号炉	976	950	940	943	951	950	958	955	957	948	954	941	940	925	931	941	935	947	953	944	985	964	951	957		
	2号炉	980	975	974	964	971	960	957	981	965	966	962	977	968	969	960	971	965	976	957	975	991	958	970	970		
22	1号炉	958	961	937	930	987	948	915	892	910	943	941	957	959	950	940	933	960	949	953	959	942	941	933	939		
	2号炉	963	970	953	989	964	960	965	968	897			989	951	960	954	967	959	955	951	964	941	973	954	977	8:35~11:21給じん停止	
23	1号炉	925	907	930	940	932	901	900	930	921																8:45~保持運転	
	2号炉	982	954	1009	988	969	995	966	996	936				954	996	1004	949	972	949	960	967	965	968	973	963	8:49~12:23給じん停止	
24	1号炉																		877	903	941	925	966	959	963	保持運転~17:57	
	2号炉	956	970	975	951	951	956	970	964	977	969	955	942	949	954	973	950	960	960	931	947	995	974	936	970		
25	1号炉	934	972	954	948	944	964	952	964	950	960	920	928	955	959	963	951	942	947	956	947	927	959	965	961		
	2号炉	940	978	964	965	976	974	982	954	949	974	971	962	973	978	947	967	965	946	943	928	954	958	965	949		
26	1号炉	961	949	962	962	968	960	945	966	984	986	978	977	973	968	943	918	958	933	948	961	941	965	955	976		
	2号炉	961	964	949	963	965	970	953	948	918		1022	964	933	948	972	971	993	962	966	958	955	975	964	946	8:40~10:33給じん停止	
27	1号炉	967	959	979	976	959	959	973	951	980	937	950	931	948	939	951	951	957	941	937	941	945	995	934	943		
	2号炉	962	962	960	961	966	958	965	958	933	959	945	960	958	938	947	941	949	941	947	983	973	952	957	952		
28	1号炉	955	976	945	948	942	943	955	921	922	951	947	949	942	932	939	929	929	950	911	934	955	962	958	951		
	2号炉	954	925	947	962	960	958	947	936	940	968	959	946	952	941	932	936	931	952	960	962	971	948	939	947		
29	1号炉	940	953	929	914	970	949	937	933	942	935	938	930	925	955	925	918	933	952	934	962	932	927	940	944		
	2号炉	943	961	988	938	928	946	901	866	898			1058	946	929	938	893	918	896	916	921	928	929	933	926	8:34~11:56給じん停止	
30	1号炉	888													988	972	956	972	969	972	963	965	969	969	974	0:21~13:19給じん停止	
	2号炉	933	914	919	934	922	901	923	899	943	881		926													9:11~11:04給じん停止 定常運転~立ち下げ (11:52~)	