

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和4年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1008	976	982	986	992	1015	987	976	973	993	867	914	943	922	956	999	966		1010	974	1009	1002	975	987	16:47~18:09給じん停止
	2号炉	943	961	985	1006	979	959	962	964	968	1000	820	884	967	980	979	995	999		974	982	962	980	978	969	16:50~18:10給じん停止
2	1号炉	982	968	1042	951	937	976	983	975	991	1025	1025	976	1029	989	986	978	989	983	996	1007	1021	992	992	976	
	2号炉	961	974	955	978	974	958	962	1003	968	967	965	984	966	954	958	953	979	960	988	981	972	967	967	968	
3	1号炉	974	971	992	975	984	1001	1013	957	962	1028	1033	1011	1031	991	992	995	986	1002	1030	1008	1011	1016	1025	1039	
	2号炉	982	980	952	940	959	972	993	989	980	978	1024	1003	1012	963	962	975	976	1012	1010	1026	1010	987	998	999	
4	1号炉	1001	989	1036	1000	1025	960	1000	1004	1044	1025	1011	1053	1068	1039	963	996	985	1004	1011	1021	1019	1026	1007	1012	
	2号炉	1002	1004	982	1031	1022	1018	984	996	999	994	1002	997	972	995	980	966	994	976	972	975	974	974	983	982	
5	1号炉	1051	990	996	961	963	1019	1024	1001	1019	1002	988	990	995	1017	989	976	985	1017	1042	1013	990	1000	1045	1011	
	2号炉	972	970	971	949	971	987	964	972	976	986	967	973	948	923	958	982	979	1011	998	994	994	995	1014	993	
6	1号炉	999	1011	1018	1003	994	1045	1040	1019	981	986	953	956	993	1020	1025	1017	998	1034	999	1013	1048	1025	1000	1007	
	2号炉	990	1005	980	966	963	962	974	958	892			1045	977	1012	994	1011	1003	999	976	971	1003	987	1001	1033	8:33~11:44給じん停止
7	1号炉	1013	983	989	1043	1010	979	1018	994	861			1060	993	975	982	989	958	944	972	988	1027	1034	1026	976	8:32~11:36給じん停止
	2号炉	988	1000	1007	1011	997	970	970	960	985	939	963	967	949	953	942	942	932	960	945	948	963	991	989	955	
8	1号炉	1020	1000	992	978	991	964	973	1000	1009	1063	1023	1031	1040	999	1032	1005	1004	1012	1003	1012	999	991	1029	1004	
	2号炉	962	986	991	963	956	966	969	953	974	970	956	963	966	979	962	948	970	968	976	1008	1015	1014	1012	1029	
9	1号炉	1045	1070	1035	1023	995	1053	1040	1036	1014	1043	1007	1037	980	1025	985	1006	997	1020	1046	1014	989	998	1035	1009	
	2号炉	1021	1038	1002	983	993	1032	1040	1044	1037	1013	970	946	1001	1008	1029	974	983	966	990	975	1021	997	1014	1024	
10	1号炉	1011	1006	961	947	981	985	979	989	1006	960	952	1000	931	962	1014	980	955	956	944	930	948	969	948	919	
	2号炉	1011	980	973	967	946	960	996	1022	998	988	951	987	949	954	965	1012	999	984	1016	950	977	1007	946	978	
11	1号炉	953	932	921	930	946	997	1018	966	983	982	1004	964	1002	997	1006	1009	976	971	998	986	964	985	1001	957	
	2号炉	1005	971	987	990	993	991	979	950	985	983	1020	986	968	993	994	978	1003	999	1006	978	973	962	941	953	
12	1号炉	955	958	981	1005	1032	1029	998	1017	994				1172	991	946	944	990	979	986	1004	988	987	990	1013	8:51~12:25給じん停止
	2号炉	972	960	996	1024	1009	997	998	1004	1004	1055	985	978	960	976	914	971	957	967	976	975	963	953	960	973	
13	1号炉	1005	984	1058	1029	994	983	978	957	913	967	977	1016	1028	1003	973	976	947	977	951	994	959	971	922	915	
	2号炉	967	950	994	1024	982	979	1030	1008	864				1051	987	961	958	930	949	953	966	962	943	980	965	8:34~12:31給じん停止
14	1号炉	914	906	954	982	946	937	953	986	966	931	928	926	980	956	972	953	953	975	980	962	983	997	977	994	
	2号炉	950	1019	964	968	960	966	1005	1006	996	967	962	953	953	937	947	967	979	969	984	1008	965	966	967	982	
15	1号炉	1014	977	984	952	975	967	981	994	996	965	941	969	1023	1046	1012	1056	1048	1042	1004	1025	1034	1038	1016	991	
	2号炉	969	944	957	973	953	959	956	960	952	970	982	970	957	980	987	977	973	1022	996	971	977	1008	1022	978	

4月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	1025	1002	980	979	1035	975	992	959	984	951	1012	996	997	1001	979	1026	974	1013	1037	1009	1002	998	975	1009	
	2号炉	972	958	957	956	971	955	961	968	984	1021	1010	976	978	964	973	961	981	979	998	1022	990	983	1016	979	
17	1号炉	975	993		1034	921	903	959	990	1007	913	955	1032	1025	1020	961	962	941	950	992	1010	1001	992	1021	985	2:00~3:53給じん停止
	2号炉	979	964	988	980	968	955	983	998	974	1001	1010	971	1002	1041	991	992	1004	999	1011	1028	1022	989	979	969	
18	1号炉	939	917	939	961	913	959	921	922	927	957	928	949	953	895	902	917	926	962	956	982	1018	1033	992	998	
	2号炉	964	963	995	995	974	982	970	966	882			999	977	953	949	965	980	992	931	1001	1029	1026	983	971	8:34~11:48給じん停止
19	1号炉	1034	988	966	991	989	955	967	985	981	990	961	986	1019	1056	1021	914	952	971	970	958	953	984	903	984	
	2号炉	949	971	968	984	954	988	978	988	971	956	969	944	977	998	974	960	984	997	984	981	976	995	994	1013	
20	1号炉	1024	959	973	990	982	979	967	960	873			1101	952	941	949	939	950	950	994	997	971	971	972	966	8:32~11:30給じん停止
	2号炉	990	958	989	966	948	965	964	970	983	993	1009	976	982	990	957	967	971	964	989	974	982	994	1007	1006	
21	1号炉	976	966	905	906	930	981	994	1023	971	975	985	966	938	949	950	779		976	949	960	957	956	978	969	15:07~17:48給じん停止
	2号炉	988	964	1006	961	949	958	1000	979	967	1000	970	946	951	949	958	733			970	920	988	988	998	975	15:07~18:28給じん停止
22	1号炉	969	943	964	943	954	976	974	956	1000	989	1004	954	985	993	979	982	996	944	1015	1051	1033	1045	1048	1017	
	2号炉	992	985	984	997	993	1005	1013	980	1001	876	1015	953	976	967	955	973	974	992	965	966	1007	1016	1015	997	
23	1号炉	1031	985	1049	1031	1018	1020	994	986	950	987	963	979	985	982	984	967	1028	1015	1012	994	1020	1037	1001	1014	
	2号炉	1024	1017	1034	1025	1011	989	997	1014	1018	969	980	986	940	949	964	1006	981	976	985	992	1014	1009	993	1009	
24	1号炉	997	998	1026	1025	1054	1058	1056	1047	1050	1025	1017	971	970	1039	995	1016	1007	995	1020	1002	987	990	1001	1009	
	2号炉	1018	997	981	1008	1044	1028	1052	1006	1003	1015	980	990	982	1050	975	956	959	951	1030	1021	1014	976	993	1003	
25	1号炉	1007	1008	1027	1004	1022	1004	1037	980	1047	1016	1006	965	998	965	993	984	980	1032	1001	996	1012	973	1009	1008	
	2号炉	999	1040	1024	989	989	987	972	1055	1029	998	1009	984	959	985	974	962	1019	982	985	969	917	993	986	996	
26	1号炉	987	1019	990	1027	1047	1014	1001	1004	892				1086	965	962	974	954	986	995	981	993	998	971	971	8:31~12:15給じん停止
	2号炉	989	987	991	972	1013	995	1009	990	983	991	1016	1028	971	975	964	978	974	976	990	967	989	989	968	989	
27	1号炉	995	1004	1036	1036	1011	1023	988	995	998	1000	1036	974	955	972	980	976	956	996	994	1024	975	973	968	980	
	2号炉	948	1046	1007	1027	1017	994	1002	1008	1019	1022	1017	1016	1029	978	946	958	1000	1007	958	961	975	966	971	986	
28	1号炉	946	992	1044	1008	1010	1031	971	996	1009	985	991	962	986	972	966	962	988	986	977	982	999	983	982	970	
	2号炉	975	972	1018	1002	1001	1023	985	965	872			1009	939	938	942	951	962	968	993	969	985	971	940	930	8:32~11:41給じん停止
29	1号炉	1007	1010	1041	1010	1017	991	969	979	1014	1024	1005	1038	1007	1044	1022	1046	1006	993	998	1000	980	987	1009	1000	
	2号炉	925	972	1039	1015	990	987	961	942	957	984	1007	1009	994	979	999	998	993	976	952	945	940	972	964	955	
30	1号炉	986	980	1038	1007	993	981	1003	1011	1019	1042	1030	1043	1065	1024	1012	1037	1022	1044	1005	1004	985	1033	1000	1037	
	2号炉	957	950	952	966	1016	1001	1023	968	964	1001	972	984	987	971	988	993	994	987	980	1023	1007	1001	1049	1016	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和4年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1047	1003	1018	991	995	970	1054	1063	1074	1085	1040	1024	1049	1003	1027	1007	1065	1008	972	1003	996	1061	1073	1041	
	2号炉	1004	977	1002	974	954	964	982	1033	1036	1044	1008	1000	971	971	1001	986	1010	1021	966	993	989	1030	1010	1035	
2	1号炉	1020	1004	980	1011	990	1011	977	993	877			1186	1003	943	969	951	992	1001	994	1008	953	986	976	955	8:34~11:31給じん停止
	2号炉	979	1015	973	961	970	992	963	965	964	965	963	944	940	972	967	962	979	974	1018	1005	956	950	974	983	
3	1号炉	919	955	983	996	980	985	969	971	911	985	1011	1037	1015	1061	1026	988	985	1012	1041	1057	1032	965	986	995	
	2号炉	935	938	952	945	961	958	958	963	990	968	977	986	1012	996	990	968	935	1003	1008	996	982	988	951	981	
4	1号炉	970	990	975	972	987	982	979	964	979	1006	1020	1022	1023	1001	994	962	1003	993	992	1036	994	1006	995	984	
	2号炉	977	981	967	952	979	951	960	937	959	938	948	965	994	1007	1017	985	1000	997	1044	1013	1037	995	1026	1003	
5	1号炉	998	998	990	990	981	998	1010	1016	986	980	987	975	984	995	988	958	975	972	975	986	988	965	966	959	
	2号炉	1005	962	873	945	990	969	984	977	887			985	973	971	923	959	979	973	972	992	978	993	974	973	8:30~11:32給じん停止
6	1号炉	996	1000	982	970	978	1012	982	966	945																定常運転~立ち下げ(図57~)
	2号炉	987	965	971	969	967	965	983	989	986	996	943	946	959	952	954	943	954	997	976	976	1007	1028	1012	1051	
7	1号炉																									休炉
	2号炉	1040	1002	994	998	1007	985	987	996	964	954	992	984	962	982	979	951	954	981	968	953	1000	988	994	989	
8	1号炉																									休炉
	2号炉	968	957	986	977	993	1015	1004	963	989	995	999	982	966	971	962	964	1031	983	989	989	1015	1014	984	962	
9	1号炉																									休炉
	2号炉	964	1015	991	971	1012	1029	1051	1018	981	970	979	988	949	953	956	966	953	943	953	1006	1013	1027	986	991	
10	1号炉																									休炉
	2号炉	967	1062	998	1014	1011	1000	997	1050	1007	1001	1005	965	955	957	960	944	940	977	964	986	989	998	957	968	
11	1号炉																									休炉
	2号炉	980	1023	1012	1020	1039	964	980	1000	967	916	904	925	984	951	999	996	973	931	972	1010	1002	953	977	953	
12	1号炉																									休炉
	2号炉	983	1048	1050	1058	1014	1040	1008	989	892				926	937	932	946	956	965	952	931	916	943	950	945	8:32~12:03給じん停止
13	1号炉																									休炉
	2号炉	934	934	988	962	954	976	971	972	967	941	958	999	986	939	944	951	964	968	919	911	946	932	933	930	
14	1号炉																									休炉
	2号炉	946	946	956	981	982	977	1005	949	978	1004	951	984	1034	944	993	959	943	983	968	972	982	947	926	930	
15	1号炉																									休炉
	2号炉	928	981	965	955	969	974	996	976	948	968	992	978	997	957	1012	992	987	940	936	907	930	964	928	923	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和4年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	984	992	1014	1033	1036	1042	1041	1035	1026	1023	1001	1004	1000	952	956	968	958	971	947	973	985	952	973	963	
	2号炉																									休炉
2	1号炉	962	989	962	1020	983	955	946	959	937	934	962	985	999	983	973	973	963	1030	999	973	1004	998	946	943	
	2号炉																									休炉
3	1号炉	941	981	985	956	967	957	964	952	957	989	1004	1015	926	953	956	925	932	959	938	924	911	969	953	987	
	2号炉																									休炉
4	1号炉	960	976	993	970	963	990	1010	1009	977	966	981	944	986	1010	1024	1004	980	988	981	993	997	944	937	896	
	2号炉											971	960	975	972	968	968	940	982	976	1010	1016	963	948		立上げ～定常運転
5	1号炉	896	933	978	998	985	978	1013	1018	997	962	946	980	987	971	935	967	936	935	945	949	991	997	939	975	
	2号炉	944	977	984	958	951	945	933	915	934	922	992	981	986	975	945	937	997	973	992	972	977	1009	1028	1016	
6	1号炉	964	963	954	962	960	947	963	985	889			1057	935	956	922	934	957	963	945	943	962	947	951		8:38～12:54給じん停止
	2号炉	985	970	938	977	951	960	995	1046	952	948	962	957	925	922	936	962	972	989	1021	989	992	958	961	946	
7	1号炉	951	957	980	981	958	980	985	921	940	964	965	989	951	936	950	932	956	952	967	993	954	971	968	955	
	2号炉	1011	1009	1041	1032	996	1015	1011	985	1011	993	980	981	961	970	975	964	958	962	1006	1011	1050	1059	1019	1000	
8	1号炉	960	940	1014	985	966	944	976	944	938	930	929	936	943	934	920	880	909	952	909	970	956	976	949	955	
	2号炉	1008	1042	1030	1016	1016	989	1022	951	956	972	966	955	963	964	976	928	917	970	983	995	1004	961	973	976	
9	1号炉	963	940	975	967	995	967	966	1011	984	985	970	979	952	982	957	949	982	965	989	1014	1015	949	1005	1013	
	2号炉	984	1008	1018	1032	987	1005	970	954	969	1015	993	1024	1005	960	960	966	946	958	997	960	1016	1002	989	1017	
10	1号炉	972	969	969	990	985	976	967	975	950	958	926	899	922	943	947	899	933	938	1007	987	948	976	960	946	
	2号炉	1008	1031	1014	989	988	989	1004	996	985	978	972	989	967	989	1011	1052	1047	1010	1055	1050	1022	1004	993	1034	
11	1号炉	959	985	1000	960	994	981	958		934	938	942	936	964	988	985	968	973	1027	980	963	955	965	982	1032	6:50～8:01給じん停止
	2号炉	1013	1035	1052	1063	1070	1050	1049	1076	1032	971	959	983	975	1035	1018	982	958	980	1038	1038	1104	1056	1043	1062	
12	1号炉	952	981	1019	976	954	961	968	955	942	964	974	992	942	965	975	968	974	954	984	971	986	1015	985	994	
	2号炉	1049	1007	1048	1042	1008	1036	1064	1061	979	992	1006	1007	1006	958	964	971	1033	1003	985	966	993	980	1008	1028	
13	1号炉	949	1030	989	969	962	973	949	956	953			929	879	882	920	902	923	924	934	934	968	940	971	987	8:48～11:04給じん停止
	2号炉	1040	1044	1079	1056	1031	1062	1057	1071	1048	975	987	965	944	949	949	949	953	940	1041	996	1024	1020	996	939	
14	1号炉	924	945	993	971	998	953	959	958	933	941	950	938	953	919	937	949	932	934	968	991	955	980	960	1006	
	2号炉	944	937	948	959	967	1003	988	996	906				897	939	922	917	904	1021	1010	1037	1000	996	998	1014	8:32～12:18給じん停止
15	1号炉	994	991	961	936	1002	1008	966	959	951	943	1012	964	989	1002	942	905	938	950	968	997	972	978	963	948	
	2号炉	984	983	989	953	980	970	981	965	964	959	975	957	965	969	963	963	960	958	978	988	994	957	1015	1039	

6月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	953	1004	1018	1004	988	1000	945	998	963	921	932	976	971	977	945	997	993	944	937	946	979	1017	956	981	
	2号炉	994	951	1006	1014	990	982	985	937	956	952	968	948	1007	1010	1001	976	986	961	979	961	953	1018	985	956	
17	1号炉	1007	1050	1021	1045	984	1019	991	981	974	953	967	974	972	948	916	975	973	953	1012	1009	985	950	973	968	
	2号炉	945	985	999	992	985	1008	970	972	978	1002	967	959	966	957	958	954	957	973	1010	1003	992	939	1018	1025	
18	1号炉	1017	993	986	1017	990	937	1040	1048	1020	1012	1023	999	983	985	988	972	1015	984	1011	1025	971	1000	1020	1015	
	2号炉	1003	972	953	954	976	965	936	957	975	1071	1025	999	981	985	992	997	1031	1008	998	967	966	980	957	1016	
19	1号炉	996	1000	1002	1039	994	988	990	997	993	1028	1034	999	983	980	955	967	998	1003	1022	1052	1018	982	1009	1015	
	2号炉	1018	1021	1006	1029	1006	990	966	938	949	951	959	963	986	968	974	958	974	1012	1011	982	1040	993	1008	997	
20	1号炉	989	987	1024	1029	1020	987	960	970	975	1004	988	974	996	996	985	997	988	982	955	971	975	976	993	955	
	2号炉	1062	1018	1008	1005	987	964	984	980	881			964	979	944	973	949	996	972	907	946	966	952	998	1018	8:34~11:42給じん停止
21	1号炉	985	1004	1001	1030	995	974	1006	1015	930					987	968	955	942	955	957	975	970	956	954	953	8:32~13:02給じん停止
	2号炉	992	974	967	1004	973	979	990	1014	968	967	972	967	961	975	971	972	974	974	1002	1014	1032	998	1022	1026	
22	1号炉	944	947	939	959	949	975	979	980	969	1007	962	970	963	1002	982	947	969	967	974	979	973	980	979	949	
	2号炉	994	952	970	953	966	976	996	1018	970	1025	1002	981	962	960	946	963	965	1004	1011	1003	955	955	965	958	
23	1号炉	941	952	985	972	978	1056	988	1023	1002	967	973	955	944	958	932	935	958	963	965	950	936	984	995	996	
	2号炉	958	964	982	981	964	973	954	939	958	973	968	960	961	961	954	949	960	959	958	994	985	1000	998	1007	
24	1号炉	1001	1008	1022	981	967	984	823							988	951	948	952	1014	985	954	972	992	990	953	6:05~13:06給じん停止
	2号炉	996	972	988	984	976	950	973	940	965	961	970	966	979	939	984	1013	958	943	978	963	961	954	992	1036	
25	1号炉	961	959	938	932	951	968	946	984	952	995	981	985	970	995	971	1023	986	977	983	1006	974	1009	997	979	
	2号炉	1010	989	989	965	951	939	971	996	946	985	980	997	969	989	963	929	935	948	941	965	1024	1029	1022	992	
26	1号炉	963	998	986	1008	997	1020	996	982	986	986	985	1006	1017	987	965	978	971	970	948	975	991	975	974	937	
	2号炉	1034	986	966	951	999	970	948	981	990	987	1044	1018	1035	970	970	1019	970	1024	1043	973	1003	994	1006	1020	
27	1号炉	929	997	963	968	969	968	967	967	967	961	971	938	936	935	973	958	966	966	1009	1001	987	989	978	965	
	2号炉	1007	987	990	973	998	1032	957	999	928			1035	973	989	973	952	960	969	1028	1017	1019	985	971	957	8:35~11:39給じん停止
28	1号炉	1002	989	1018	1019	1005	994	995	997	778			1012	976	962	1008	987	962	952	936	971	960	1014	1008	1025	8:06~11:06給じん停止
	2号炉	963	976	950	946	969	987	962	976	751		934	935	925	986	919	930	926	933	952	926	937	989	970	949	8:06~10:00給じん停止
29	1号炉	1001	1096	1019	1020	1004	1013	996	1026	919				994	944	954	978	1005	973	969	984	976	981	989	989	8:31~12:22給じん停止
	2号炉	916	976	1019	1016	996	1002	980	981	967	956	976	971	932	967	952	950	943	954	934	957	949	927	987	960	
30	1号炉	968	986	998	992	972	987	1034	999	1007	980	907	982	951	953	972	963	972	961	958	966	968	954	987	993	
	2号炉	996	978	997	972	989	984	1015	1021	972	980	971	943	954	938	941	946	935	925	923	919	935	990	998	997	

