

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

4月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	1.99	0.00	0.50	22	0	2.5	58	0	32.0	0	0	0	8	0	3.0	10.75	0.00	2.80
2	1.10	0.00	0.30	35	0	2.5	50	8	35.0	0	0	0	8	1	4.5	13.75	0.00	2.91
3	1.02	0.00	0.41	25	0	2.5	55	22	39.0	0	0	0	8	2	4.5	12.00	0.00	2.02
4	1.12	0.00	0.45	5	0	0.5	58	19	35.5	0	0	0	7	2	3.5	2.75	0.00	0.27
5	1.10	0.00	0.41	5	0	0.5	49	28	34.5	0	0	0	7	1	3.5	2.00	0.00	0.34
6	1.51	0.00	0.51	5	0	0.0	52	0	35.5	0	0	0	6	0	3.0	1.75	0.00	0.31
7	1.65	0.00	0.57	6	0	0.5	49	2	37.0	0	0	0	6	0	3.5	2.75	0.00	0.59
8	2.01	0.00	0.73	15	0	0.5	58	28	41.5	0	0	0	5	2	3.0	7.00	0.00	0.73
9	1.29	0.00	0.55	5	0	0.5	56	19	33.0	0	0	0	6	1	3.5	1.75	0.00	0.35
10	1.52	0.00	0.49	13	0	1.0	61	23	39.5	0	0	0	7	1	3.5	6.25	0.00	1.12
11	1.42	0.00	0.51	19	0	1.5	57	12	37.0	0	0	0	7	1	3.0	6.50	0.00	1.52
12	2.17	0.00	0.66	11	0	1.5	56	1	36.5	0	0	0	7	0	3.5	6.75	0.00	1.35
13	2.24	0.00	0.56	57	0	4.0	61	0	32.5	0	0	0	7	0	3.0	29.75	0.00	3.66
14	2.70	0.00	0.69	31	0	4.5	59	7	34.0	0	0	0	5	0	2.0	23.75	0.00	5.44
15	1.76	0.00	0.69	17	0	1.5	56	7	38.0	0	0	0	7	0	2.0	8.75	0.00	1.14
16	1.51	0.00	0.51	24	0	3.0	57	21	39.5	0	0	0	6	1	3.5	12.50	0.00	2.73
17	1.41	0.00	0.53	22	0	3.5	60	0	36.0	0	0	0	8	0	4.5	11.50	0.00	3.39
18	3.02	0.00	0.68	12	0	1.5	63	0	38.5	0	0	0	8	0	3.0	5.25	0.50	1.39
19	4.84	0.00	1.15	10	0	1.5	55	4	37.0	0	0	0	5	1	2.5	6.25	0.00	1.30
20	2.62	0.00	0.99	21	0	1.5	56	2	34.5	0	0	0	4	0	2.5	10.75	0.00	1.56
21	5.79	0.00	1.08	26	0	2.0	61	0	34.0	1	0	0	27	0	4.0	16.75	0.00	2.66
22	2.26	0.00	0.73	9	0	1.0	58	0	37.0	0	0	0	4	0	3.0	3.75	0.00	0.93
23	2.62	0.00	0.92	25	0	2.0	58	22	39.5	9	0	0.5	7	2	3.0	11.75	0.00	2.46
24	3.00	0.00	1.07	33	0	3.0	61	26	42.5	0	0	0	9	2	3.5	13.75	0.00	3.07
25	2.82	0.00	1.07	17	0	1.0	57	20	40.0	0	0	0	7	2	3.5	7.75	0.00	1.27
26	3.07	0.00	1.28	21	0	1.0	57	4	38.5	0	0	0	4	1	2.0	9.00	0.00	1.25
27	2.81	0.00	0.95	28	0	4.0	59	18	39.0	0	0	0	6	1	3.0	13.00	0.00	3.94
28	3.27	0.00	0.97	42	0	3.5	62	0	41.5	0	0	0	6	0	3.0	16.00	0.00	3.12
29	2.68	0.00	1.03	13	0	1.5	59	14	39.5	0	0	0	7	2	3.5	16.75	0.00	2.28
30	2.27	0.00	0.95	14	0	1.0	59	21	40.5	0	0	0	6	2	3.5	8.25	0.00	1.01

※ 硫黄酸化物濃度について、令和3年8月13日以降の数値は2号炉での計測器不具合により1号炉のみの数値となっています

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

5月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	2.53	0.00	1.02	7	0	1.0	59	15	35.0	0	0	0	6	2	3.5	2.75	0.00	0.55
2	3.29	0.00	0.97	19	0	2.0	57	1	35.0	0	0	0	7	0	3.5	6.25	0.00	1.53
3	2.76	0.00	0.99	48	0	2.5	58	19	37.5	0	0	0	5	2	3.0	22.50	0.00	3.13
4	2.79	0.00	1.02	19	0	1.0	60	26	40.5	0	0	0	3	2	2.5	7.00	0.00	1.23
5	2.36	0.00	0.79	30	0	1.5	59	2	34.5	0	0	0	3	0	2.0	13.25	0.00	1.56
6	3.91	0.00	1.32	2	0	0.0	42	9	33.5	0	0	0	5	0	2.0	3.00	0.00	0.58
7	2.68	1.29	2.05	0	0	0.0	32	11	25.0	0	0	0	13	3	5.0	0.00	0.00	0.00
8	3.62	1.21	2.54	4	0	0.0	51	17	30.0	0	0	0	5	3	3.0	1.50	0.00	0.25
9	3.66	1.56	2.79	0	0	0.0	52	26	43.0	0	0	0	4	2	3.0	0.00	0.00	0.00
10	3.25	1.08	2.44	0	0	0.0	40	21	33.0	0	0	0	7	2	3.0	0.00	0.00	0.00
11	2.68	0.33	2.03	15	0	2.0	50	4	33.0	0	0	0	7	2	4.0	8.75	0.00	1.79
12	4.68	0.53	2.71	18	0	3.0	48	1	31.0	0	0	0	5	1	4.0	9.00	0.00	2.60
13	3.85	1.35	2.69	26	0	2.0	42	17	27.0	0	0	0	6	2	4.0	10.75	0.00	2.95
14	2.98	0.91	2.10	18	0	2.0	47	19	39.0	0	0	0	7	2	4.0	5.50	0.00	1.54
15	3.04	0.71	1.81	35	0	4.0	38	10	26.0	0	0	0	10	4	7.0	19.00	0.00	4.69
16	3.36	0.89	2.38	7	0	1.0	42	27	38.0	0	0	0	6	2	4.0	2.00	0.00	0.60
17	3.22	0.00	1.21	37	0	6.0	49	3	27.5	0	0	0	8	0	3.5	21.50	2.75	5.99
18	2.66	0.00	0.90	24	0	5.5	52	5	37.5	0	0	0	9	0	4.5	17.00	0.00	6.11
19	3.33	0.00	1.14	30	0	4.5	65	13	41.5	0	0	0	8	1	3.5	21.25	0.00	4.81
20	4.40	0.00	1.37	36	0	3.5	60	0	34.0	0	0	0	42	0	4.0	21.50	0.00	3.68
21	4.07	0.00	1.45	48	0	3.0	59	1	34.0	0	0	0	5	0	2.5	26.75	0.00	3.00
22	3.38	0.00	1.40	18	0	2.5	47	7	31.0	0	0	0	6	2	3.5	11.00	0.00	2.17
23	4.61	0.00	1.56	11	0	1.5	55	0	36.5	0	0	0	7	0	2.5	6.75	0.00	2.02
24	3.75	0.00	1.60	8	0	0.5	61	14	38.5	0	0	0	4	2	2.5	2.75	0.00	0.51
25	3.17	0.00	1.34	19	0	1.5	58	23	38.5	0	0	0	5	1	2.5	9.25	0.00	1.45
26	3.78	0.00	1.29	11	0	1.0	61	11	37.0	0	0	0	5	1	2.5	7.25	0.00	0.78
27	3.09	0.00	1.38	15	0	1.0	57	10	36.5	0	0	0	3	0	2.0	9.25	0.00	1.23
28	0.02	0.00	0.00	15	0	2.0	69	34	46.0	0	0	0	2	1	1.0	7.50	0.00	1.17
29	0.02	0.00	0.00	4	0	1.0	57	42	49.0	0	0	0	6	1	2.0	7.25	0.00	1.28
30	0.03	0.00	0.00	18	0	2.0	59	2	43.0	0	0	0	2	0	2.0	7.25	0.00	1.08
31	0.02	0.00	0.00	14	0	2.0	61	25	47.0	0	0	0	3	1	2.0	10.50	0.00	3.00

※ 硫黄酸化物濃度について、令和3年8月13日以降の数値は2号炉での計測器不具合により1号炉のみの数値となっています

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

6月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.02	0.00	0.00	4	0	1.0	63	37	49.0	0	0	0	3	1	2.0	2.00	0.00	0.50
2	0.03	0.00	0.00	9	0	1.0	58	35	47.0	0	0	0	2	1	2.0	4.50	0.00	0.84
3	0.02	0.00	0.00	4	0	1.0	60	36	52.0	0	0	0	2	1	2.0	2.00	0.00	0.60
4	0.53	0.00	0.21	10	0	1.5	65	0	40.5	0	0	0	5	0	3.0	4.00	0.25	1.43
5	0.56	0.00	0.23	27	0	2.5	61	6	42.5	0	0	0	9	0	4.0	16.50	0.00	2.49
6	0.60	0.00	0.23	20	0	2.0	62	0	39.5	0	0	0	7	0	3.0	9.75	0.00	2.35
7	0.51	0.00	0.22	20	0	1.0	59	34	43.0	0	0	0	5	1	2.5	6.75	0.00	1.07
8	0.47	0.00	0.19	23	0	1.5	62	11	38.0	0	0	0	5	1	2.5	8.50	0.00	1.19
9	0.50	0.00	0.22	14	0	1.0	63	29	43.5	0	0	0	4	1	2.5	6.25	0.00	0.81
10	0.55	0.00	0.24	15	0	0.5	59	28	44.5	0	0	0	4	1	2.5	4.50	0.00	0.66
11	0.50	0.00	0.23	27	0	2.5	64	26	44.5	0	0	0	11	1	3.5	13.00	0.00	2.70
12	0.50	0.00	0.23	10	0	1.0	63	28	43.5	0	0	0	7	1	3.5	3.25	0.00	0.85
13	0.44	0.00	0.20	19	0	1.0	61	16	40.5	0	0	0	7	1	3.0	5.75	0.00	1.37
14	0.47	0.00	0.19	22	0	2.0	60	5	42.5	0	0	0	6	0	2.0	7.00	0.00	2.01
15	0.50	0.00	0.22	18	0	2.0	65	31	44.5	0	0	0	4	1	2.0	7.50	0.00	1.65
16	0.54	0.00	0.24	17	0	2.0	60	28	42.0	0	0	0	4	1	2.0	8.00	0.00	1.75
17	0.60	0.00	0.25	10	0	1.5	60	30	40.5	0	0	0	6	1	2.0	6.50	0.00	1.17
18	0.58	0.00	0.26	7	0	1.0	54	27	38.0	0	0	0	4	1	2.0	3.00	0.00	0.78
19	0.60	0.00	0.25	17	0	1.0	61	30	43.0	0	0	0	6	1	2.5	6.75	0.00	1.10
20	0.55	0.00	0.23	6	0	0.5	63	0	43.0	0	0	0	4	0	1.5	2.75	0.00	0.38
21	0.50	0.00	0.25	16	0	0.5	61	17	40.0	0	0	0	6	0	3.0	6.00	0.00	0.79
22	0.58	0.00	0.26	35	0	3.0	56	26	40.5	0	0	0	4	1	2.5	12.75	0.00	2.76
23	0.60	0.00	0.28	11	0	1.0	58	24	40.0	0	0	0	4	1	2.5	5.50	0.00	0.91
24	0.60	0.00	0.29	18	0	2.0	50	3	36.5	1	0	0	4	0	2.5	7.25	0.00	1.61
25	0.60	0.00	0.27	20	0	3.0	63	30	41.5	0	0	0	4	1	2.5	8.25	0.00	2.64
26	0.60	0.00	0.27	16	0	1.0	64	33	46.5	0	0	0	5	1	3.0	11.75	0.00	1.10
27	0.60	0.00	0.24	8	0	0.5	57	0	41.5	0	0	0	4	0	2.5	5.50	0.00	0.78
28	1.01	0.00	0.28	19	0	0.5	57	1	37.5	0	0	0	4	0	1.5	4.75	0.00	0.76
29	0.60	0.00	0.27	14	0	1.5	63	11	38.0	0	0	0	3	0	2.5	5.00	0.00	1.37
30	0.60	0.00	0.29	18	0	2.0	56	22	40.5	0	0	0	5	1	3.0	8.25	0.00	1.97

※ 硫黄酸化物濃度について、2号炉での計測器不具合は6月13日に復旧しました

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

7月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.65	0.00	0.27	6	0	0.0	59	0	37.5	0	0	0	4	0	2.5	2.75	0.00	0.34
2	0.60	0.00	0.28	13	0	2.5	63	21	36.5	0	0	0	7	1	3.5	5.25	0.00	2.19
3	0.58	0.00	0.27	32	0	3.0	59	2	40.5	0	0	0	7	1	3.5	10.75	0.00	3.14
4	0.50	0.00	0.23	24	0	1.0	58	4	37.5	0	0	0	5	0	2.5	6.00	0.00	0.74
5	0.55	0.00	0.25	6	0	0.5	57	22	39.0	0	0	0	5	1	2.5	7.50	0.00	0.73
6	0.60	0.00	0.28	9	0	0.5	54	26	38.5	0	0	0	3	1	2.0	4.50	0.00	0.48
7	0.60	0.00	0.27	5	0	0.0	56	28	39.5	0	0	0	3	1	2.0	2.00	0.00	0.32
8	0.60	0.00	0.27	6	0	0.0	64	2	39.5	0	0	0	3	0	2.0	2.50	0.00	0.21
9	0.55	0.00	0.29	14	0	1.0	57	23	38.0	0	0	0	4	1	2.0	7.00	0.00	1.40
10	0.60	0.06	0.32	5	0	0.5	62	32	43.0	0	0	0	4	1	2.5	2.00	0.00	0.64
11	0.64	0.01	0.31	12	0	0.5	66	0	41.0	0	0	0	4	0	2.0	5.25	0.00	0.81
12	0.60	0.08	0.36	4	0	0.0	61	30	44.0	0	0	0	3	1	2.0	1.25	0.00	0.21
13	0.55	0.01	0.33	24	0	1.0	55	2	40.0	0	0	0	3	0	2.0	6.00	0.00	0.64
14	0.53	0.06	0.29	6	0	0.5	56	5	38.5	0	0	0	4	0	2.0	4.50	0.00	0.80
15	0.57	0.00	0.31	15	0	1.0	51	0	34.5	0	0	0	3	0	1.5	4.25	0.00	1.00
16	0.50	0.23	0.42	1	0	0.0	39	33	36.0	0	0	0	4	1	3.0	0.25	0.00	0.04
17	0.50	0.23	0.43	13	0	1.0	51	29	39.0	0	0	0	3	2	3.0	5.50	0.00	0.92
18	0.50	0.25	0.45	0	0	0.0	42	33	38.0	0	0	0	3	2	2.0	0.00	0.00	0.00
19	0.50	0.05	0.42	1	0	0.0	40	2	34.0	0	0	0	4	0	3.0	0.25	0.00	0.05
20	0.50	0.24	0.45	1	0	0.0	37	27	34.0	0	0	0	4	2	2.0	0.25	0.00	0.04
21	0.50	0.24	0.45	15	0	3.0	38	28	33.0	0	0	0	5	1	3.0	8.25	0.00	1.76
22	0.50	0.23	0.42	3	0	0.0	39	30	36.0	0	0	0	2	1	2.0	7.50	0.00	0.83
23	0.40	0.21	0.37	9	0	1.0	39	29	34.0	0	0	0	3	2	3.0	3.50	0.00	0.96
24	0.50	0.18	0.36	5	0	0.0	39	31	36.0	0	0	0	3	2	2.0	4.50	0.00	0.82
25	0.55	0.23	0.45	6	0	0.0	40	34	37.0	0	0	0	3	2	3.0	1.75	0.00	0.21
26	0.60	0.01	0.27	16	0	2.0	52	0	34.0	0	0	0	3	0	2.0	4.75	0.00	1.86
27	0.60	0.00	0.28	21	0	3.0	55	32	40.5	0	0	0	3	1	2.5	11.00	0.00	3.38
28	0.60	0.00	0.29	32	0	4.5	66	6	40.5	0	0	0	3	0	1.5	17.75	0.00	4.84
29	0.65	0.00	0.32	19	0	3.0	62	13	41.5	0	0	0	3	0	2.0	13.25	0.00	2.85
30	0.60	0.05	0.32	18	0	2.5	58	27	40.5	0	0	0	3	2	2.5	15.50	0.00	2.55
31	0.60	0.05	0.30	10	0	1.5	57	9	39.0	0	0	0	3	1	2.5	5.75	0.00	1.69

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

8月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.61	0.02	0.32	18	0	2.5	60	30	41.0	0	0	0	3	1	2.5	8.50	0.25	2.18
2	0.60	0.00	0.30	33	0	2.0	57	0	38.0	1	0	0	3	0	2.5	10.25	0.00	1.54
3	0.65	0.01	0.30	31	0	4.5	66	0	35.5	1	0	0	3	0	2.0	18.00	0.00	3.61
4	0.60	0.00	0.32	30	0	3.0	55	0	36.0	0	0	0	4	0	3.0	14.00	0.00	3.54
5	0.55	0.03	0.29	20	0	2.5	58	1	37.0	0	0	0	3	0	2.5	10.75	0.00	2.43
6	0.24	0.04	0.12	15	0	4.0	58	32	43.0	0	0	0	4	2	3.0	11.00	0.00	3.88
7	0.30	0.03	0.14	30	0	5.0	61	26	44.0	0	0	0	3	2	3.0	12.25	0.00	5.03
8	0.40	0.11	0.20	34	0	6.0	63	28	47.0	0	0	0	4	2	3.0	17.75	0.00	6.45
9	0.30	0.07	0.18	5	0	1.0	63	32	48.0	0	0	0	3	2	3.0	3.25	0.00	1.14
10	0.27	0.02	0.17	12	0	2.0	63	5	46.0	0	0	0	3	0	2.0	5.50	0.00	2.09
11	0.57	0.08	0.20	8	0	1.0	65	10	45.0	0	0	0	3	0	2.0	1.75	0.00	0.69
12	0.44	0.06	0.23	30	0	9.0	60	6	46.0	0	0	0	3	0	1.0	21.50	3.25	9.02
13	0.64	0.12	0.31	22	0	3.0	65	27	51.0	0	0	0	3	2	2.0	8.50	0.00	2.96
14	0.37	0.12	0.24	22	0	6.0	56	31	45.0	0	0	0	2	1	2.0	13.25	0.25	5.25
15	0.32	0.00	0.21	11	0	2.0	56	0	37.0	0	0	0	3	0	2.0	15.25	0.00	2.99
16	0.35	0.08	0.20	17	0	1.0	61	36	48.0	0	0	0	3	1	2.0	6.75	0.00	1.29
17	0.59	0.10	0.33	22	0	5.0	65	8	39.5	0	0	0	2	0	1.5	15.25	0.00	4.74
18	0.60	0.00	0.35	36	0	3.0	60	0	41.5	0	0	0	2	0	1.5	14.00	0.00	3.32
19	0.60	0.10	0.37	24	0	3.5	65	31	44.5	0	0	0	3	1	2.5	13.50	0.00	3.40
20	0.60	0.17	0.42	12	0	1.5	60	26	41.5	0	0	0	3	1	2.0	8.50	0.00	1.95
21	0.61	0.12	0.40	24	0	2.0	64	23	41.5	0	0	0	3	1	2.5	8.00	0.00	1.89
22	0.65	0.08	0.40	15	0	0.5	61	21	43.0	0	0	0	3	1	2.0	5.50	0.00	0.70
23	0.65	0.14	0.40	7	0	0.5	65	21	43.5	0	0	0	2	1	2.0	2.25	0.00	0.41
24	0.60	0.01	0.36	31	0	4.0	70	1	40.0	0	0	0	4	0	2.5	11.25	0.00	3.74
25	0.61	0.00	0.38	10	0	1.5	62	6	41.5	0	0	0	3	0	2.5	7.75	0.00	2.01
26	0.60	0.13	0.39	7	0	0.5	57	27	41.5	0	0	0	3	1	2.0	2.25	0.00	0.48
27	0.60	0.18	0.40	21	0	2.0	54	26	41.0	0	0	0	3	0	2.0	7.75	0.00	1.78
28	0.71	0.13	0.38	24	0	2.5	56	4	40.0	1	0	0	3	0	2.5	13.00	0.00	2.43
29	0.60	0.09	0.34	23	0	2.0	58	27	40.5	0	0	0	3	2	2.5	10.50	0.00	2.06
30	0.58	0.05	0.39	26	0	3.0	67	25	42.5	0	0	0	3	1	2.5	12.25	0.00	2.75
31	0.60	0.08	0.38	24	0	3.0	62	3	38.0	0	0	0	4	0	2.5	8.75	0.00	3.09

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

9月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.80	0.18	0.47	24	0	2.5	58	30	41.5	0	0	0	3	1	2.5	8.50	0.00	2.09
2	0.62	0.00	0.41	17	0	2.0	54	3	37.0	0	0	0	3	0	2.5	8.50	0.25	1.97
3	0.60	0.05	0.43	27	0	3.5	61	8	39.0	0	0	0	3	1	2.5	13.75	0.00	2.89
4	0.71	0.04	0.42	17	0	2.0	61	1	37.0	0	0	0	3	0	2.5	15.75	0.00	2.37
5	0.70	0.20	0.49	4	0	0.5	66	33	44.0	0	0	0	4	1	3.0	7.00	0.00	0.62
6	0.61	0.10	0.46	4	0	0.5	58	27	40.0	0	0	0	4	1	2.5	2.00	0.00	0.30
7	0.55	0.02	0.39	10	0	1.0	62	0	37.5	0	0	0	3	0	2.0	2.75	0.00	0.79
8	1.16	0.06	0.42	22	0	2.0	61	4	40.5	0	0	0	4	0	2.5	9.50	0.00	2.40
9	1.08	0.21	0.56	15	0	1.5	64	28	41.5	0	0	0	4	1	2.5	6.00	0.00	1.55
10	1.09	0.29	0.63	5	0	0.5	57	31	43.5	0	0	0	3	1	2.5	3.50	0.00	0.49
11	0.90	0.02	0.49	19	0	2.0	56	9	38.0	0	0	0	3	0	2.0	8.25	0.00	1.79
12	0.65	0.24	0.48	7	0	0.5	58	25	40.5	0	0	0	3	1	2.0	4.25	0.00	0.76
13	0.69	0.01	0.45	26	0	2.5	60	1	37.0	0	0	0	3	0	2.0	11.00	0.00	2.11
14	1.84	0.00	0.67	26	0	5.0	56	0	34.5	0	0	0	6	0	2.5	16.50	0.00	5.50
15	1.48	0.30	0.78	18	0	2.5	59	6	34.0	0	0	0	6	1	3.0	10.50	0.00	2.67
16	1.78	0.04	0.85	25	0	1.0	63	1	37.0	0	0	0	6	0	3.0	6.75	0.00	1.30
17	1.72	0.19	0.85	9	0	1.0	58	12	37.0	0	0	0	7	0	3.0	3.75	0.00	0.86
18	1.26	0.30	0.70	27	0	2.5	51	28	38.0	0	0	0	6	1	3.5	13.00	0.00	2.53
19	1.61	0.00	0.64	11	0	0.5	47	0	34.5	0	0	0	4	0	2.5	10.50	0.00	1.06
20	1.17	0.29	0.58	7	0	0.5	62	18	38.0	0	0	0	4	2	3.0	3.25	0.00	0.52
21	0.99	0.03	0.46	19	0	3.0	52	2	36.0	0	0	0	6	0	3.0	9.25	0.00	2.88
22	0.61	0.24	0.41	14	0	0.5	51	25	37.5	0	0	0	6	2	3.5	6.75	0.00	1.16
23	0.51	0.21	0.41	2	0	0.0	52	31	40.0	0	0	0	3	2	3.0	4.75	0.00	0.68
24	0.48	0.27	0.40	1	0	0.0	43	25	36.0	0	0	0	2	1	2.0	0.50	0.00	0.08
25	0.35	0.20	0.27	1	0	0.0	41	9	34.0	0	0	0	2	1	2.0	0.75	0.00	0.13
26	0.46	0.02	0.33	8	0	1.0	46	3	36.0	0	0	0	4	0	2.0	3.75	0.00	0.89
27	0.48	0.24	0.39	9	0	1.0	49	33	39.0	0	0	0	4	2	3.0	3.75	0.00	0.63
28	0.46	0.24	0.39	2	0	0.0	44	28	38.0	0	0	0	4	2	3.0	0.50	0.00	0.13
29	0.40	0.09	0.33	17	0	1.0	41	7	36.0	0	0	0	4	1	3.0	6.50	0.00	1.13
30	0.45	0.23	0.36	2	0	0.0	43	18	36.0	0	0	0	4	2	3.0	0.75	0.00	0.21