

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

10月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 管理値: 100ppm以下 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下			一酸化炭素濃度(ppm) 管理値: 30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.45	0.21	0.35	5	0	0.0	46	30	38.0	0	0	0	5	2	3.0	2.00	0.00	0.41
2	0.36	0.13	0.28	8	0	1.0	42	10	33.0	0	0	0	4	1	3.0	3.50	0.00	0.76
3	0.43	0.14	0.34	7	0	0.0	42	29	36.0	0	0	0	5	2	4.0	2.50	0.00	0.34
4	0.50	0.09	0.37	1	0	0.0	36	5	30.0	0	0	0	5	1	4.0	1.75	0.00	0.28
5	0.47	0.20	0.34	13	0	1.0	38	28	32.0	0	0	0	7	2	4.0	3.75	0.00	0.66
6	0.30	0.16	0.25	1	0	0.0	43	30	36.0	0	0	0	7	3	5.0	0.50	0.00	0.14
7	0.31	0.12	0.22	1	0	0.0	40	29	36.0	0	0	0	5	3	4.0	0.25	0.00	0.04
8	0.25	0.09	0.20	2	0	0.0	46	12	35.0	0	0	0	6	2	4.0	0.50	0.00	0.10
9	0.30	0.11	0.22	17	0	1.0	44	26	35.0	0	0	0	6	3	5.0	6.25	0.00	1.13
10	0.34	0.14	0.27	1	0	0.0	54	15	35.0	0	0	0	7	3	5.0	0.50	0.00	0.08
11	0.20	0.00	0.17	0	0	0.0	46	0	34.0	0	0	0	8	0	3.0	0.00	0.00	0.00
12	0.28	0.14	0.21	0	0	0.0	39	22	33.0	0	0	0	4	1	2.0	0.00	0.00	0.00
13	0.48	0.06	0.30	12	0	1.0	40	6	33.0	0	0	0	5	1	3.0	5.50	0.00	0.92
14	0.45	0.27	0.35	0	0	0.0	52	20	37.0	0	0	0	4	2	2.0	0.00	0.00	0.00
15	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22	0.89	0.00	0.67	1	0	0.0	33	0	27.0	0	0	0	2	0	1.0	0.50	0.00	0.16
23	0.94	0.48	0.75	8	0	1.0	43	24	33.0	0	0	0	3	1	2.0	4.00	0.00	1.19
24	0.75	0.38	0.63	4	0	0.0	46	23	35.0	0	0	0	4	1	3.0	1.75	0.00	0.35
25	0.64	0.36	0.56	8	0	1.0	52	28	39.0	0	0	0	3	2	2.0	3.25	0.00	0.58
26	0.63	0.36	0.57	0	0	0.0	57	24	40.0	0	0	0	3	1	3.0	0.00	0.00	0.00
27	0.65	0.03	0.52	1	0	0.0	52	2	37.0	0	0	0	4	0	3.0	0.50	0.00	0.10
28	0.64	0.33	0.55	12	0	1.0	59	25	40.0	0	0	0	3	2	3.0	3.25	0.00	0.75
29	0.70	0.4	0.53	0	0	0.0	54	30	40.0	0	0	0	3	2	3.0	0.00	0.00	0.00
30	0.57	0.20	0.44	2	0	0.0	65	19	45.0	0	0	0	4	1	3.0	1.00	0.00	0.19
31	0.59	0.01	0.47	10	0	1.0	59	0	44.0	0	0	0	4	0	3.0	2.75	0.00	0.57

