

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

10月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 管理値: 100ppm以下 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下			一酸化炭素濃度(ppm) 管理値: 30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.45	0.21	0.35	5	0	0.0	46	30	38.0	0	0	0	5	2	3.0	2.00	0.00	0.41
2	0.36	0.13	0.28	8	0	1.0	42	10	33.0	0	0	0	4	1	3.0	3.50	0.00	0.76
3	0.43	0.14	0.34	7	0	0.0	42	29	36.0	0	0	0	5	2	4.0	2.50	0.00	0.34
4	0.50	0.09	0.37	1	0	0.0	36	5	30.0	0	0	0	5	1	4.0	1.75	0.00	0.28
5	0.47	0.20	0.34	13	0	1.0	38	28	32.0	0	0	0	7	2	4.0	3.75	0.00	0.66
6	0.30	0.16	0.25	1	0	0.0	43	30	36.0	0	0	0	7	3	5.0	0.50	0.00	0.14
7	0.31	0.12	0.22	1	0	0.0	40	29	36.0	0	0	0	5	3	4.0	0.25	0.00	0.04
8	0.25	0.00	0.20	2	0	0.0	46	0	34.0	0	0	0	6	0	4.0	0.50	0.00	0.08
9	0.30	0.11	0.22	17	0	1.0	44	26	35.0	0	0	0	6	3	5.0	6.25	0.00	1.13
10	0.34	0.14	0.27	1	0	0.0	54	15	35.0	0	0	0	7	3	5.0	0.50	0.00	0.08
11	0.20	0.00	0.17	0	0	0.0	46	0	34.0	0	0	0	8	0	3.0	0.00	0.00	0.00
12	0.28	0.14	0.21	0	0	0.0	39	22	33.0	0	0	0	4	1	2.0	0.00	0.00	0.00
13	0.48	0.06	0.30	12	0	1.0	40	6	33.0	0	0	0	5	1	3.0	5.50	0.00	0.92
14	0.45	0.27	0.35	0	0	0.0	52	20	37.0	0	0	0	4	2	2.0	0.00	0.00	0.00
15	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
17	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
18	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
19	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
20	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
21	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
22	0.89	0.00	0.67	1	0	0.0	33	0	27.0	0	0	0	2	0	1.0	0.50	0.00	0.16
23	0.94	0.48	0.75	8	0	1.0	43	24	33.0	0	0	0	3	1	2.0	4.00	0.00	1.19
24	0.75	0.38	0.63	4	0	0.0	46	23	35.0	0	0	0	4	1	3.0	1.75	0.00	0.35
25	0.64	0.36	0.56	8	0	1.0	52	28	39.0	0	0	0	3	2	2.0	3.25	0.00	0.58
26	0.63	0.36	0.57	0	0	0.0	57	24	40.0	0	0	0	3	1	3.0	0.00	0.00	0.00
27	0.65	0.03	0.52	1	0	0.0	52	2	37.0	0	0	0	4	0	3.0	0.50	0.00	0.10
28	0.64	0.33	0.55	12	0	1.0	59	25	40.0	0	0	0	3	2	3.0	3.25	0.00	0.75
29	0.70	0.4	0.53	0	0	0.0	54	30	40.0	0	0	0	3	2	3.0	0.00	0.00	0.00
30	0.57	0.20	0.44	2	0	0.0	65	19	45.0	0	0	0	4	1	3.0	1.00	0.00	0.19
31	0.59	0.01	0.47	10	0	1.0	59	0	44.0	0	0	0	4	0	3.0	2.75	0.00	0.57

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

11月	ばいじん濃度(mg/Nm3) 管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値: 100ppm以下 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下			一酸化炭素濃度(ppm) 管理値: 30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.65	0.05	0.51	2	0	0.0	62	6	40.0	0	0	0	6	0	3.0	2.75	0.00	0.36
2	0.70	0.10	0.46	18	0	1.0	58	7	45.0	0	0	0	3	0	2.0	5.25	0.00	1.34
3	0.55	0.03	0.43	10	0	2.0	50	2	37.0	0	0	0	3	0	2.0	5.75	0.00	1.91
4	0.65	0.36	0.52	13	0	1.0	58	28	41.0	0	0	0	4	2	3.0	4.25	0.00	1.14
5	0.57	0.00	0.30	22	0	5.0	45	1	27.5	0	0	0	5	0	2.5	2.50	0.00	0.45
6	0.64	0.02	0.31	27	0	2.0	53	9	38.5	0	0	0	7	1	4.0	12.75	0.00	1.60
7	0.63	0.00	0.32	9	0	2.0	61	1	40.5	0	0	0	5	0	3.0	13.75	0.00	2.72
8	0.70	0.35	0.60	0	0	0.0	54	29	38.0	0	0	0	4	2	3.0	0.00	0.00	0.00
9	0.69	0.36	0.59	4	0	0.0	59	31	41.0	0	0	0	4	2	4.0	1.50	0.00	0.25
10	0.60	0.00	0.26	8	0	1.0	58	0	35.5	0	0	0	5	0	3.5	3.00	0.00	0.59
11	0.73	0.00	0.35	17	0	1.5	52	23	38.0	0	0	0	6	2	4.0	7.25	0.00	1.62
12	0.81	0.00	0.42	34	0	1.0	60	31	39.5	0	0	0	6	2	4.0	11.75	0.00	1.38
13	0.86	0.05	0.40	13	0	1.5	62	30	43.0	0	0	0	6	2	3.5	6.75	0.00	1.40
14	0.73	0.00	0.30	10	0	1.0	48	0	34.5	0	0	0	4	0	3.5	6.00	0.00	1.14
15	0.69	0.00	0.29	16	0	2.0	58	4	37.5	0	0	0	5	1	3.5	9.25	0.00	1.95
16	0.65	0.00	0.29	16	0	1.5	52	1	34.0	0	0	0	6	0	4.0	7.00	0.00	1.73
17	0.91	0.00	0.31	8	0	0.5	59	8	40.0	0	0	0	5	1	3.5	4.25	0.00	0.60
18	0.75	0.00	0.31	10	0	0.5	56	4	36.5	0	0	0	4	0	2.0	4.00	0.00	0.75
19	0.79	0.02	0.40	9	0	0.5	52	17	34.0	0	0	0	3	1	3.0	2.50	0.00	0.48
20	0.71	0.09	0.41	12	0	2.0	61	30	43.0	0	0	0	4	1	2.5	8.00	0.00	2.02
21	0.76	0.03	0.38	25	0	1.0	59	2	39.0	0	0	0	4	0	3.0	7.25	0.00	0.79
22	0.73	0.02	0.36	16	0	1.5	59	27	41.5	0	0	0	4	2	3.0	9.75	0.00	1.59
23	0.80	0.06	0.43	8	0	0.5	54	22	39.5	0	0	0	4	2	3.0	4.25	0.00	0.43
24	0.78	0.00	0.39	12	0	1.0	55	3	39.0	0	0	0	4	0	3.0	4.75	0.00	0.59
25	0.94	0.02	0.40	23	0	2.0	58	1	41.0	0	0	0	4	0	2.5	11.50	0.00	2.20
26	1.05	0.06	0.52	10	0	1.0	58	22	37.5	0	0	0	4	2	3.0	6.75	0.00	1.06
27	0.86	0.09	0.47	6	0	0.5	62	25	41.0	0	0	0	4	2	3.0	2.50	0.00	0.35
28	0.99	0.11	0.51	5	0	0.0	57	20	40.0	0	0	0	4	2	3.0	1.50	0.00	0.21
29	1.25	0.11	0.58	8	0	1.0	60	24	41.5	0	0	0	5	2	3.0	3.00	0.00	1.02
30	0.89	0.10	0.57	10	0	1.0	56	36	45.5	0	0	0	5	2	3.0	5.75	0.00	1.25

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

1月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6	1.28	0.06	0.90	17	0	3.0	34	4	27.0	0	0	0	3	0	1.0	5.75	0.00	3.18
7	1.72	0.38	1.22	6	0	1.0	38	9	30.0	0	0	0	3	1	2.0	2.50	0.00	0.63
8	1.06	0.65	0.92	3	0	0.0	40	24	33.0	0	0	0	3	2	2.0	0.75	0.00	0.09
9	1.11	0.61	0.87	0	0	0.0	47	29	36.0	0	0	0	3	2	2.0	0.75	0.00	0.03
10	1.11	0.21	0.80	5	0	0.0	43	10	35.0	0	0	0	8	0	4.0	2.00	0.00	0.26
11	1.10	0.01	0.49	45	0	5.0	63	9	38.0	0	0	0	4	0	2.0	21.00	0.00	3.17
12	1.15	0.01	0.48	18	0	2.0	59	0	36.0	0	0	0	4	0	2.5	20.75	0.00	3.13
13	1.38	0.05	0.61	18	0	2.0	52	22	39.0	0	0	0	4	1	2.5	13.25	0.00	2.17
14	1.41	0.07	0.65	21	0	1.5	59	19	40.5	0	0	0	4	2	2.5	9.25	0.00	1.27
15	1.31	0.07	0.63	18	0	1.5	66	22	39.5	0	0	0	4	2	2.5	9.50	0.00	1.40
16	1.31	0.07	0.63	18	0	1.5	66	22	39.5	0	0	0	4	2	2.5	2.75	0.00	1.00
17	1.53	0.19	0.72	19	0	1.0	65	27	43.5	0	0	0	4	1	2.5	7.25	0.00	1.11
18	1.29	0.02	0.68	6	0	0.5	57	3	40.0	0	0	0	3	0	2.0	7.75	0.00	1.20
19	1.41	0.05	0.69	20	0	1.0	59	11	37.5	0	0	0	4	0	2.0	7.00	0.00	1.15
20	1.16	0.19	0.64	5	0	0.0	56	23	40.0	0	0	0	5	2	3.0	2.50	0.00	0.21
21	1.11	0.21	0.64	13	0	1.0	51	27	39.5	0	0	0	3	2	3.0	3.50	0.00	0.46
22	1.16	0.26	0.67	15	0	1.5	58	23	37.5	0	0	0	4	1	2.0	6.00	0.00	1.68
23	1.2	0.12	0.74	14	0	1.5	50	12	38.5	0	0	0	4	1	2.5	4.50	0.00	1.45
24	1.58	0.20	0.82	18	0	1.5	47	3	36.0	0	0	0	4	0	2.5	7.75	0.00	1.20
25	1.40	0.32	0.79	23	0	2.0	50	19	35.5	0	0	0	4	0	2.5	8.75	0.00	2.02
26	0.93	0.27	0.63	14	0	1.0	59	26	42.0	0	0	0	4	2	3.0	7.25	0.00	1.03
27	1.16	0.03	0.68	1	0	0.0	50	2	40.0	0	0	0	4	0	2.5	0.50	0.00	0.04
28	1.05	0.31	0.65	27	0	1.5	54	32	41.0	0	0	0	4	2	3.0	12.25	0.00	1.54
29	0.87	0.34	0.57	6	0	0.5	60	26	43.0	0	0	0	4	2	3.0	4.50	0.00	0.38
30	1.07	0.09	0.71	16	0	2.5	53	3	39.5	0	0	0	5	1	3.0	10.00	0.00	2.37
31	1.21	0.38	0.80	19	0	1.0	57	22	39.5	0	0	0	4	1	2.5	5.50	0.00	0.79

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

2月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	1.08	0.35	0.70	10	0	1.0	62	20	45.0	0	0	0	5	1	3.0	3.75	0.00	0.91
2	2.88	0.00	1.36	2	0	0.0	53	0	36.0	0	0	0	3	0	2.0	1.25	0.00	0.12
3	1.86	0.39	1.19	2	0	0.0	57	24	39.5	0	0	0	4	1	2.5	0.75	0.00	0.11
4	1.75	0.45	1.05	12	0	0.5	55	28	42.0	0	0	0	4	1	3.0	5.25	0.00	0.71
5	1.56	0.41	0.96	3	0	0.0	57	23	40.5	0	0	0	3	2	2.5	1.50	0.00	0.22
6	1.34	0.36	0.88	20	0	1.0	53	17	42.5	0	0	0	4	1	2.5	9.50	0.00	1.20
7	1.87	0.25	1.08	4	0	0.5	60	4	40.0	0	0	0	3	0	2.0	2.25	0.00	0.36
8	1.63	0.58	1.03	15	0	1.5	55	32	41.5	0	0	0	3	2	2.0	7.75	0.00	1.51
9	1.11	0.49	0.82	0	0	0.0	57	17	43.5	0	0	0	4	0	3.0	0.50	0.00	0.02
10	1.75	0.39	1.01	27	0	0.5	59	25	41.0	0	0	0	4	2	3.5	8.50	0.00	0.73
11	1.33	0.49	0.97	4	0	0.0	55	31	43.5	0	0	0	6	2	3.5	2.50	0.00	0.18
12	1.21	0.42	0.96	4	0	0.0	59	36	45.0	0	0	0	7	2	4.0	1.50	0.00	0.28
13	1.58	0.51	1.09	7	0	0.5	60	34	47.5	0	0	0	5	2	3.5	3.25	0.00	0.29
14	1.75	0.16	1.00	9	0	0.5	60	9	44.0	0	0	0	4	1	3.0	2.50	0.00	0.72
15	3.69	0.22	1.31	0	0	0.0	55	3	42.0	0	0	0	5	0	4.0	0.00	0.00	0.00
16	2.26	1.27	1.66	0	0	0.0	54	36	45.0	0	0	0	4	3	4.0	0.00	0.00	0.00
17	1.40	0.40	1.13	0	0	0.0	53	16	43.0	0	0	0	4	1	3.0	0.00	0.00	0.00
18	1.30	0.50	0.86	0	0	0.0	51	36	44.0	0	0	0	5	3	4.0	0.00	0.00	0.00
19	0.97	0.41	0.80	1	0	0.0	53	38	45.0	0	0	0	4	2	4.0	0.25	0.00	0.04
20	0.83	0.40	0.68	0	0	0.0	60	34	51.0	0	0	0	6	3	4.0	0.00	0.00	0.00
21	0.91	0.28	0.64	0	0	0.0	63	43	52.0	0	0	0	5	2	4.0	0.00	0.00	0.00
22	1.13	0.00	0.76	0	0	0.0	63	0	44.0	0	0	0	5	0	4.0	0.00	0.00	0.00
23	1.07	0.55	0.74	0	0	0.0	53	34	45.0	0	0	0	5	3	4.0	0.00	0.00	0.00
24	1.43	0.44	1.04	0	0	0.0	54	30	42.0	0	0	0	6	1	3.0	0.00	0.00	0.00
25	1.38	0.55	0.94	0	0	0.0	61	37	50.0	0	0	0	3	2	2.0	0.00	0.00	0.00
26	2.05	0.29	1.19	0	0	0.0	62	11	50.0	0	0	0	4	1	3.0	1.25	0.00	0.28
27	2.77	0.04	1.53	14	0	2.0	43	2	35.0	0	0	0	4	0	2.0	4.50	0.00	1.28
28	1.17	0.70	1.04	0	0	0.0	58	39	47.0	0	0	0	3	2	2.0	0.00	0.00	0.00

令和4年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

3月	ばいじん濃度(mg/Nm3) 管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値: 100ppm以下 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下			一酸化炭素濃度(ppm) 管理値: 30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	1.03	0.02	0.79	0	0	0.0	51	1	41.0	0	0	0	3	0	2.0	0.00	0.00	0.00
2	1.42	0.39	0.96	0	0	0.0	52	35	46.0	0	0	0	3	2	2.0	0.00	0.00	0.00
3	1.01	0.48	0.79	0	0	0.0	58	27	41.0	0	0	0	3	2	2.0	0.00	0.00	0.00
4	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5	0.89	0.00	0.43	25	0	6.0	47	0	34.0	0	0	0	9	0	4.0	12.75	0.00	5.53
6	0.40	0.06	0.30	15	0	4.0	48	7	38.0	0	0	0	6	0	2.0	8.75	0.00	4.97
7	0.46	0.00	0.33	10	0	2.0	48	3	36.0	0	0	0	3	0	2.0	5.00	0.00	1.32
8	0.41	0.00	0.25	16	0	3.0	59	0	36.0	0	0	0	6	0	3.0	8.00	0.00	2.94
9	0.77	0.00	0.46	4	0	1.0	50	1	37.0	0	0	0	4	0	3.0	2.00	0.00	0.74
10	0.73	0.00	0.53	1	0	0.0	52	2	36.0	0	0	0	3	0	3.0	0.50	0.00	0.09
11	0.77	0.28	0.55	27	0	5.0	50	27	39.0	0	0	0	3	1	2.0	15.50	0.25	4.64
12	0.86	0.31	0.65	8	0	1.0	49	30	39.0	0	0	0	4	2	3.0	2.75	0.00	1.34
13	0.84	0.12	0.61	20	0	2.0	58	6	39.0	0	0	0	3	0	2.0	4.75	0.00	0.81
14	1.10	0.04	0.75	19	0	6.0	49	2	32.0	0	0	0	4	0	2.0	12.75	0.00	6.76
15	1.11	0.61	0.88	19	0	4.0	52	33	40.0	0	0	0	3	1	3.0	10.75	0.00	3.84
16	1.08	0.41	0.74	2	0	0.0	58	26	44.0	0	0	0	4	2	3.0	0.75	0.00	0.25
17	1.10	0.41	0.85	17	0	3.0	61	23	45.0	0	0	0	3	2	3.0	8.75	0.00	2.33
18	1.40	0.32	0.85	7	0	0.0	54	28	42.0	0	0	0	10	1	3.0	2.50	0.00	0.55
19	1.23	0.10	0.75	22	0	3.0	53	2	37.0	0	0	0	4	0	3.0	8.25	0.00	1.79
20	1.26	0.54	0.99	22	0	2.0	57	32	44.0	0	0	0	4	2	3.0	13.00	0.00	3.20
21	1.42	0.56	1.01	2	0	0.0	59	26	43.0	0	0	0	4	2	3.0	1.00	0.00	0.33
22	1.42	0.36	0.90	13	0	1.0	62	29	44.0	0	0	0	3	2	3.0	7.75	0.00	1.46
23	1.23	0.37	0.79	6	0	1.0	63	38	48.0	0	0	0	4	2	4.0	4.25	0.00	0.79
24	1.59	0.73	1.13	0	0	0.0	58	26	46.0	0	0	0	3	2	3.0	0.00	0.00	0.00
25	1.44	0.13	0.95	3	0	0.0	55	10	42.0	0	0	0	3	1	3.0	0.75	0.00	0.15
26	1.44	0.13	0.95	3	0	0.0	55	10	42.0	0	0	0	3	1	3.0	2.75	0.00	0.55
27	2.07	0.05	1.20	12	0	1.0	61	3	46.0	0	0	0	4	0	3.0	4.00	0.00	1.20
28	1.98	1.07	1.45	12	0	1.0	46	31	40.0	0	0	0	3	2	3.0	4.25	0.00	1.25
29	1.77	1.00	1.47	10	0	1.0	56	36	45.0	0	0	0	4	2	3.0	4.25	0.00	0.74
30	2.52	1.02	1.57	4	0	1.0	55	36	46.0	0	0	0	4	2	3.0	2.50	0.00	0.63
31	2.37	0.00	1.81	13	0	1.0	60	2	41.0	0	0	0	3	0	2.0	4.25	0.00	0.78