

令和5年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

10月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
	1	0.79	0.00	0.34	5	0	0.0	53	0	33.5	0	0	0	3	0	1.5	2.00	0.00
2	0.73	0.00	0.33	2	0	0.0	54	27	37.5	0	0	0	3	1	2.0	0.75	0.00	0.13
3	0.78	0.00	0.32	3	0	0.0	51	16	38.0	0	0	0	3	1	1.0	1.50	0.00	0.18
4	0.80	0.00	0.34	12	0	0.5	52	23	37.0	0	0	0	7	1	3.0	3.75	0.00	0.38
5	0.74	0.00	0.30	0	0	0.0	53	11	35.5	0	0	0	4	0	2.5	3.75	0.00	0.14
6	0.71	0.00	0.31	7	0	0.5	48	22	35.0	0	0	0	4	1	3.0	2.25	0.00	0.69
7	0.65	0.36	0.61	12	0	1.0	38	27	33.0	0	0	0	6	2	4.0	4.00	0.00	0.67
8	0.61	0.01	0.49	1	0	0.0	44	0	31.0	0	0	0	3	0	2.0	0.25	0.00	0.05
9	0.65	0.33	0.47	0	0	0.0	47	19	35.0	0	0	0	3	2	3.0	0.00	0.00	0.00
10	0.68	0.36	0.54	0	0	0.0	45	30	37.0	0	0	0	3	2	2.0	0.00	0.00	0.00
11	0.68	0.32	0.58	0	0	0.0	40	26	35.0	0	0	0	5	2	3.0	0.00	0.00	0.00
12	0.60	0.33	0.53	0	0	0.0	39	33	36.0	0	0	0	3	2	3.0	0.00	0.00	0.00
13	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
14	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
15	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
16	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
17	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
18	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
19	2.01	0.03	1.20	15	0	7.0	39	3	25.0	0	0	0	0	0	0.0	0.00	0.00	0.00
20	0.60	0.16	0.27	7	0	1.0	61	24	40.0	0	0	0	2	0	1.0	5.25	0.00	1.25
21	0.29	0.18	0.25	27	0	6.0	59	26	40.0	0	0	0	3	1	2.0	19.50	0.00	5.71
22	0.26	0.02	0.22	9	0	1.0	46	1	33.0	0	0	0	3	0	2.0	3.25	0.00	0.63
23	0.30	0.01	0.22	1	0	0.0	63	1	48.0	0	0	0	3	0	2.0	0.50	0.00	0.10
24	0.30	0.00	0.21	7	0	1.0	59	0	41.0	0	0	0	3	0	2.0	3.00	0.00	0.58
25	0.25	0.15	0.24	11	0	1.0	62	27	41.0	0	0	0	3	1	2.0	3.25	0.00	0.94
26	0.25	0.08	0.23	3	0	0.0	52	14	32.0	0	0	0	5	1	2.0	1.25	0.00	0.37
27	0.30	0.17	0.25	14	0	1.0	50	26	38.0	0	0	0	5	1	3.0	4.00	0.00	0.69
28	0.25	0.15	0.24	3	0	0.0	48	29	38.0	0	0	0	5	2	3.0	1.00	0.00	0.29
29	0.25	0.15	0.24	5	0	1.0	49	28	39.0	0	0	0	3	2	3.0	1.75	0.00	0.58
30	0.25	0.00	0.20	9	0	1.0	63	0	42.0	0	0	0	4	0	3.0	3.25	0.00	0.71
31	0.25	0.13	0.21	3	0	0.0	58	30	42.0	0	0	0	4	2	3.0	0.75	0.00	0.21

令和5年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

11月	ばいじん濃度(mg/Nm ³) 管理値:20mg/Nm ³ 以下 排出基準:150mg/Nm ³ 以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.25	0.11	0.22	9	0	1.0	58	34	48.0	0	0	0	4	2	3.0	5.75	0.00	1.04
2	0.49	0.08	0.29	3	0	0.5	53	10	34.0	0	0	0	4	1	3.0	2.00	0.00	0.21
3	0.62	0.05	0.36	2	0	0.0	51	4	32.0	0	0	0	5	0	2.5	1.25	0.00	0.18
4	0.65	0.03	0.40	3	0	0.5	64	2	36.0	0	0	0	5	0	3.5	1.00	0.00	0.24
5	0.62	0.04	0.40	2	0	0.0	64	6	36.5	0	0	0	5	0	3.5	1.25	0.00	0.11
6	0.80	0.14	0.44	2	0	0.0	58	25	41.0	0	0	0	3	2	3.0	0.75	0.00	0.06
7	0.69	0.10	0.39	17	0	0.5	57	24	43.0	0	0	0	4	1	3.0	6.75	0.00	0.58
8	0.55	0.06	0.34	2	0	0.0	62	6	41.0	0	0	0	4	1	2.5	0.50	0.00	0.02
9	0.65	0.02	0.37	4	0	0.5	54	4	40.0	0	0	0	5	0	2.5	2.25	0.00	0.38
10	0.74	0.02	0.40	2	0	0.0	52	1	37.5	0	0	0	4	0	2.5	0.75	0.00	0.09
11	0.58	0.00	0.34	8	0	0.5	65	0	38.0	0	0	0	4	0	2.5	2.50	0.00	0.31
12	0.56	0.05	0.30	23	0	0.5	50	11	36.5	0	0	0	5	1	3.0	8.00	0.00	0.67
13	0.84	0.11	0.31	2	0	0.0	64	30	45.0	0	0	0	4	2	3.0	0.75	0.00	0.08
14	0.50	0.02	0.25	1	0	0.0	58	1	41.5	0	0	0	5	0	2.0	0.25	0.00	0.02
15	0.52	0.11	0.29	7	0	0.5	62	23	42.0	0	0	0	5	1	2.5	2.25	0.00	0.42
16	0.64	0.02	0.29	0	0	0.0	54	2	38.0	0	0	0	4	0	1.5	0.00	0.00	0.00
17	0.50	0.11	0.29	11	0	1.0	55	16	38.0	0	0	0	4	1	2.5	4.00	0.00	0.70
18	0.41	0.11	0.25	3	0	0.0	58	14	34.5	0	0	0	5	0	2.5	1.75	0.00	0.18
19	0.46	0.11	0.27	15	0	1.0	54	26	41.0	0	0	0	3	0	2.0	7.75	0.00	0.70
20	0.78	0.10	0.32	7	0	0.5	61	25	42.0	0	0	0	7	1	2.0	3.50	0.00	0.47
21	0.64	0.04	0.29	1	0	0.0	57	15	43.5	0	0	0	3	1	1.5	0.25	0.00	0.03
22	0.49	0.01	0.28	14	0	0.5	61	2	39.5	0	0	0	5	0	2.0	5.25	0.00	0.61
23	0.54	0.11	0.32	20	0	0.5	48	23	36.0	0	0	0	3	1	2.0	5.50	0.00	0.56
24	1.07	0.01	0.35	27	0	1.5	57	1	35.0	0	0	0	6	0	3.0	13.00	0.00	1.63
25	0.44	0.11	0.26	14	0	1.0	52	13	33.5	0	0	0	4	1	3.0	5.25	0.00	1.08
26	0.70	0.03	0.31	37	0	2.5	62	13	40.0	0	0	0	4	1	2.5	15.00	0.00	2.74
27	1.28	0.03	0.36	2	0	0.0	57	17	39.0	0	0	0	7	1	3.0	0.50	0.00	0.06
28	1.76	0.06	0.36	0	0	0.0	53	22	41.0	0	0	0	4	1	2.0	0.00	0.00	0.00
29	0.85	0.00	0.28	7	0	0.5	59	0	36.5	0	0	0	4	0	2.5	3.25	0.00	0.29
30	1.09	0.04	0.38	10	0	0.5	57	4	37.0	0	0	0	5	0	3.0	3.25	0.00	0.46

令和5年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

1月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
2	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
3	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
4	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—	—
5	0.42	0.00	0.18	11	0	1.0	60	0	40.0	0	0	0	6	0	4.0	4.50	0.00	1.29
6	0.28	0.04	0.16	2	0	0.0	67	6	48.0	0	0	0	4	1	2.0	0.75	0.00	0.14
7	0.37	0.02	0.14	9	0	1.0	65	3	40.0	0	0	0	3	0	2.0	4.00	0.00	0.82
8	0.20	0.00	0.12	10	0	1.0	59	0	38.0	0	0	0	3	0	2.0	4.00	0.00	0.97
9	0.20	0.00	0.12	13	0	2.0	58	1	38.0	0	0	0	3	0	2.0	5.25	0.00	1.85
10	0.75	0.06	0.26	3	0	0.0	61	8	31.5	0	0	0	3	1	1.5	2.50	0.00	0.27
11	0.35	0.00	0.21	9	0	0.0	51	0	32.5	0	0	0	3	0	1.5	2.75	0.00	0.44
12	0.53	0.00	0.22	4	0	0.0	65	0	40.0	0	0	0	3	0	1.5	1.75	0.00	0.24
13	0.43	0.00	0.22	10	0	0.5	56	1	36.5	0	0	0	3	0	2.0	2.75	0.00	0.45
14	0.69	0.00	0.24	6	0	0.0	59	0	37.5	0	0	0	3	0	2.0	1.50	0.00	0.24
15	0.55	0.05	0.25	2	0	0.0	62	22	40.5	0	0	0	4	1	2.5	0.50	0.00	0.10
16	0.37	0.11	0.23	5	0	0.0	58	40	47.5	0	0	0	3	1	2.0	1.25	0.00	0.15
17	0.30	0.01	0.19	20	0	1.0	63	2	39.5	0	0	0	4	1	1.5	9.00	0.00	0.82
18	0.72	0.06	0.25	3	0	0.0	59	21	39.0	0	0	0	4	1	2.5	1.25	0.00	0.14
19	0.49	0.09	0.24	16	0	0.5	58	18	39.5	0	0	0	4	2	2.5	8.00	0.00	0.80
20	0.44	0.09	0.24	10	0	0.5	50	8	34.5	0	0	0	3	1	2.0	3.75	0.00	0.36
21	0.62	0.06	0.28	16	0	0.5	64	16	45.5	0	0	0	4	1	2.0	6.75	0.00	0.74
22	0.39	0.04	0.21	9	0	0.5	61	16	44.0	0	0	0	3	1	2.0	5.25	0.00	0.80
23	0.37	0.00	0.20	7	0	0.5	58	1	40.5	0	0	0	3	0	2.0	5.25	0.00	0.53
24	0.30	0.00	0.15	18	0	1.0	67	0	39.0	0	0	0	6	0	2.5	7.00	0.00	1.37
25	0.34	0.01	0.18	7	0	0.5	63	5	36.5	0	0	0	3	0	2.0	3.00	0.00	0.46
26	0.38	0.05	0.21	14	0	0.5	60	13	34.0	0	0	0	4	1	2.5	5.50	0.00	0.54
27	0.34	0.00	0.20	10	0	0.5	50	0	30.5	0	0	0	4	0	3.0	2.75	0.00	0.51
28	0.47	0.01	0.23	8	0	0.5	66	1	33.0	0	0	0	4	0	2.0	2.75	0.00	0.25
29	0.39	0.05	0.22	6	0	0.5	59	17	38.0	0	0	0	3	1	1.5	2.50	0.00	0.22
30	0.60	0.03	0.22	1	0	0.0	61	3	34.0	0	0	0	3	1	2.0	2.50	0.00	0.20
31	0.40	0.10	0.24	15	0	0.5	50	16	34.5	0	0	0	4	1	2.5	5.75	0.00	0.48

令和5年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

2月	ばいじん濃度(mg/Nm ³) 管理値: 20mg/Nm ³ 以下 排出基準: 150mg/Nm ³ 以下			一酸化炭素濃度 (ppm) 管理値: 100ppm以下 維持管理基準: 100ppm以下			窒素酸化物濃度 (ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度 (ppm) 管理値: 20ppm以下			塩化水素濃度 (ppm) 管理値: 50ppm以下 排出基準: 430ppm以下			一酸化炭素濃度 (ppm) 管理値: 30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.56	0.04	0.26	0	0	0.0	54	8	35.0	0	0	0	4	1	3.0	0.00	0.00	0.00
2	0.43	0.04	0.22	3	0	0.0	55	3	33.5	0	0	0	4	0	1.5	0.75	0.00	0.06
3	0.30	0.11	0.21	0	0	0.0	51	21	32.0	0	0	0	4	1	2.5	0.00	0.00	0.00
4	0.40	0.04	0.23	6	0	0.0	61	9	33.0	0	0	0	4	1	2.0	1.75	0.00	0.09
5	0.43	0.07	0.23	1	0	0.0	63	12	33.5	0	0	0	5	1	1.5	0.25	0.00	0.02
6	0.40	0.03	0.22	0	0	0.0	64	17	35.5	0	0	0	2	0	1.5	0.00	0.00	0.00
7	0.31	0.05	0.19	15	0	1.0	65	9	42.0	0	0	0	3	0	1.5	7.50	0.00	0.73
8	0.30	0.01	0.19	0	0	0.0	59	2	35.0	0	0	0	3	0	2.0	2.75	0.00	0.16
9	0.31	0.09	0.21	6	0	0.0	55	21	38.0	0	0	0	3	1	2.0	2.25	0.00	0.19
10	0.34	0.11	0.22	0	0	0.0	61	23	39.0	0	0	0	3	1	2.0	0.00	0.00	0.00
11	0.37	0.05	0.21	7	0	0.5	60	3	37.0	0	0	0	4	0	1.5	3.75	0.00	0.52
12	0.30	0.05	0.18	0	0	0.0	63	4	36.0	0	0	0	4	0	1.5	0.00	0.00	0.00
13	0.33	0.00	0.18	8	0	0.5	56	0	32.0	0	0	0	3	0	2.0	4.00	0.00	0.33
14	0.35	0.00	0.20	5	0	0.0	63	0	34.0	0	0	0	5	0	2.5	1.50	0.00	0.10
15	0.40	0.04	0.23	3	0	0.0	59	8	33.5	0	0	0	5	0	3.0	1.00	0.00	0.07
16	0.35	0.03	0.22	0	0	0.0	58	11	34.0	0	0	0	4	1	2.5	0.00	0.00	0.00
17	0.32	0.02	0.21	2	0	0.0	61	8	38.0	0	0	0	4	0	2.0	1.25	0.00	0.10
18	0.40	0.01	0.21	0	0	0.0	61	0	39.5	0	0	0	4	0	2.5	0.00	0.00	0.00
19	0.38	0.09	0.28	0	0	0.0	45	12	28.0	0	0	0	3	1	2.0	0.00	0.00	0.00
20	0.34	0.00	0.23	0	0	0.0	38	0	25.0	0	0	0	4	0	2.0	0.00	0.00	0.00
21	0.31	0.14	0.25	0	0	0.0	33	16	28.0	0	0	0	3	1	2.0	0.00	0.00	0.00
22	0.49	0.03	0.23	0	0	0.0	30	3	23.0	0	0	0	3	0	2.0	0.00	0.00	0.00
23	0.39	0.05	0.22	0	0	0.0	47	4	30.0	0	0	0	4	0	2.0	0.00	0.00	0.00
24	0.36	0.11	0.21	0	0	0.0	41	19	30.0	0	0	0	3	1	2.0	0.00	0.00	0.00
25	0.30	0.02	0.21	0	0	0.0	50	0	28.0	0	0	0	2	0	1.0	0.00	0.00	0.00
26	0.32	0.00	0.21	0	0	0.0	31	0	22.0	0	0	0	2	0	1.0	0.00	0.00	0.00
27	0.30	0.12	0.21	0	0	0.0	31	10	24.0	0	0	0	2	1	1.0	0.00	0.00	0.00
28	0.28	0.11	0.19	0	0	0.0	46	12	28.0	0	0	0	2	1	2.0	0.00	0.00	0.00
29	0.30	0.02	0.20	1	0	0.0	51	0	26.0	0	0	0	3	0	2.0	0.25	0.00	0.04

令和5年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

3月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
	1	0.35	0.15	0.26	0	0	0.0	36	22	29.0	0	0	0	4	1	2.0	0.00	0.00
2	0.26	0.12	0.19	0	0	0.0	33	11	24.0	0	0	0	4	1	3.0	0.00	0.00	0.00
3	0.31	0.15	0.21	0	0	0.0	44	25	35.0	0	0	0	3	2	2.0	0.00	0.00	0.00
4	0.42	0.00	0.20	18	0	2.0	54	0	33.5	0	0	0	5	0	3.0	9.00	0.25	2.38
5	0.40	0.06	0.24	5	0	0.5	60	19	36.0	0	0	0	6	1	3.5	6.75	0.00	0.40
6	0.40	0.04	0.25	27	0	1.5	55	7	29.5	0	0	0	5	1	2.5	8.25	0.00	1.23
7	0.38	0.13	0.24	0	0	0.0	57	20	36.0	0	0	0	4	2	2.5	0.75	0.00	0.04
8	0.38	0.00	0.24	0	0	0.0	58	0	34.5	0	0	0	4	0	2.5	0.00	0.00	0.00
9	0.35	0.12	0.24	7	0	0.5	60	18	41.5	0	0	0	7	2	3.5	2.75	0.00	0.33
10	0.32	0.11	0.22	9	0	0.5	61	13	39.5	0	0	0	4	1	2.5	2.50	0.00	0.27
11	0.54	0.09	0.24	30	0	0.5	65	23	41.5	0	0	0	4	1	2.5	8.00	0.00	0.67
12	0.41	0.00	0.22	4	0	0.0	59	0	34.0	0	0	0	5	0	3.0	1.25	0.00	0.12
13	0.35	0.08	0.22	0	0	0.0	54	16	33.5	0	0	0	3	1	1.5	0.00	0.00	0.00
14	0.19	0.11	0.15	3	0	0.0	54	14	41.0	0	0	0	4	1	3.0	1.00	0.00	0.14
15	0.15	0.08	0.14	0	0	0.0	57	32	45.0	0	0	0	4	2	2.0	0.75	0.00	0.03
16	0.15	0.11	0.15	0	0	0.0	55	27	46.0	0	0	0	3	2	2.0	0.00	0.00	0.00
17	0.15	0.11	0.15	3	0	0.0	62	35	50.0	0	0	0	3	2	2.0	0.75	0.00	0.17
18	0.15	0.02	0.13	13	0	1.0	59	6	43.0	0	0	0	3	0	2.0	4.50	0.00	1.50
19	0.15	0.06	0.14	4	0	0.0	59	19	41.0	0	0	0	3	1	2.0	1.50	0.00	0.48
20	0.15	0.11	0.15	1	0	0.0	57	22	39.0	0	0	0	2	1	2.0	0.25	0.00	0.04
21	0.15	0.11	0.15	11	0	1.0	58	13	38.0	0	0	0	3	1	2.0	3.50	0.00	0.96
22	0.15	0.11	0.15	22	0	2.0	59	14	39.0	0	0	0	3	2	2.0	7.50	0.00	1.79
23	0.15	0.11	0.15	0	0	0.0	54	37	48.0	0	0	0	3	2	2.0	0.00	0.00	0.00
24	0.15	0.07	0.14	30	0	3.0	67	10	45.0	0	0	0	3	1	2.0	14.75	0.00	3.12
25	0.15	0.07	0.14	1	0	0.0	55	28	44.0	0	0	0	3	2	2.0	0.25	0.00	0.04
26	0.35	0.00	0.20	13	0	2.0	54	0	33.5	0	0	0	4	0	2.0	8.25	0.00	2.15
27	0.37	0.11	0.23	22	0	1.5	49	16	34.0	0	0	0	4	1	2.5	9.00	0.00	1.58
28	0.41	0.21	0.23	2	0	0.0	53	18	32.0	0	0	0	6	1	3.0	1.00	0.00	0.17
29	0.45	0.11	0.26	1	0	0.0	55	17	32.5	0	0	0	4	2	3.0	0.25	0.00	0.04
30	0.56	0.11	0.26	9	0	0.5	52	13	33.5	0	0	0	6	2	3.5	3.50	0.00	0.33
31	0.62	0.00	0.27	1	0	0.0	58	0	38.0	0	0	0	5	0	2.5	0.25	0.00	0.02