

令和6年度 排ガス中のばい煙濃度等

4月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値: 20mg/Nm <sup>3</sup> 以下 排出基準: 150mg/Nm <sup>3</sup> 以下			維持管理基準: 100ppm以下			管理値: 70ppm以下 排出基準: 250ppm以下			管理値: 20ppm以下			管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.57	0.11	0.29	16	0	0.5	53	18	40.0	0	0	0	5	1	2.5
2	0.41	0.00	0.24	9	0	0.5	60	1	34.5	0	0	0	5	0	2.5
3	0.49	0.07	0.26	16	0	1.0	40	7	29.5	0	0	0	4	1	2.5
4	0.45	0.04	0.26	27	0	2.0	54	3	29.5	0	0	0	7	1	3.5
5	0.40	0.11	0.24	14	0	0.5	48	17	32.5	0	0	0	6	2	3.5
6	0.50	0.11	0.25	7	0	0.5	53	18	33.5	0	0	0	9	2	4.0
7	0.41	0.06	0.24	10	0	0.0	56	9	36.0	0	0	0	6	1	3.5
8	0.57	0.11	0.30	10	0	0.5	49	11	33.0	0	0	0	9	2	3.5
9	0.44	0.08	0.25	10	0	0.5	57	12	37.5	0	0	0	7	2	3.5
10	0.49	0.04	0.24	2	0	0.0	61	5	40.0	0	0	0	6	1	3.5
11	0.62	0.08	0.24	1	0	0.0	57	18	39.0	0	0	0	6	2	3.5
12	0.48	0.05	0.25	1	0	0.0	58	1	32.0	0	0	0	6	0	3.0
13	0.47	0.19	0.30	5	0	0.0	44	27	34.0	0	0	0	4	1	3.0
14	0.42	0.18	0.31	12	0	1.0	47	33	38.0	0	0	0	5	2	3.0
15	0.46	0.02	0.34	0	0	0.0	53	2	36.0	0	0	0	5	0	2.0
16	0.40	0.06	0.31	7	0	1.0	47	2	36.0	0	0	0	5	1	2.0
17	0.40	0.22	0.34	0	0	0.0	51	33	39.0	0	0	0	7	2	3.0
18	0.35	0.16	0.29	0	0	0.0	45	28	34.0	0	0	0	12	2	5.0
19	0.84	0.15	0.38	0	0	0.0	50	14	38.0	0	0	0	5	1	2.0
20	0.40	0.13	0.29	0	0	0.0	46	32	37.0	0	0	0	5	1	2.0
21	0.37	0.17	0.31	0	0	0.0	44	26	35.0	0	0	0	7	2	3.0
22	0.50	0.00	0.33	0	0	0.0	42	0	32.0	0	0	0	7	0	3.0
23	0.40	0.02	0.32	0	0	0.0	46	1	33.0	0	0	0	3	0	2.0
24	1.63	0.24	0.62	21	0	1.0	39	16	30.0	0	0	0	4	2	3.0
25	0.54	0.00	0.30	23	0	2.0	41	0	23.0	0	0	0	13	0	3.5
26	1.23	0.00	0.37	31	0	1.5	48	0	33.5	0	0	0	5	0	3.5
27	0.69	0.00	0.32	21	0	1.0	278	0	43.0	0	0	0	5	0	3.0
28	0.70	0.00	0.47	0	0	0.0	52	0	39.0	0	0	0	4	0	2.0
29	0.82	0.34	0.47	8	0	0.0	48	26	33.0	0	0	0	5	1	3.0
30	0.57	0.06	0.40	0	0	0.0	47	2	34.0	0	0	0	4	0	2.0

令和6年度 排ガス中のばい煙濃度等

5月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.40	0.00	0.43	0	0	0.0	46	0	37.0	0	0	0	3	0	2.0
2	0.40	0.00	0.27	0	0	0.0	46	0	35.0	0	0	0	3	1	3.0
3	0.44	0.19	0.33	0	0	0.0	47	11	36.0	0	0	0	4	1	2.0
4	0.45	0.20	0.38	0	0	0.0	46	20	35.0	0	0	0	5	2	3.0
5	0.60	0.00	0.39	0	0	0.0	37	0	29.0	0	0	0	6	0	3.0
6	0.64	0.00	0.41	7	0	0.0	41	0	24.0	0	0	0	6	0	2.0
7	0.64	0.00	0.38	0	0	0.0	41	0	24.0	0	0	0	5	0	2.0
8	0.46	0.00	0.34	0	0	0.0	38	0	29.0	0	0	0	3	0	2.0
9	0.42	0.00	0.28	3	0	0.0	40	28	29.0	0	0	0	5	0	3.0
10	0.53	0.00	0.28	11	0	1.0	42	0	17.0	0	0	0	7	0	3.0
11	0.59	0.00	0.32	17	0	1.0	41	0	15.0	1	0	0	13	0	4.5
12	0.71	0.12	0.37	2	0	0.0	44	0	16.0	0	0	0	8	2	4.5
13	0.73	0.01	0.35	6	0	0.5	44	0	17.0	0	0	0	6	0	3.5
14	0.63	0.01	0.32	1	0	0.0	41	0	16.5	0	0	0	5	0	3.5
15	0.66	0.00	0.19	7	0	0.0	40	0	6.5	0	0	0	5	0	2.5
16	0.22	0.12	0.17	5	0	1.0	0	0	0.0	0	0	0	6	3	5.0
17	0.24	0.00	0.14	9	0	1.0	0	0	0	0	0	0.0	5	0	4.0
18	0.20	0.11	0.17	0	0	0.0	0	0	0.0	0	0	0	5	3	4.0
19	0.15	0.11	0.15	0	0	0.0	0	0	0.0	0	0	0	5	2	4.0
20	0.20	0.11	0.16	1	0	0	0	0	0	0	0	0	5	3	5
21	0.25	0.11	0.18	0	0	0.0	0	0	0.0	0	0	0	5	3	4.0
22	0.23	0.00	0.16	17	0	2.0	0	0	0.0	0	0	0	4	0	4.0
23	0.25	0.16	0.23	17	0	2.0	0	0	0.0	0	0	0	4	2	4.0
24	0.25	0.00	0.18	21	0	1.0	0	0	0.0	0	0	0	4	0	4.0
25	0.25	0.13	0.20	5	0	0.0	0	0	0.0	0	0	0	4	3	3.0
26	0.25	0.11	0.20	0	0	0.0	0	0	0.0	0	0	0	4	2	4.0
27	0.25	0.15	0.23	2	0	0.0	0	0	0.0	0	0	0	4	2	4.0
28	0.25	0.13	0.20	0	0	0.0	0	0	0.0	0	0	0	4	3	4.0
29	0.25	0.11	0.17	0	0	0.0	0	0	0.0	0	0	0	4	3	4.0
30	0.25	0.00	0.14	2	0	0.0	0	0	0.0	0	0	0	4	0	3.0
31	0.20	0.11	0.15	2	0	0.0	0	0	0.0	0	0	0	4	2	4.0

令和6年度 排ガス中のばい煙濃度等

6月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.24	0.11	0.17	0	0	0.0	0	0	0.0	0	0	0	4	3	4.0
2	0.25	0.15	0.20	2	0	0.0	0	0	0.0	0	0	0	4	3	4.0
3	0.24	0.11	0.18	11	0	1.0	0	0	0.0	0	0	0	4	2	4.0
4	0.25	0.14	0.19	7	0	1.0	0	0	0.0	0	0	0	4	3	4.0
5	0.24	0.11	0.19	0	0	0.0	0	0	0.0	0	0	0	4	2	4.0
6	0.25	0.00	0.16	0	0	0.0	0	0	0.0	0	0	0	4	2	4.0
7	0.64	0.00	0.20	4	0	0.0	40	0	4.0	0	0	0	9	0	3.0
8	1.64	0.18	0.57	13	0	0.5	45	0	17.5	0	0	0	7	2	4.0
9	1.06	0.00	0.42	7	0	0.5	41	0	16.5	0	0	0	8	0	4.5
10	1.06	0.00	0.42	7	0	0.5	41	0	16.5	0	0	0	8	0	4.5
11	0.67	0.00	0.36	1	0	0.0	43	0	18.0	12	0	0.5	5	0	3.5
12	0.70	0.00	0.39	2	0	0.0	44	0	18.0	0	0	0	6	0	3.5
13	0.77	0.00	0.38	10	0	0.5	44	0	17.0	0	0	0	7	0	3.5
14	0.86	0.02	0.44	7	0	0.0	51	0	18.0	0	0	0	5	0	3.0
15	0.70	0.00	0.41	2	0	0.0	43	0	16.0	0	0	0	5	0	3.0
16	1.11	0.02	0.47	0	0	0.0	42	0	16.5	0	0	0	5	0	3.0
17	0.93	0.18	0.47	5	0	0.0	43	0	18.0	0	0	0	4	1	3.0
18	0.75	0.00	0.40	5	0	0.0	45	0	15.0	0	0	0	5	0	2.5
19	0.25	0.00	0.11	3	0	0.0	0	0	0.0	0	0	0	4	0	1.5
20	0.79	0.00	0.35	0	0	0.0	43	0	12.5	0	0	0	4	0	2.5
21	0.67	0.16	0.40	1	0	0.0	41	0	17.0	0	0	0	5	2	3.0
22	0.70	0.01	0.42	3	0	0.0	42	0	15.5	0	0	0	5	0	3.0
23	1.34	0.18	0.53	10	0	0.5	38	0	17.0	0	0	0	4	2	3.0
24	0.92	0.18	0.46	0	0	0.0	49	0	17.5	0	0	0	6	1	3.0
25	0.79	0.00	0.35	0	0	0.0	43	0	16.5	0	0	0	4	0	1.5
26	0.70	0.38	0.58	16	0	1.0	38	26	32.0	0	0	0	5	1	2.0
27	0.71	0.00	0.51	7	0	1.0	48	0	27.0	0	0	0	4	0	2.0
28	0.83	0.46	0.65	0	0	0.0	48	20	36.0	0	0	0	3	1	2.0
29	0.69	0.04	0.58	0	0	0.0	40	2	31.0	0	0	0	3	0	1.0
30	0.75	0.40	0.65	0	0	0.0	43	28	34.0	0	0	0	4	1	2.0

令和6年度 排ガス中のばい煙濃度等

7月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.88	0.00	0.67	0	0	0.0	39	0	31.0	0	0	0	3	0	1.0
2	0.88	0.39	0.73	0	0	0.0	52	27	38.0	0	0	0	3	1	1.0
3	0.89	0.00	0.65	12	0	1.0	39	18	34.0	0	0	0	3	1	1.0
4	0.89	0.00	0.65	0	0	0.0	49	0	31.0	0	0	0	3	0	1.0
5	0.95	0.43	0.81	1	0	0.0	52	30	40.0	0	0	0	3	1	2.0
6	0.91	0.49	0.79	0	0	0.0	47	28	39.0	0	0	0	3	1	2.0
7	0.90	0.04	0.72	0	0	0.0	44	0	33.0	0	0	0	3	0	2.0
8	0.93	0.09	0.74	0	0	0.0	43	2	35.0	0	0	0	3	0	2.0
9	0.96	0.44	0.80	0	0	0.0	54	32	43.0	0	0	0	4	1	2.0
10	1.04	0.10	0.75	0	0	0.0	50	3	35.0	0	0	0	4	0	3.0
11	0.87	0.00	0.59	2	0	0.0	49	0	32.0	0	0	0	4	0	2.0
12	0.94	0.49	0.78	0	0	0.0	45	28	38.0	0	0	0	3	1	2.0
13	0.89	0.44	0.77	3	0	0.0	45	28	37.0	0	0	0	3	2	2.0
14	0.76	0.04	0.64	0	0	0.0	49	2	35.0	0	0	0	4	0	2.0
15	1.59	0.04	0.84	1	0	0.0	52	29	40.0	0	0	0	3	2	2.0
16	0.91	0.01	0.65	0	0	0.0	50	0	34.0	0	0	0	3	0	2.0
17	1.09	0.43	0.79	4	0	0.0	53	32	41.0	0	0	0	4	1	2.0
18	0.99	0.00	0.68	0	0	0.0	44	0	31.0	0	0	0	3	0	2.0
19	1.84	0.00	0.53	28	0	1.0	46	33	19.5	0	0	0	8	0	2.0
20	0.98	0.08	0.68	0	0	0.0	55	1	21.0	0	0	0	9	0	3.5
21	1.09	0.32	0.65	0	0	0.0	53	37	22	0	0	0.0	4	2	2.5
22	3.61	0.03	0.78	7	0	0.5	49	1	18.0	0	0	0	4	0	2.5
23	2.70	0.00	0.84	6	0	0.0	46	0	36.0	0	0	0	4	0	2.5
24	1.38	0.19	0.71	8	0	0.5	42	33	38.0	0	0	0	4	1	2.5
25	1.46	0.00	0.66	5	0	0.0	46	0	35.0	0	0	0	5	0	2.5
26	1.42	0.00	0.73	3	0	0.0	49	31	38.0	0	0	0	4	0	2.0
27	1.11	0.21	0.63	9	0	0.5	52	11	39.0	0	0	0	4	1	2.5
28	1.14	0.00	0.62	2	0	0.0	45	0	37.0	0	0	0	4	0	2.5
29	1.18	0.23	0.68	1	0	0.0	45	30	39.0	0	0	0	6	2	3.5
30	1.34	0.00	0.69	5	0	0.5	41	0	33.0	0	0	0	7	0	4.5
31	1.05	0.00	0.33	1	0	0.0	43	0	14.0	0	0	0	8	0	3.5

令和6年度 排ガス中のばい煙濃度等

8月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.39	0.00	0.28	0	0	0.0	-	-	-	0	0	0	7	0	4.0
2	0.35	0.00	0.25	14	0	1.0	-	-	-	0	0	0	7	0	5.0
3	0.35	0.20	0.27	2	0	0.0	-	-	-	0	0	0	12	3	5.0
4	0.37	0.23	0.30	5	0	1.0	-	-	-	0	0	0	6	3	5.0
5	0.34	0.19	0.28	8	0	1	-	-	-	0	0	0	5	3	3
6	0.34	0.22	0.28	2	0	0.0	-	-	-	0	0	0	3	1	2.0
7	0.35	0.18	0.27	0	0	0.0	-	-	-	0	0	0	3	1	2.0
8	0.33	0.00	0.24	1	0	0.0	-	-	-	0	0	0	2	0	1.0
9	2.05	0.00	0.42	3	0	0.0	41	0	15.0	0	0	0	7	0	2.5
10	0.35	0.18	0.30	3	0	0.0	-	-	-	0	0	0	6	2	3.0
11	2.70	0.00	1.19	13	0	0.5	39	0	30.0	0	0	0	5	0	4.0
12	1.78	0.21	0.84	19	0	1.0	49	36	43.0	0	0	0	5	2	3.0
13	1.71	0.24	0.89	1	0	0.0	59	33	47.0	0	0	0	4	1	2.5
14	2.03	0.22	1.03	12	0	0.5	51	30	40.0	0	0	0	3	1	2.0
15	3.13	0.00	1.19	0	0	0.0	56	31	42.0	0	0	0	3	0	1.5
16	5.14	0.00	1.72	1	0	0.0	58	0	37.0	0	0	0	3	0	1.5
17	3.67	0.22	1.67	0	0	0.0	57	34	43.0	0	0	0	4	1	2.0
18	2.90	0.15	1.30	4	0	0.0	55	2	36.0	0	0	0	5	0	2.5
19	2.61	0.21	1.28	0	0	0.0	56	32	42.0	0	0	0	6	1	2.0
20	3.26	0.00	1.28	0	0	0.0	61	33	45.0	0	0	0	3	0	1.5
21	4.68	0.00	1.32	17	0	1.0	56	0	35.0	0	0	0	5	0	3.0
22	1.93	0.24	0.95	2	0	0.0	48	36	39.0	0	0	0	4	2	3.0
23	2.51	0.25	1.17	0	0	0.0	54	33	41.0	0	0	0	3	2	2.5
24	2.64	0.25	1.20	0	0	0.0	41	3	32.0	0	0	0	3	0	2.0
25	2.98	0.00	1.25	3	0	0.0	52	1	37.0	0	0	0	4	0	2.5
26	2.87	0.00	1.34	1	0	0.0	42	31	38.0	0	0	0	4	0	2.5
27	2.90	0.00	1.27	0	0	0.0	43	0	34.0	0	0	0	3	0	2.0
28	2.84	0.09	1.31	10	0	1.0	38	27	32.0	13	0	0.5	5	1	3.0
29	3.51	0.19	1.61	19	0	1.0	43	26	37	0	0	0.0	8	2	3.5
30	2.85	0.18	1.34	14	0	1.0	42	30	36.0	0	0	0	5	2	3.0
31	2.96	0.00	1.31	9	0	0.0	48	0	35.0	0	0	0	3	0	2.0

令和6年度 排ガス中のばい煙濃度等

9月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	2.71	0.23	1.28	3	0	0.0	48	26	39.0	0	0	0	5	2	3.0
2	2.77	0.18	1.31	1	0	0.0	49	34	41.0	0	0	0	6	2	3.0
3	3.30	0.00	1.21	25	0	1.0	53	0	18.5	0	0	0	6	0	2.5
4	4.12	0.00	1.50	23	0	0.5	49	0	35.0	0	0	0	4	0	2.5
5	3.00	0.18	1.42	1	0	0.0	41	29	34.0	0	0	0	5	1	3.0
6	4.15	0.00	1.66	0	0	0.0	41	0	32.0	0	0	0	3	0	2.0
7	3.87	0.18	1.62	2	0	0.0	51	29	39.0	0	0	0	3	1	2.0
8	3.41	0.19	1.67	2	0	0.0	47	29	39.0	0	0	0	4	1	2.0
9	3.76	0.18	1.65	0	0	0.0	45	30	40.0	0	0	0	4	1	2.5
10	3.25	0.00	1.22	1	0	0.0	46	0	33.0	0	0	0	5	0	2.5
11	3.10	0.00	1.26	10	0	0.5	46	26	36.0	0	0	0	3	0	3.0
12	3.41	0.89	2.22	15.00	0	1	49	32	42	0	0	0	3	2	3
13	3.34	0.04	2.54	13	0	1.0	44	1	34.0	0	0	0	3	0	3.0
14	3.28	1.83	2.85	3	0	0.0	47	27	38.0	0	0	0	3	2	3.0
15	3.04	0.00	2.41	4	0	0.0	47	0	32.0	0	0	0	4	0	3.0
16	2.85	1.23	2.25	0	0	0.0	46	12	37.0	0	0	0	3	1	3.0
17	2.79	0.00	1.75	0	0	0.0	45	0	31.0	0	0	0	3	0	2.0
18	3.79	1.72	2.86	0	0	0.0	50	41	0.0	0	0	0	3	2	2.0
19	2.61	1.18	2.13	0	0	0.0	43	29	37.0	0	0	0	3	2	2.0
20	3.76	0.27	2.52	0	0	0.0	44	5	36.0	0	0	0	3	0	2.0
21	2.56	0.00	1.97	0	0	0.0	47	0	36.0	0	0	0	3	0	2.0
22	2.83	1.04	2.42	2	0	0.0	48	30	40.0	0	0	0	3	1	2.0
23	2.23	1.50	2.00	0	0	0.0	56	32	45.0	0	0	0	4	1	2.0
24	3.17	0.00	1.22	13	0	1.0	54	0	41.0	0	0	0	8	0	3.0
25	3.43	0.18	1.47	2	0	0.0	47	3	37.0	0	0	0	4	0	3.0
26	3.34	0.18	1.33	8	0	0.5	48	5	35.0	0	0	0	4	1	3.0
27	3.50	0.00	1.38	14	0	0.5	51	0	34.0	0	0	0	3	0	1.5
28	3.55	0.20	1.33	6	0	0.5	46	32	39.0	0	0	0	5	2	3.0
29	3.90	0.00	1.64	0	0	0.0	50	0	37.0	0	0	0	4	0	2.5
30	4.12	0.18	1.86	7	0	0.5	56	35	44.0	0	0	0	4	1	2.5

令和6年度 排ガス中のばい煙濃度等

10月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm <sup>3</sup> 以下 排出基準:150mg/Nm <sup>3</sup> 以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	3.78	0.00	1.54	6	0	0.0	51	2	35.0	0	0	0	4	0	2.0
2	3.55	0.00	1.70	24	0	2.0	53	0	41.0	0	0	0	4	0	1.5
3	0.25	0.01	0.22	0	0	0.0	-	-	-	-	-	-	3	0	2.0
4	0.30	0.18	0.25	0	0	0.0	-	-	-	-	-	-	3	2	2.0
5	0.30	0.18	0.25	0	0	0.0	-	-	-	-	-	-	3	1	2.0
6	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	3	1	3.0
7	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	3	1	2.0
8	0.25	0.00	0.23	9	0	0.0	-	-	-	-	-	-	5	0	3.0
9	0.25	0.15	0.24	1	0	0.0	-	-	-	-	-	-	5	2	4.0
10	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	5	3	4.0
11	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	6	3	4.0
12	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	5	3	4.0
13	0.25	0.18	0.24	0	0	0.0	-	-	-	-	-	-	5	3	5.0
14	0.25	0.01	0.23	1	0	0.0	-	-	-	-	-	-	5	0	4.0
15	0.25	0.00	0.23	2	0	0.0	-	-	-	-	-	-	6	2	3.0
16	0.25	0.18	0.25	2	0	0.0	-	-	-	-	-	-	2	2	2.0
17	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	3	2	2.0
18	0.29	0.18	0.25	0	0	0.0	-	-	-	-	-	-	3	1	2.0
19	0.25	0.12	0.23	1	0	0.0	-	-	-	-	-	-	2	1	2.0
20	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	3	2	2.0
21	0.29	0.11	0.22	0	0	0.0	-	-	-	-	-	-	3	2	3.0
22	0.25	0.00	0.23	1	0	0.0	-	-	-	-	-	-	4	0	2.0
23	0.25	0.18	0.25	1	0	0.0	-	-	-	-	-	-	3	1	2.0
24	0.30	0.14	0.25	0	0	0.0	-	-	-	-	-	-	5	2	3.0
25	0.25	0.18	0.25	0	0	0.0	-	-	-	-	-	-	4	2	3.0
26	0.25	0.15	0.24	0	0	0.0	-	-	-	-	-	-	4	2	3.0
27	0.25	0.18	0.25	0	0	0	-	-	-	-	-	-	4	2	3
28	0.28	0.18	0.25	0	0	0.0	-	-	-	-	-	-	4	2	3.0
29	0.25	0.13	0.21	0	0	0.0	-	-	-	-	-	-	4	2	3.0
30	0.25	0.11	0.22	0	0	0.0	-	-	-	-	-	-	4	2	3.0
31	0.25	0.15	0.21	0	0	0.0	-	-	-	-	-	-	4	2	3.0

令和6年度 排ガス中のばい煙濃度等

11月	ばいじん濃度(mg/Nm <sup>3</sup> )			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値: 20mg/Nm <sup>3</sup> 以下 排出基準: 150mg/Nm <sup>3</sup> 以下			維持管理基準: 100ppm以下			管理値: 70ppm以下 排出基準: 250ppm以下			管理値: 20ppm以下			管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.25	0	0.24	0	0	0	-	-	-	-	-	-	2	0	2
2															
3															
4															
5															
6															
7															
8															
9	0.62	0.01	0.42	44	1	22.0	60	0	32.0	0	0	0	6	0	4.0
10	0.92	0.37	0.72	16	0	1.0	44	28	36.0	0	0	0	6	3	4.0
11	0.74	0.03	0.05	2	0	0.0	54	1	39.0	0	0	0	5	0	3.0
12	0.64	0.00	0.33	9	0	0.5	45	27	37.0	0	0	0	4	0	3.5
13	0.58	0.06	0.35	2	0	0.0	49	32	40.0	0	0	0	7	1	3.5
14	0.54	0.00	0.30	3	0	0.0	49	37	43.0	0	0	0	5	0	3.0
15	0.57	0.02	0.29	6	0	0.0	48	1	37.0	0	0	0	4	0	3.0
16	1.00	0.13	0.46	3	0	0.0	45	30	40.0	0	0	0	4	2	3.5
17	0.91	0.18	0.46	16	0	1.0	59	32	41.0	0	0	0	7	2	4.0
18	0.88	0.01	0.40	2	0	0.0	56	29	46.0	0	0	0	4	0	2.5
19	0.40	0.00	0.26	4	0	0.0	46	0	37.0	0	0	0	5	0	3.5
20	0.40	0.00	0.26	4	0	0.0	46	0	37.0	0	0	0	5	0	3.5
21	0.70	0.00	0.29	14	0	1.5	43	0	32.0	0	0	0	8	0	4.5
22	0.44	0.11	0.27	9	0	0.5	42	23	36.0	0	0	0	7	1	4.5
23	0.41	0.03	0.27	13	0	0.5	44	31	38.0	0	0	0	7	1	3.5
24	0.62	0.08	0.30	1	0	0.0	41	30	37.0	0	0	0	6	1	3.5
25	0.94	0.02	0.42	3	0	0.0	43	33	40.0	0	0	0	5	0	2.0
26	0.94	0.10	0.38	0	0	0.0	45	8	35.0	0	0	0	6	0	3.5
27	0.78	0.11	0.33	0	0	0.0	46	30	37.0	0	0	0	7	2	4.5
28	0.70	0.11	0.31	14	0	0.5	44	31	39.0	0	0	0	7	2	4.5
29	0.86	0.11	0.34	1	0	0.0	43	31	39.0	0	0	0	8	2	4.5
30	0.72	0.11	0.32	0	0	0.0	13	29	39.0	0	0	0	7	2	5.0









