

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1032	1008	976	999	1016	1022	1015	1055	1029	978	953	958	955	909	917	907	912	981	976	936	989	1026	1035	1032	
	2号炉	1045	1001	999	1000	1019	1018	1034	1039	1020	990	958	960	964	974	947	934	945	999	995	991	977	967	968	968	
2	1号炉	1034	1070	1054	1063	1023	1074	1064	1099	945					964	988	988	952	983	1012	1026	1036	1040	1004	8:30~14:25給じん停止	
	2号炉	979	990	997	1013	1013	993	1030	995	952	959	959	965	931	968	961	961	959	962	956	963	942	912		981	21:45~23:35給じん停止
3	1号炉	997	1003	1003	998	1011	999	1034	1007	1023	1035	1024	1008	992	987	955	964	964	947	974	1022	1007	983	1005	1030	
	2号炉	940	984	998	998	974	967	991	1001	884					961	944	968	928	932	942	965	975	938	943	932	8:31~13:07給じん停止
4	1号炉	997	1012	1000	1012	1038	1020	989	987	988	1006	985	943	924	916	974	940	994	937	1011	1059	1033	982	982	1010	
	2号炉	939	1007	1031	984	1014	1020	1003	1000	978	951	961	913	914	948	1005	1045	1014	958	1039	1107	1050	1064	898	1013	
5	1号炉	997	1010	1024	1026	1017	1014	1012	1001	1003	1014	1004	966	1003	1002	983	947	933	966	967	965	956	995	1017	999	
	2号炉	1069	1033	1005	1050	1010	1082	1091	1060	1067	1069	1047	1010	1001	1017	1023	993	971	961	965	1024	1038	1047	1070	1065	
6	1号炉	1008	999	983	972	983	976	986	986	991	1000	999	991	962	984	998	988	1019	1020	993	1030	1013	1016	981	959	
	2号炉	1015	1050	1036	976	991	991	1036	1021	994	1002	1031	1013	1041	1044	1045	1018	1090	1036	1045	1054	1061	994	1067	1015	
7	1号炉	981	970	969	924	957	986	993	989	976	976	907	923	988	972	970	933	938	949	923	928	911	934	936	978	
	2号炉	1012	1018	982	992	1017	960		1005	1007	1000	1014	1034	1007	1033	1040	1018	1014	982	999	1073	1008	1046	984	1013	5:24~7:02給じん停止
8	1号炉	948	991	998	1009	958	970	982	986	984	951	922	935	902	883	919	925	905	921	935	953	966	965	943	991	
	2号炉	1030	1003	1039	1038	1002	1011	1066	1033	1013	999	994	1003	981	991	983	968	980	979	1002	1014	996	1027	1059	1055	
9	1号炉	944	952	924	942	921	957	941	925	941	976	950	956	953	974	970	962	957	937	946	971	979	987	1014	994	
	2号炉	1031	994	990	992	990	990	998	977	1011	984	992	1023	1002	1009	988	1005	976	985	1025	1026	995	1028	1007	1029	
10	1号炉	990	992	998	973	996	974	972	1006	983	977	939	941	972	1051	1062	1005	970	983	986	1003	998	1021	1025	995	
	2号炉	999	1013	1031	1053	1075	999	1005	962	889					1010	994	985	986	982	974	990	1000	991	987	1031	8:31~13:24給じん停止
11	1号炉	1001	997	1036	1002	991	1004	1048	1055	913																定常運転~立ち下げ(8:48)
	2号炉	1011	986	987	989	989	992	1006	1037	1059	1031	1007	968	984	998	997	967	976	961	973	988	978	998	1001	1007	
12	1号炉																									休炉
	2号炉	974	990	1023	1001	1022		991	1036	1021	969	1020	1023	968	939	981	1007	1004	989	1017	1018	971	960	1027	983	4:50~6:23給じん停止
13	1号炉																									休炉
	2号炉	999	989	983	990	1007	1012	988	1016	994	999	1003	1017	998	985	1027	1021	1041	982	976	989	975	982	967	959	
14	1号炉																									休炉
	2号炉	948	986	951	965	978	955	1012	974	959	943	968	974	961	966	1014	1016	990	976	963	968	989	971	999	987	
15	1号炉																									休炉
	2号炉	965	986	991	982	987	977	980	984	967	982	967	981	984	947	981	949	947	959	950	955	1025	1034	1004	990	

4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉																									休炉
	2号炉	1022	1001	1008	1011	995	975	965	960	862	912	960	976	954	954	959	964	992	1001	985	991	997	998	1022	1005	
17	1号炉																									休炉
	2号炉	1003	960	964	969	990	982	973	1001	986	1018	977	996	989	967	951	993	957	996	1006	1024	1005	1052	1042	1057	
18	1号炉																									休炉
	2号炉	1006	1014	1037	1012	988	1043	1004	1022	1018	998	993	985	957	958	981	1027	1023	1003	998	1016	1006	1007	1005	1033	
19	1号炉																									休炉
	2号炉	1002	978	991	989	1004	966	967	958	970	986	978		956	981	951	978	957	962	1014	972	984	1001	1014	986	10:17~12:00給じん停止
20	1号炉																									休炉
	2号炉	982	995	993	1004	1006	1004	975	943	968	1000	983	972	962	1001	982	994	995	983	986	988	983	1002	989	1023	
21	1号炉																									休炉
	2号炉	1016	1042	1030	1054	1045	1043	978	979	1031	1009	1014	1023	1011	1035	1006	1036	1047	1045	1076	1014	1006	1026	1037	1017	
22	1号炉																									休炉
	2号炉	1030	975	1000	1031	1048	1035	1024	1021	1030	1009	1021	1004	977	1006	987	994	1004	975	961	971	990	992	1014	1006	
23	1号炉																									休炉
	2号炉	991	980	998	1020	975	964	972	979	979	998	987	996	964	949	966	968	966	713			1015	967	981	979	17:03~20:32給じん停止
24	1号炉																									休炉
	2号炉	976	985	999	1007	1013	1000	993	985	1007	1026	1016	1004	996	1008	1009	992	1020	991	1017	1037	1001	973	986	1004	
25	1号炉							801	877	895	923	913	924	926	928	854	928	953	896	915	844	851	928	918	905	立ち上げ~定常運転(6:52)
	2号炉	986	1007	995	975	975	991	1000	993	985	992	976	966	979	997	995	1007	985	968	974	1055	973	1012	998	982	
26	1号炉	903	928	924	914	952	953	933	911	918	923	943	906	920	889	937	900	918	930	918	971	914	916	920	925	
	2号炉	985	1011	998	980	999	962					951	942	924	957	990	988	944	957	949	973	949	990	987	1020	5:16~10:11給じん停止
27	1号炉	946	961	928	946	932	930	949	944	937	971	926	895									921	940	940	709	11:11~19:02給じん停止 定常運転~立ち下げ(22:05)
	2号炉	947	951	914	966	939	954	949	945	949	963	954	967	935	973	948	962	943	978	973	1009	987	979	944	936	
28	1号炉																									休炉
	2号炉	946	931	936	947	968	964	970	979	970	963	954	951	967	982	1063	964	960	961	945	946	965	957	975	987	13:16~15:02給じん停止
29	1号炉																									休炉
	2号炉	982	973	986	978	967	979	963	971	980	968	975	979	987	951	950	966	960	972	1000	1012	999	992	973	985	
30	1号炉																									休炉
	2号炉	977	977	961	975	923		1007	978	976	974	956	989	967	918	940	937	921	932	944	931	956	904		956	4:25~6:27給じん停止 21:33~23:02給じん停止

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	969	931	946	971	967	925	940	987	963	944	964	955	970	978				1059	955	942	972	962	965	967	14:09~18:04 給じん停止
2	1号炉																									休炉
	2号炉	1004	971	987	977	977	981	979	976	957	970	951	946	917	918	917	920	950	939	947	970	941	955	915	22:22~24:04 給じん停止	
3	1号炉																									休炉
	2号炉	961	912	957	959	962	920	953	954	950	939	958	960	964	949	995	952	956	973	987	930	960	980	947	966	
4	1号炉																									休炉
	2号炉	941	962	954	940	931	967	942	972	964	994	992	980	975	954	1000	991	945	999	974	981	980	981	968	979	13:10~13:13 給じん停止
5	1号炉																									休炉
	2号炉	977	973	979	1019	1015	999	1013	1003	994	989	989	1011	1006	993		1015	1019	958	1010	985	991	987	996	976	13:50~15:02 給じん停止
6	1号炉																									休炉
	2号炉	940	948	987	990	999	975	949	983	982			922	969	971	957	970	1011	965	1003	1004	1011	997	1033	1033	8:44~11:02 給じん停止
7	1号炉																									休炉
	2号炉	1027	998	999	1044	1020	1019	997	1010	916				1081	982	955	949	943	968	984	986	1009	1004	987	989	8:37~13:00 給じん停止
8	1号炉																									休炉
	2号炉	997	992	1005	993	975	958	961	976	963	960	968	977	971	967	935	947	956	944	965	982	998	975	956	22:55~24:05 給じん停止	
9	1号炉																									休炉
	2号炉	939	972	981	970	968	988	963	967	979	976	957	922	930	952	954	979	929	950	932	923		958	939	958	19:37~21:11 給じん停止
10	1号炉	547	602	732	845	900	948	914	928	924	896	894	896	913	918	920	929	914	925	919	943	941	1006	985	957	立上げ~定常運転 (3:46)
	2号炉	963	959	966	927	937	940	938	952	946	937	950	969	880	940	978	925	919	956	942	959	952	944	948	936	
11	1号炉	938	946	961	992	987	998	979	974	977	1004	1036	1011	1014	1019	964	955	949	934	937	978	1017	985	1012	1048	
	2号炉	934	948	988	981	1001		1034	1015	983	990	1005	960	985	1000	982	964	978	986	999	1007	1013	997	955	958	5:36~7:21 給じん停止
12	1号炉	985	965	1028	1015	1027	991	1012	1000	976	1004	994	1009	1011	990	995	1002	993	988	958	975	965	944	953	975	
	2号炉	1018	1043	976	1012	1006	1012	1025	971	974	1013	961	993	969	990	991	935	999	1001	967	965	980	986	995	973	
13	1号炉	963	963	956	989	968	986	983	1034	1008	973	931	939	930	962	976	992	944	937	939	961	982	977	986	999	
	2号炉	986	973	986	1013	983	981	935	981	971	972	992	985	971	983	981	949	952	975	951	972	975	974	929	975	
14	1号炉	1004	1017	994	965	949	936	977	942	941	979	1007	952	915	898	937	903	907	933	941	933	937	978	999	1021	
	2号炉	957	942	1006	970	966	961	953	944	968	1001	1001	939	948	967	984	947	962	964	957	988	964	991	978	1003	
15	1号炉	1007	1013	1001	982	964	981	980	1002	1004	1004	982	992	977	1006	1013	996	978	980	993	1004	1061	1021	1035	1066	
	2号炉	995	957	969	991	979	969	1003	991	971																定常運転~立下げ (8:45)

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	948	930	910	928	926	908	961	941	946	942	973	977	976	941	922	954	943	938	967	959	961	972	960	979	
	2号炉																									休炉
2	1号炉	963	970	977	981	990	947	964	970	988	993	1005	1019	993	1013	1017	1004	1001	987	1007	998	995	1001	998	992	
	2号炉																									休炉
3	1号炉	1007	990	1000	989	948	991	995	1003	992	999	1011	1009	1000	984	1005	991	955	1015	1014	1017	1010	983	978	966	
	2号炉																									休炉
4	1号炉	968	988	990	1001	1001	1008	1007	985	976	962	991	980	988	986	994	976	996	1003	1011	1027	1025	967	984	976	
	2号炉																									休炉
5	1号炉	983	955	971	967	942	944	950	979	995	997	1002	972	942	988	952	972	991	957	946	953	980	979	999	1003	
	2号炉																									休炉
6	1号炉	978	988	1000	990	994	979	963	964	895				980	928	949	939	951	973	971	957	986	979	954	957	8:30~12:19 給じん停止
	2号炉																									休炉
7	1号炉	975	982	950	956	947	953	941	942	950	963	955	949	957	939	945	948	971	959	962	1003	985	972	963	947	
	2号炉																	948	1046	1086	1077	1037	1023	990	1023	立上げ~定常運転(16:25)
8	1号炉	969	989	985	991	977	993	1000	993	985	969	995	984	981	988	986	997	984	954	999	1000	957	966	976	998	
	2号炉	1023	989	1027	986	1020	1025	995	995	988	987	983	1012	1014	1000	1050	1066	1039	1034	1044	1074	1024	1020	1024	1001	
9	1号炉	998	965	1000	979	959	946	908	914	894	864	969	974	983	979	982	1010	1002	998	956	992	985	990	1004	1012	8:45~10:04 給じん停止
	2号炉	994	1047	1043	1038	984	1014	1062	1018	1011	1008	1015	1019	1032	1002	1007	1021	1040	1002	980	1020	959	989	991	1000	
10	1号炉	992	1022	1006	998	978	993	1007	979	1004	991	966	887	884	945	977	1005	950	957	963	941	952	957	988	986	
	2号炉	1009	1001	953	1005	985	976	992	955	982	972	989	965	952	948	966	980	963	955	958	958	972	971	946	992	
11	1号炉	982	994	982	986	984	983	982	1003	945	989	974	993	955	975	957	951	947	990	966	999	992	993	993	970	
	2号炉	952	981	978	956	948	956	926	973	970	976	950	931	932	922	934	947	954	965	972	999	986	974	974	935	
12	1号炉	940	981	1004	963	936	954	933	976	971	968	990	973	963	960	957	967	937	1006	977	985	997	1004	1013	984	
	2号炉	962	963	979	972	946	946	985	965	941	979	871	992	913	945	972	956	952	986	983	958	960	982	994	967	10:06~12:00 給じん停止
13	1号炉	943	996	1000	980	989	981	1010	971	866				967	922	908	919	931	957	973	1004	982	996	1015	1009	8:30~12:30 給じん停止
	2号炉	964	990	1025	1015	986	951	944	970	972				1009	934	937	977	977	1011	949	990	969	980	955	981	9:50~12:28 給じん停止
14	1号炉	1008	995	985	969	958	993	994	975	1000	1033	959	929	952	949	975	970	939	958	989	995	1004	984	984	983	
	2号炉	959	963	952	1002	980	975	988	999	988	967	918	965	959	918	951	967	971	954	962	953	962	1008	1012	999	
15	1号炉	976	968	989	978	984	9890	1005	1003	962	1005	969	991	995	975	1030	999	1007	1023	1001	1019	1036	993	1009	1050	
	2号炉	1003	1022	899	980	1036	1035	1010	990	998	997	1033	1028	1049	1033	1015	1030	1017	988	977	1014	1036		1015	1013	21:50~23:19 給じん停止

6月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	1025	985	988	999	994	991	1019	1011	1006	1032	994	996	986	978	997	1023	1022	987	994	1001	999	1019	985	1009	
	2号炉	983	1072	1045	1034	1013	1037	1027	1025	1008	994	926	1020	979	1007	1007	1000	989	984	1017	1022	1032	1011	1027	1006	
17	1号炉	996	1023	1006	996	990	1003	1002	1006	999	1027	983	946	982	983	989	962	1003	1028	973	964	943	952	1008	1000	
	2号炉	1031	980	983	1004	1004	1008	1017	1016	1037	1011	983	997	1037	1004	1000	1034	947	965	979	992	996	1039	981	1059	
18	1号炉	966	998	990	1011	997	1015	988	987	994	965	971	989	968	955	964	958	964	940	993	992	896	1050	981	953	
	2号炉	1030	921	991	970	1002	1019	1028	1030	997		920	982	970	1007	1023	990	1030	1040	1052	1024	942	1099	999	967	9:50~11:15 給じん停止
19	1号炉	972	979	1003	995	995	957	968	980			1013	1038	942	959	967	931	979	917	952	988	948	953	988	970	8:31~11:51 給じん停止
	2号炉	992	1033	969	994	993	991	1007	1010	986	994	1025	990	1011	1043	993	993	983	997	995	1035	1009	998	984	1000	
20	1号炉	983	985	990	984	991	983	965	962	946	944	970	959	949	960	979	984	984	980	980	978	966	979	977	974	
	2号炉	1008	1011	1061	983	969	855		947	841					1015	1006	959	992	1001	978	998	1040	1027	1025	975	1005
21	1号炉	997	985	977	983	981	975	1008	967	1009	1021	983	899	935	902	940	953	940	969	979	966	962	990	992	991	
	2号炉	1048	998	1006	1001	990	1002	1002	1001	974	1008	1000	961	966	971	1001	983	991	997	1020	1023	994	1028	1033	1018	
22	1号炉	975	1007	974	941	960	978	961	958	962	964	946	974	948	952	943	928	955	980	996	997	993	997	962	959	
	2号炉	997	955	983	1014	1027	1022	1061	1045	1043	1034	958	1028	988	1000	1001	968	1027	1006	1033	1038	997	1019	1017	1016	
23	1号炉	973	1000	1009	995	977	993	1015	995	991	975	975	970	991	1002	993	985	1014	991	992	986	991	997	987	1008	
	2号炉	1043	1013	1045	1040	987	1015	1037	1029	1036	1035	1016	1028	1033	1020	1016	992	993	1031	1030	1003	1022	1053	1031	1034	
24	1号炉	996	1026	967	949	954	984	1019	1011	979	991	975	926	928	924	910	937	953	972	989	978	944	942	942	1013	
	2号炉	1038	1019	1045	1001	983	1040	1077	1058	1056	1004	1018	986	947	971	982	982	937	990	1000	998	992	1006	1032	997	
25	1号炉	993	976	963	968	977	971	948	935	904																定常運転~立下げ(8:58)
	2号炉	1023	978	1011	1052	1006	967	979	962	939	971	963	1044	990	982	1027	976	1004	949	975	985	1012	1009	996	1003	
26	1号炉																									休炉
	2号炉	1007	994	994	990	1012	1002	1013	996	995	1029	1039	982	974	956	985	1018	993	1023	1001	994	1017	1001	1013	995	
27	1号炉																									休炉
	2号炉		1035	1034	1030	1014	1015	1022	950	851		1008	983	959	955	959	985	962	977	1001	1012	966	954	973	972	立上げ~定常運転(1:48) 8:34~10:08 給じん停止
28	1号炉																									休炉
	2号炉	963	969	966	985	990	997	1011	997	1017	990	1018	1036	955	981	988	1019	976	985	999	977	1060	1027	1041	998	
29	1号炉																									休炉
	2号炉	971	1004	1007	1013	1007	997	986	997	981	981	991	1009	1023	1035	1047	1036	994	1000	1033	1017	1014	1006	1042	1028	
30	1号炉																									休炉
	2号炉	1036	1024	1043	1030	1032	1030	1029	1051	999	997	1006	995	1007	1007	1022	1006	1020	1017	1049	1031	1013	1051	1054	1038	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	1037	1033	1002	1044	1017	1014	1015	1002	999	1019	1021	988	989	967	949	940	925	945		967	943	951	930	949	17:37~19:01給じん停止
2	1号炉																									休炉
	2号炉	956	996	1004	996	979	967	968	951	972	947	952	963	952	965	1011	996	999	1002	972	1000	987	1019	1001	995	
3	1号炉																									休炉
	2号炉	1003	977	997	973	994	1009	984	977	970	958	963	958	948	982	990	979	977	970	938	982	1008	977	1001	1008	
4	1号炉																									休炉
	2号炉	1008	1026	1044	1006	1017	1014	995	982	904				1005	995	973	982	990	1006	989	988	982	994	989	998	8:34~12:05給じん停止
5	1号炉																									休炉
	2号炉	1001	988	989	984	1008	962	986	972	960	982	995	998	997	980	978	955	979	1016	990	1002	984	1033	1017	1002	
6	1号炉																									休炉
	2号炉	1007	1000	1012	1012	1009	1038	1022	1018	1023	996	979	990	998	1017	1039	1029	998	1012	1023	1003	988	1024	1008	1014	
7	1号炉																									休炉
	2号炉	1023	921	991	970	981	1003	1019	1017	1030	994	990	1006	996	980	1014	1044	1031	1039	1027	1013	1018	1020	1022	1031	
8	1号炉																									休炉
	2号炉	1027	1012	1027	1019	1046	1021	998	1004	1029	1022	1008	1026	1026	1008	1031	1020	1003	1011	1004	1054	969	919	974	984	
9	1号炉																									休炉
	2号炉	997	1014	1014	1022	999	970	990	990	1022	1031	1024	1020	997	971	975	947	973	989	1008	1010	1011	988	993	988	
10	1号炉																									休炉
	2号炉	981	985	1017	976	976	979	1003	981	972	979	975	966	978	985	1008	1015	989	1003	1014	1051	984	993	1020	2021	
11	1号炉																									休炉
	2号炉	1009	970	1015	998	975	999	1003	1023	989			1085	963	920	939	941	968	958	977	966	970	972	986	981	8:30~11:42給じん停止
12	1号炉																									休炉
	2号炉	1013	1022	1026	986	1011	1000	1018	1021	1031	993	973	1011	985	1007	991	990	1050	1022	995	980	1027	995	1004	981	
13	1号炉																									休炉
	2号炉	1008	995	965	973	1004	1002	1029	1021	1008	1006	991	1018	1019	1010	1032	988	1003	1009	1020	1001	1035	1015	990	1009	
14	1号炉																									休炉
	2号炉	992	961	993	1009	1008	1018	1011	973	1013	993	1015	990	1007	988	970	1002	968	1030	1026	1035	983	960	977	1009	
15	1号炉																									休炉
	2号炉	1014	1009	1011	1012	982	1015	998	1006	966	1002	998	998	1002	973	952	992	1007	973	1006	1002	999	978	983	976	

7月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉																									休炉
	2号炉	998	1000	987	997	981	977	979	909	935	927	967	927	913	916	925	922	951	946	950	957	965	969	973	981	
17	1号炉																									休炉
	2号炉	959	948	976	944	950	951	960	966	951	943	951	968	933	920	964	941	959	954	965	951	980	933	970	979	
18	1号炉																									休炉
	2号炉	976	960	948	965	947	940	973	976	863			961	954	937	915	930	940	939	939	956	990	992	972	961	8:30~11:35給じん停止
19	1号炉															865	957	945	961	926	956	973	961	981	立上げ→定常運転(15:02)	
	2号炉	984	986	975	966	969	969	969	963	973	991	988	973	959	982	991	988	985	989	992	993	995	992	953	1001	
20	1号炉	982	964	943	965	965	982	987	954	955	972	963	949	947	931	978	966	965	974	972	952	953	983	942	956	
	2号炉	969	960	960	913	952	986	984	960	982	977	944	973	974	981	985	964	967	1030	935	974	974	954	930	935	
21	1号炉	973	1000	987	1066	1036	1054	1039	1024	1020	1040	1009	1012	1019	992	1011	1014	1023	1054	1041	1029	1025	1004	1004	1014	
	2号炉	934	945	955	960	964	951	970	978	937	945	943	961	952	987	975	968	966	964	972	979	949	971	938	937	
22	1号炉	1003	1012	1059	1059	1063	1040	1028	1006	1029	1024	1038	1028	975	956	967	952	962	999	948	1001	1005	1028	1078	1061	
	2号炉	920	961	965	987	974	983	998	981	983	968	949	953	920	924	932	943	978	942	944	933	974	970	964	959	
23	1号炉	1047	1067	1054	1032	1036	1046	1035	1039	1024	1027	949	966	1000	1010	972	972	985	971	964	969	968	997	1003	1003	
	2号炉	955	951	973	968	960	962	991	987	989	951	936	928	959	935	944	937	953	948	1047	950	924	927	943	960	
24	1号炉	977	985	994	981	958	996	965	963	959	998	1019	1006	1022	1042	1051	1062	1069	1066	1024	1051	1027	1030	1059	1071	
	2号炉	951	942	947	941	933	940	940	935	909	961	939	941	927	942	919	917	928	951	955	943	937	944	936	965	
25	1号炉	1045	1027	1075	1013	998	992	1016	1027	1024	1000	971	969	959	967	975	973	990	992	964	1010	1012	1027	1029	1043	
	2号炉	962	929	941	932	921	904	904	893	925			939	897	899	896	1030	968	971	993	978	967	984	958	988	8:32~11:01給じん停止
26	1号炉	1014	1018	1012	1008	976	974	1008	1002	856				990	983	971	974	978	1003	1000	1003	972	963	1003	989	8:30~12:10給じん停止
	2号炉	1000	969	1007	994	980	980	970	969	967	978	984	1008	972	944	953	988	986	1024	1008	999	989	945	972	933	
27	1号炉	959	980	985	983	1009	1020	1037	1052	1047	1025	1053	1046	1032	1002	1036	1000	1021	1005	1003	1004	998	993	998	989	
	2号炉	935	928	970	954	973	986	990	967	980	988	986	985	978	960	985	935	955	968	982	944	972	981	964	953	
28	1号炉	963	1015	991	1002	998	1025	1020	1007	1012	983	996	997	1011	1009	1045	993	1047	1023	998	986	998	984	992	993	
	2号炉	941	1004	966	978	954	952	977	965	960	952	973	960	943	962	968	927	960	921		959	967	941	967	964	17:30~19:05給じん停止
29	1号炉	1012	985	976	1015	1006	985	990	976	990	991	1012	988	958	978	955	983	967	979	968	991	989	980	1005	993	
	2号炉	941	964	950	944	955	970	920	897	913	893	928	991	936	925	921	908	948	935	954	930	951	955	967	950	
30	1号炉	989	986	969	987	989	976	976	982	998	996	986	993	986	978	982	990	982	1010	1006	994	973	940	972	1010	
	2号炉	1000	956	941	955	961		941	937	971	940	939	956	942	951	924	929	939	974	952	946	961	968	950	940	4:57~6:05給じん停止
31	1号炉	1044	1013	974	1010	997	1005	1009	1001	996	1026	1026	1009	1029	1018	1035	1011	1015	972	975	978	989	946	961	985	
	2号炉	948	915	933	934	977	977	939	951	900	1001	905	794	739	675	551	452	408	376	353	402	364	343			定常運転~立下げ(19:42)

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	958	988	970	960	926		952	996	973	926	974	1005	981	974	975	990	988	871							4:54~6:07給じん停止 17:05~24:22給じん停止
	2号炉																									休炉
2	1号炉	912	955	992	979	984	969	984	999	903			926	938	954	920	956	950	956	1004	990	966	998	1000		8:37~12:29給じん停止
	2号炉																									休炉
3	1号炉	986	975	986	986	980	984	995	992	995	994	1000	989	997	1013	999	994	995	998	1003	1000	1013	1017	1013	1013	
	2号炉																									休炉
4	1号炉	1002	1003	1013	1024	1031	1009	1011	988	970	1003	999	992	996	999	1001	994	990	1026	1006	979	1007	1022	1013	1010	
	2号炉																									休炉
5	1号炉	1000	990	1004	1004	999	999	1007	1009	994	989	1005	991	974	951	969	972	986	1007	994	982	971	987	967	991	
	2号炉																									休炉
6	1号炉	1008	1004	978	954	987	960	976	976	982	941	941	975	954	937	963	944	970	986	966	975	1000	1004	1008	969	
	2号炉																									休炉
7	1号炉	971	973	971	976	972	996	987	964	957	964	974	975	977	972	985	959	981	990	991	981	1012	987	970	1006	
	2号炉																									休炉
8	1号炉	1008	989		963	951	996	1026	965	983	1011	984	995	973	943	937	967	971	968	984	975	990	977	965	983	1:15~3:04給じん停止
	2号炉																									休炉
9	1号炉	976	970	980	977	996	1003	965	970	841		1017	960	959	947	948	964	953	966	947	936	960	932	977		8:32~11:53給じん停止
	2号炉										984	926	962	960	971	973	976	959	922	929	945	966	893			立上げ~定常運転(10:05) ~立下げ(22:39)
10	1号炉	999	982	994	987	977	967	977	967	962	949	949	948	946	960	982	999	1007	966	947	983	981	999	963	977	
	2号炉																									休炉
11	1号炉	1000	996	1000	990	987	1000	1001	984	958	952	974	997	984	980	979	986	994	946	958	1003	1000	1023	1056	999	
	2号炉							899	993	964	981	984	1013	995	956	964	965	1006	989	1007	1014	1030	1013	1016		立上げ~定常運転(7:34)
12	1号炉	939	953	967	989	995	979	990	992	997	1017	1011	1012	1016	1008	1038	1002	1004	1000	983	991	986	973	968	944	
	2号炉	1004	972	969	980	960	965	995	995	982	996	1003	991	988	989	980	977	1001	973	1002	998	986	964	969	966	
13	1号炉	955	995	984	998	1010	1005	993	970	992	957	972	962	931	962	972	964	915	915	938	953	923	919	951	960	
	2号炉	982	976	992	970	976	992	978	975	973	935	982	1010	978	990	1026	1000	1020	975	964	985	980	956	980	971	
14	1号炉	973	970	968	952	975	979	982	980	963	970	960	956	963	952	952	972	971	955	986	940	946	955	982	973	
	2号炉	991	982	994	1009	996	992	998	1014	994	1022	1026	989	966	983	1000	1024	995	989	1020	1017	1023	997	1021	1020	
15	1号炉	974	970	939	976	964	926	964	916	835				967	970	923	906	910	934	983	981	973	968	956	971	8:32~12:15給じん停止
	2号炉	1014	1019	984	977	997	1015	1018	1011	1013	1027	1015	1016	968	988	996	983	981	995	1009	1002	994	973	997	1032	

8月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉	927	934	955	975	960	959	969	964	975	969	937	933	934	948	953	967	950	972	964	957	976	966	997	936	
	2号炉	971	974	997	996	987	969	997	1029	906				1029	954	975	967	958	974	990	976	974	988	1001	999	8:32~12:29給じん停止
17	1号炉	923	969	970	981	991	972	960	976	990	966	946	923	923	894	889	931	959	959	967	949	965	980	998	975	
	2号炉	976	1012	973	968	985	992	970	994	1021	995	971	988	1021	972	976	1013	974	965	986	977	981	989	1009	971	
18	1号炉	979	951	928	945	980	958	983	984	984	996	981	970	954	970	975	946	908	969	971	967	934	943	996	967	
	2号炉	986	1010	974	995	1017	1001	1000	991	1001	1002	981	954	968	984	1000	1001	990	1006	992	1005	963	987	1005	993	
19	1号炉	977	971	945	946	954	937	925	909	960	973	973	996	950	928	955	959	952	953	966	974	983	942	947	988	
	2号炉	1009	982	984	993	1016	993	1014	973	989	1006	1000	1014	976	984	1013	993	1004	1009	988	990	1011	996	998	975	
20	1号炉	983	966	925	978	978	978	987	974	929				973	937	939	922	956	915	925	927	931	945	930	980	8:38~12:16給じん停止
	2号炉	991	987	994	1024	1025	1017	983	1012	1008	1009	988	1004	1002	972	950	957	988	996	982	966	995	974	992	1023	
21	1号炉	969	973	991	979	995	964	998	936	957	951	963	974	958	953	984	954	952	1006	981	978	941	933	990	987	
	2号炉	1022	983	996	979	1024	993	985	989	971			1061	993	1002	985	989	947	945	1011	1028	1004	1013	1006	1028	8:31~11:34給じん停止
22	1号炉	991	1000	1002	989	960	977	947	940	938	958	961	965	966	984	985	975	953	947	928	957	992	988	954	956	
	2号炉	953	1006	1024	1011	1003	991	989	1004	994	1011	990	1000	992	994	987	1005	999	988	966	969	1003	1001	993	978	
23	1号炉	923	947	983	984	977	988	956	982	963	930	951	983	950	1016	992	971	950	962	949	1010	1016	1031	1004	993	
	2号炉	989	1004	987	1002	1011	1007	967	1012	988	1000	995	1023	1000	1011	1011	987	1023	1026	988	1027	998	1022	1026	1035	
24	1号炉	981	971	924	930	951	954	931	946	959	1017	993	983	992	983	974	992	1008	989	999	1003	999	978	984	969	
	2号炉	1024	1024	1005	1018	1001	987	983	980	978	1008	1022	1022	1011	1019	1007	1027	1026	1009	1003	1005	1009	992	987	999	
25	1号炉	968	984	969	971	973	974	979	942	978	998	978	976	977	1002	989	1017	1009	1011	983	981	1019	961	912		22:35~24:00給じん停止
	2号炉	984	999	1005	1040	1033	1066	998	1010	1022	1028	1007	1015	1016	1010	967	981	982	1038	1017	1007	987	1000	1004	996	
26	1号炉		923	971	967	983	1003	980	1001	980	994	980	973	984	984	942	964	975	964	969	987	1025	1010	995	1019	0:00~1:10給じん停止
	2号炉	1011	968	1005	983	1013	1018	1036	1036	1033	1016	1006	988	994	958	967	965	973	984	989	1011	1011	992	999	954	
27	1号炉	977	964	986	1002	946	963	1016	992	917				1008	945	985	971	994	992	998	982	978	1015	990	986	8:31~12:54給じん停止
	2号炉	982	984	991	998	988	1007	1040	995	1007	1009	1002	992	995	849		993	984	997	992	984	994	982	981	963	13:29~15:20給じん停止
28	1号炉	1018	1018	1025	997	998	1039	1008	1003	979	967	1003	998	982	921	946	975	985	1011	966	958	924	951	981	888	
	2号炉	1002	992	964	981	985	1019	1006	1043	1007	1014	1000	990	1014	985	982	1002	969	1018	1019	997	1013	1027	979	990	
29	1号炉	938	994	1005	995	993	1004	1005	969	989	962	911	937	925	926	930	947	989	933	958	978	930	908	902	908	
	2号炉	1003	964	990	999	978	983	983	1021	1026	987	1024	1018	980	961	991	981	996	994	979	1008	950	968	976	980	
30	1号炉	907	939	942	946	956	970	981	981	959	967	971	947	967	932	952	939	952	913	926	931	918	926	927	962	
	2号炉	993	1003	1004	986	1012	1026	1019	987	970	1011	1019	1012	1009	980	984	1003	1008	958	983	992	968	965	1006	954	
31	1号炉	955	959	968	961	981	1006	970	944	961	944	965	942	951	960	1003	988	945	969	931	902	932	944	952	958	
	2号炉	951	982	975	964	987	984	985	959	966	964	951		964	983	1004	1027	972	961	975	958	1026	1039	1038	1034	10:33~12:02給じん停止

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

9月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	955	998	1016	1017	996	990	1008	1008	982	988	977	962	972	981	966	970	991	971	975	965	941	975	999	1009	
	2号炉	1040	1039	1041	989	1019	1018	1033	1000	1006	1015	1011	991	1010	997	980	989	997	996	1017	1043	1022	1034	1020	1025	
2	1号炉	997	1011	997	972	975	1010	1018	992	995	978	955	964	995	977	959	959	979	938	984	992	990	976	976	1006	
	2号炉	1010	1003	1011	975	999	1016	1034	1000	1042	985	1010	972	986	1045	1023	1021	1031	1036	1012	1031	1030	1028	1017	1023	
3	1号炉	988	976	1008	994	1001	988	1018	1009	916				978	930	924	929	915	921	918	934	938	938	930	951	8:31~12:48給じん停止
	2号炉	1034	980	1026	999	992	1002	1023	1013	1016	1020	1015	989	1017	992	1015	1025	1023	969	995	1023	1014	1004	1004	976	
4	1号炉	955	940	929	920	920	952	963	945	932	944	943	956	964	937	940	944	974	934	942	952	972	982	976	1001	
	2号炉	979	1023	1009	996	1060	991	999	960	861		1034	999	1001	1029	1023	986	1000	985	993	1028	1002	1000	1010	1009	8:32~10:58給じん停止
5	1号炉	1013	1016	1006	1023	1013	1007	1027	999	974	987	1020	1001	937	967	1004	989	999	1008	979	967	984	980	967	971	
	2号炉	1030	1024	980	992	1003	1047	1001	967	977	1027	1003	985	1001	1001	980	991	992	1005	1004	983	996	972	971	989	
6	1号炉	974	968	980	954	959	948	917	955	925	942	939	971	1018	1023	982	1036	966	963	966	983	963	987	1002	1002	
	2号炉	994	1009	1032	1040	1007	1039	977	1019	1013	1007	1043	1025	1008	991	994	1008	981	1027	1011	992	1008	962		980	21:23~23:02給じん停止
7	1号炉	971	953	954	955	977	935	907	940	940	972	971	930	940	950	953	960	966	957	969	935	936	949	971	973	
	2号炉	991	994	997	995	980	981	976	981	985	1011	1031	989	962	965	1027	956	991	968	975	961	967	997	1015	1006	
8	1号炉	957	939	940	962	973	960	957	941	946	972	979	996	967	949	933	931	931	920	967	992	983	976	976	1009	
	2号炉	983	968	967	956	978	959	1008	987	1009	1006	1008	994	999	996	1001	999	974	1028	1043	1031	1003	992	999	1044	
9	1号炉	1001	1002	986	966	926	943	946	946	938	987	966	927	920	929	923	936	916	966	935	925	937	904	906	914	
	2号炉	1036	996	992	990	1003	1006	987	977	1045	1005	1012	996	977	981	996	981	982	1006	995	995	998	1001	1019	1021	
10	1号炉	914	928	961	995	998	988	960	952	941	954	907	965	977	993	964	998	1002	1000	962	975	977	981	959	967	
	2号炉	993	1004	1055	1036	1028	986	965	960	857			996	971	990	977	999	985	985	1032	1031	1007	1001	1024	1016	8:30~11:15給じん停止
11	1号炉	942	994	976	942	977	986	1003	966	872																定常運転~立下げ(8:40)
	2号炉	1033	994	978	963	998	982	1027	1007	994	1003	1001	989	956	981	989	948	982	987	1004	989	1032	1039	1026	1039	
12	1号炉																									休炉
	2号炉	1041	997	1006	976	994	1002	1039	974	985	970	978	1001	954	953	967	988	1007	1009	1007	981	966	981	987	981	
13	1号炉																									休炉
	2号炉	961	978	9569	976	1006	953	1013	941	967	989	1001	976	966	989	988	1005	956	951	989	956	970	977	1014	1008	
14	1号炉																									休炉
	2号炉	1013	958	984	994	1001	970	989	964	981	1004	1054	1001	1016	1008	1015	1024	1023	1003	992	1011	1010	1004	980	977	
15	1号炉																									休炉
	2号炉	1002	1039	1055	1023	1039	998	965	1019	996	1009	1017	1000	1005	981	1014	1012	884	982	987	1006	975	1014	1020	992	8:50~10:22給じん停止

9月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉																									休炉
	2号炉	985	984	991	972	978	1012	994	959	994	995	926	981	1012	1008	967	971	990	982	979	928	988	975	984	992	
17	1号炉																									休炉
	2号炉	987	1042	1021	1004	970	966	980	1007	1015	985	1024	998	993	981	1004	1015	1009	762			1031	978	973	971	17:10~20:40給じん停止
18	1号炉																									休炉
	2号炉	1005	981	951	957	950	964	963	982	996	997	1014	1001	975	968	972	951	974	970	989	970	976	990	999	972	
19	1号炉																									休炉
	2号炉	976	978	989	996	969	984	1018	986	1024	966	1002	996	989	976	991	1009	977	1004	977	957	970	994	1001	1015	
20	1号炉																									休炉
	2号炉	1000	988	996	949	991	1004	996	995	1014	1005	994	963	968	974	976	995	984	1017	1032	1015	1018	998	989	963	
21	1号炉																									休炉
	2号炉	961	993	1022	970	964	996	963	1013	1003	1009	958	977	973	984	978	966	959	977	983	956	986	1005		940	21:53~23:02給じん停止
22	1号炉																									休炉
	2号炉	945	985	974	977	988	974	1002	976	951	938	937	955	954	977	965	996	1010	976	1013	1011	1010	1019	1041	1032	
23	1号炉																									休炉
	2号炉	1002	990	1012	984	1021	1019	985	969	995	1018	1015	1012	974	981	990	991	1048	987	1030	993	978	1019	1016	1029	
24	1号炉			952	960	952	941	962	954	970	955	934	922	917	951	1009	1016	1032	1017	973	972	954	928	970	934	立上げ～定常運転(1:20)
	2号炉	1020	968	966	980	988	976	995	1014	976	881		991	951	956	972	983	981	980	977	966	957	980	976	1004	9:34~11:45給じん停止
25	1号炉	952	952	954	942	961	943	997	1022	1021	1050	989	976	993	1020	957	967	969	966	993	987	1011	974	1023	975	
	2号炉	1003	986	1025	981	967	1013	1000	1030	1005	978	996	991	981	981	978	1003	998	1034	1017	998	958	985	1004	957	
26	1号炉	1010	977	985	981	1003	992	981	982	998	978	1007	1034	1022	1007	1056	1033	1039	1056	1014	1008	1042	1030	1029	1029	
	2号炉	942	1008	986	1012	983	998	998	1008	986	972	965	981	1016	1005	984	1001	1002	1025	998	990	967	972	959	975	
27	1号炉	976	1019	992	997	962	1008	1029	954	1001	1009	1031	1009	1041	971	1009	996	975	998	993	989	1012	1007	1010	1037	
	2号炉	981	994	959	982	961	946	917	947	967	986	987	947	954	940	941	971	945	870		980	967	986	944	929	17:21~19:52給じん停止
28	1号炉	1014	986	966	981	982	969	986	1007	1018	1008	979	959	957	959	984	956	961	968	971	972	972	992	965	993	
	2号炉	949	930	926	919	933	961	944	935	945	977	972	1005	958	965	954	955	961	981	945	939	952	971	967	965	
29	1号炉	989	1011	973	970	984	993	992	961	986	985	978	995	1024	945	964	996	984	963	991	997	1006	1031	1040	1024	
	2号炉	955	958	964	921	918	915	948	946	945	920	944	974	970		999	934	961	908	938	935	954	963	959	952	12:55~14:52給じん停止
30	1号炉	1015	1004	1025	1004	1004	995	1017	1011	996	987	1049	1035	990	962	1009	997	990	1008	938	1014	1006	986	947	986	
	2号炉	926	926	930	933	930	955	949	941	922	946	954	951	918	922	967	940	926	955	896	926	961	953	909	909	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	954	950	962	925	925	943	930	943																	定常運転～立下げ(8:41)
	2号炉																									休炉
2	1号炉																									休炉
	2号炉																									休炉
3	1号炉																									休炉
	2号炉																									休炉
4	1号炉																									休炉
	2号炉																									休炉
5	1号炉																									休炉
	2号炉																									休炉
6	1号炉																									休炉
	2号炉																									休炉
7	1号炉																									休炉
	2号炉																									休炉
8	1号炉																									休炉
	2号炉																									休炉
9	1号炉																									休炉
	2号炉																					832	820	857	992	立上げ～定常運転(20:47)
10	1号炉																									休炉
	2号炉	983	1000	994	997	1010	1048	1046	1042	1055	1016	1007	1003	1011	1024	1038	1047	1020	1025	1021	1010	1030	1014	1009	1016	
11	1号炉																									休炉
	2号炉	1025	1030	1071	1064	1061	1042	1068	1054	1023	1055	913	973	986	996	978	957	972	984	967	943	976	1025	1010	1019	
12	1号炉								858	939	946	949	932	920	937	920	939	929	933	939	928	927	965	951	937	立上げ～定常運転(7:42)
	2号炉	1037	1051	1039	1030	1042	1039	1039	1072	996	996	992	967	983	969	981	993	985	1000	1021	1011	978	993	1032	1031	
13	1号炉	933	950	961	942	932	918	928	923	937	946	951	942	941	944	980	1008	907	944	957	946	939	945	972	998	
	2号炉	1022	965	987	973	939	960	949	957	962	1002	997	967	979	995	997	1017	1026	982	968	976	994	1004	1024	990	
14	1号炉	970	977	955	944	952	946	958	966	976	988	974	957	969	972	952	982	978	945	886	880	932	950	957	930	
	2号炉	971	982	957	940	951	963	958	945	945	965	949	906	944	925	924	918	915	935	953	938	944	963	967	966	
15	1号炉	982	976	971	934	961	945	951	943	946	973	957	966	967	932	938	918	943	943	953	931	939	934	941	961	
	2号炉	945	905	948	984	960	964	958	967	979	975	986	1007	986	968	997	989	985	955	942	931	942	981	1012	1026	

11月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
16	1号炉	961	958	942	956	942	938	973	974	974	970	976	957	977	951	989	927	943	963	957	983	985	992	978	969	
	2号炉	987	993	1009	1026	985	963	979	992	994	984	979	977	960	983	977	984	1004	995	980	988	989	1010	985	981	
17	1号炉	947	1005	985	992	985	967	976	970	980	981	983	969	962	957	984	974	984	946	947	954	945	970	989	984	
	2号炉	1003	1027	1008	1009	1017	1008	986	992	994	997	1014	1024	1022	1010	1002	1005	1005	1005	1005	1002	1006	993	973	974	
18	1号炉	973	967	924	930	947	949	936	939	897			976	928	923	911	919	917	934	931	933	932	953	945	930	8:40～11:31給じん停止
	2号炉	946	950	950	944	983	1009	1012	983	1008	999	1008	976	978	949	971	950	971	984	979	991	909	1001	984	983	
19	1号炉	943	940	961	968	944	949	944	982	970	974	980	974	969	926	935	940	944	923	920	948	976	952	974	970	
	2号炉	1014	979	986	1012	995	999	992	1004	903			1022	978	959	966	974	957	958	938	976	988	975	974	972	8:30～11:42給じん停止
20	1号炉	978	949	956	976	960	963	988	977	980	938	979	976	944	938	922	955	983	972	978	988	958	923	937	932	
	2号炉	954	967	949	970	977	992	986	972	969	968	989	982	977	963	914	905	952	997	987	964	998	990	921	757	24:00～13:47給じん停止
21	1号炉	982	984	939	915	966	986	963	977	969	1015	986	985	985	929	938	940	947	941	921	943	921	957	968	966	
	2号炉														924	945	952	964	988	974	994	971	939	918	936	
22	1号炉	968	990	977	966	992	967	957	942	976	969	922	944	935	938	970	945	932	957	962	966	954	943	951	950	
	2号炉	965	986	973	960	992	980	967	959	979	963	937	972	986	983	996	982	1018	971	986	942	1003	1001	996	1008	
23	1号炉	970	948	954	932	953	948	954	945	965	947	965	967	844	914	930	929	937	922	924	920	935	946	942	950	
	2号炉	1029	974	977	972	947	986	986	991	972	974	1001	999	986	983	945	921	930	938	937	908	940	961	966	992	
24	1号炉	953	957	949	987	976	986	1005	971	971	989	993	983	972	993	974	977	979	1003	1025	1009	978	932	909	977	
	2号炉	995	984	958	962	985	977	977	971	971	992	991	983	981	989	982	993	995	1035	1003	993	990	981	1016	997	
25	1号炉	951	991	991	962	962	954	937	965	889				1001	939	919	931	928	918	947	938	964	966	930	936	8:35～12:25給じん停止
	2号炉	979	990	978	961	972	976	990	984	974	956	948	949	933	949	976	955	938	942	965	936	962	948	960	963	
26	1号炉	943	919	947	938	928	942	936	952	925	950	959	953	925	931	909	925	931	895	941	946	956	968	977	988	8:31～11:18給じん停止
	2号炉	961	946	932	952	941	948	942	966	867			975	933	933	928	939	933	943	939	949	965	981	985	999	
27	1号炉	978	934	929	933	932	930	932	934	944	995	979	979	956	931	943	977	944	931	936	942	929	937	987	946	
	2号炉	992	986	975	958	932	930	937	945	978	993	975	971	974	979	949	973	973	955	966	978	945	935	981	947	
28	1号炉	977	957	921	957	949	945	938	925	952	970	959	932	925	957	951	944	927	932	947	955	912	983	960	925	
	2号炉	962	979	968	957	956	968	971	974	997	1024	1004	941	958	967	932	924	927	938	981	957	954	931	934	950	
29	1号炉	925	918	923	924	937	942	970	934	935	956	966	996	918	931	964	952	947	974	911	917	925	943	937	921	
	2号炉	940	920	920	917	951	1006	993	1008	962	926	961	961	937	937	962	966	957	1001	954	948	947	937	974	981	
30	1号炉	944	954	983	944	957	938	940	923	950	945	965	953	958	978	976	976	1002	997	989	977	968	932	980	957	
	2号炉	965	988	989	965	956	950	946	948	954	963	971	988	954	972	983	987	971	948	918	950	943	968	966	942	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和6年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

12月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	953	964	947	922	938	952	934	934	973	959	972	963	955	926	941	941	932	950	972	966	965	972	973	989	
	2号炉	938	922	938	926	947	975	983	973	996	972	999	979	997	924	928	925	942	960	954	971	958	940		952	21:59~23:08給じん停止
2	1号炉	963	933	964	955	945	979	975	962	981	961	928	944	1016	935	932	951	933	927	933	950	974	954	1001	1010	
	2号炉	955	974	959	953	971	980	949	985	928			962	937	921	905	934	926	912	931	958	935	916	937	979	8:37~11:22給じん停止
3	1号炉	999	979	987	985	977	948	963	983	908				996	994	980	980	979	969	990	996	996	991	1003	996	8:31~12:29給じん停止
	2号炉	977	971	976	982	962	968	977	965	958	978	951	983	967	986	976	973	945	942	960	982	954	913	959	963	
4	1号炉	999	973	992	1001	994	990	962	954	966	1040	1045	1017	986	970	1008	970	985	966	989	1008	1009	1028	1009	1027	
	2号炉	948	968	935	918	946	955	905	943	948	962	976	974	982	955	937	937	965	967	990	923	953	976	963	994	
5	1号炉	1023	995	1006	968	990	1027	978	995	1012	966	989	897	1060	1054	1005	1001	1001	1005	989	1010	973	969	977	989	
	2号炉	959	951	962	934	946	951	952	930	924	926	969	972	1020	999	968	970	982	941	952	942	917	905	909	954	
6	1号炉	995	1005	983	957	884	954	994	968	987	997	990	997	986	960		889	971	943	959	954	888	980	963	978	13:50~15:30給じん停止
	2号炉	944	943	923	895	890	909	903	919	909	943	929	910	925	894		886	931	946	969	986	997	958	978	980	13:50~15:34給じん停止
7	1号炉	903	820																							定常運転~立下げ(1:30)
	2号炉	958	969	974	975	976	953	941	991	977	965	944	938	959	960	987	977	949	969	989	980	973	985	930	963	
8	1号炉																									休炉
	2号炉	963	951	944	953	955	952	919	939	951	944	955	974	965	975	968	976	950	968	957	958	957	964	969	958	
9	1号炉																									休炉
	2号炉	966	949	964	987	925	963	971	968	957	940	938	941	953	959	952	976	986	941	911	949	932	930	937	934	
10	1号炉																									
	2号炉	952	928	946	954	948	958	964	960	943	959	939	943	951	771		981	920	918	923	895	923	929	914	913	13:21~15:53給じん停止
11	1号炉										895	994	984	1009	908	951	976	984	972	987	979	977	977	1039		給じん開始~定常運転(10:50)
	2号炉	956	921	915	921	919	953	914	912	940	917	946	937	956	1020	980	958	975	947	945	947	947	989	964	929	
12	1号炉	1003	1050	1066	998	964	968	1013	1049	1040	1032	982	980	966	983	1005	1010	1010	998	1012	928	876	979	997	999	
	2号炉	949	955	1002	1017	993	999	1012	1001	1000	1032	1013	987	1010	999	1010	977	1001	991	1009	997	1016	991	1025	1035	
13	1号炉	994	1008	960	972	1031	1073	1018	966	1032	1007	1027	960	982	994	1000	979	974	1015	996	1016	968	965	983	963	
	2号炉	1019	993	1043	1006	981	1042	1004	1010	967	983	1016	1019	975	1007	1022	1017	1052	1023	1051	996	997	985	980	989	
14	1号炉	973	959	958	963	951	927	906	897	908	912	967	966	976	987	997	997	989	1001	984	981	951	972	958	938	
	2号炉	994	965		988	994	968	972	977	978	979	968	1005	996	1036	1040	1026	1019	1066	1013	1025	969	971	984	982	1:53~3:14給じん停止
15	1号炉	987	997	961	966	982	973	988	969	972	974	977	974	964	967	939	953	950	950	968	996	991	986	1011	1009	
	2号炉	978	940	974	1003	984	968	996	990	972	990	997	978	980	985	1025	1000	1032	991	991	992	1043	992	982	981	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考		
1	1号炉																									休炉	
	2号炉																										休炉
2	1号炉																										休炉
	2号炉																										休炉
3	1号炉																										休炉
	2号炉																										休炉
4	1号炉																										休炉
	2号炉																										休炉
5	1号炉																										休炉
	2号炉																										休炉
6	1号炉																										休炉
	2号炉																										休炉
7	1号炉							996	966	971	974	971	1005	996	1007	1011	1036	1011	988	975	1000	965	975	978		立上げ～定常運転(7:54)	
	2号炉																										休炉
8	1号炉	975	967	1025	984	1001	974	1002	1005	1013	1014	1017	1012	981	991	992	1019	1025	1005	1006	993	992	980	975	978		
	2号炉																										休炉
9	1号炉	977	997	1023	1021	1025	1039	1030	1000	1005	1033	1050	995	1017	1021	1017	994	981	963	984	996	985	1026	1055	1081		
	2号炉													899	1062	1040	1041	999	991	1033	963	969	982	1002	978	立上げ～定常運転(12:45)	
10	1号炉	1042	1022	1029	1054	1018	1004	1027	1024	1024	1034	1064	1071	1059	1010	1079	1070	1055	1088	1075	1036	1008	1030	1021	1037		
	2号炉	998	1015	1028	986	1033	1007	998	1004	1005	1023	994	1024	1011	991	1040	1019	1000	1018	1029	996	995	1058	1072	1064		
11	1号炉	1055	1037	1089	1061	1024	1073	1046	1045	1074	1044	1001	1089	1082	1053	1081	1052	1024	1021	1027	1028	1032	1035	1038	1051		
	2号炉	1016	1002	1064	1038	1024	1065	1089	1078	1071	1054	1048	1036	1039	1066	1070	1044	1037	1055	1009	1056	1120	1088	1044	1069		
12	1号炉	1055	1037	1089	1061	1024	1073	1046	1045	1074	1044	1001	14089	1082	1053	1081	1052	1024	1021	1027	1028	1032	1035	1038	1051		
	2号炉	1016	1002	1064	1038	1024	1065	1089	1078	1071	1054	1048	1036	1039	1066	1070	1044	1037	1055	1009	1056	1120	1088	1044	1069		
13	1号炉	1061	1032	1038	1035	1077	1080	999	1006	1026	1100	1036	1072	1063	1037	1048	1069	1041	1030	1048	1084	1015	1085	1042	1090		
	2号炉	1007	1024	1014	1011	1054	1054	975	966	986	1028	1043	1018	1026	1013	1001	1034	1024	1030	975	995	988	983	1068	1070		
14	1号炉	1080	1070	1090	1080	1051	1034	1083	1068	1076	1066	1077	951	1093	1088	1078	1099	1073	1070	1086	1116	1093	1031	955	1055		
	2号炉	1049	1067	1078	1075	1035	1021	1035	1048	1055	995	1012	1027	1110	1053	1048	1058	998	1025	989	996	978	976	959	969		
15	1号炉	1077	1059	1008	1009	1017	1030	1030	1037	886					1003	1045	1081	1026	1084	1032	1055	1034	1009	1026	1019	8:31～13:07給じん停止	
	2号炉	984	998	993	995	1000	991	1023	1042	1085	1043	1056	1048	1043	1005	1024	1033	1045	1042	1018	1053	1015	1029	1008	986		

	1月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
16	1号炉	1038	998	1020	1051	1051	1042	1059	1047	1030	1006	1032	1035	1026	993	1068	1069	1019	1056	1031	1030	1024	1029	1019	1039	
	2号炉	1016	994	998	1062	1084	1094	1081	1037	887				1048	1009	964	1014	1045	1014	995	1008	981	988	984	990	8:31~12:30給じん停止
17	1号炉	1042	1002	976	1006	1007	994	1008	996	1015	1034	1022	1042	1002	1030	1012	1045	1065	1014	1013	1038	1011	995	1034	1028	
	2号炉	993	986	984	987	998	991	996	955	1034	989	1019	995	1003	1001	971	1029	1076	1039	1002	1029	1038	1052	1065	1063	
18	1号炉	1043	1013	1041	1007	993	1021	1045	1019	1024	1054	1044	1071	1077	1048	1068	1039	1001	1053	1058	1029	1065	1029	1022	1000	
	2号炉	1073	1062	1067	1049	1038	1014	1033	992	992	996	1024	1051	1024	1043	1085	1095	1065	1028	1035	1055	1065	1064	1040	994	
19	1号炉	1007	1089	1027	1056	1027	1055	1081	1071	1094	1022	1031	1023	996	1020	1031	1027	1026	1064	1028	1047	1037	1078	1071	1110	
	2号炉	988	1035	1016	1026	983	1003	1028	1056	1040	1035	1063	1076	1018	1033	1027	1042	1021	1077	1074	1057	1029	1036	1088	1068	
20	1号炉	1074	1059	1060	1066	1092	1072	1049	1075	1097	1083	1088	1093	1070	1098	1096	1098	1118	1132	1156	1159	1102	1028			21:34~24:05給じん停止
	2号炉	1033	1042	1022	1020	1043	1012	1022	1060	1072	1045	1075	1090	1073	1048	1095	1054	1006	1041	1058	1102	1096	1077	1052	1028	
21	1号炉	992	1058	1056	1060	985	1015	1010	1019	1022	1012	1015	1016	1022	1003	1008	1047	1034	1006	1026	1033	1079	1038	1037	1016	
	2号炉	1061	1101	1007	1042	1017	1039	983	1004	999	1000	1026	1031	1035	1018	1020	1052	1046	1069	1041	987	1029	1067	1072	1046	
22	1号炉	1034	1010	998	1012	1008	1028	1045	1041	909				957	1023	1078	1110	1055	1058	1076	1055	1092	1068	1058	978	8:31~12:48給じん停止
	2号炉	1039	1021	1004	1028	1064	1066	1052	1043	1082	1042	1055	1052	1017	1053	1035	1038	1001	1071	1080	1059	1087	1057	1040	1006	
23	1号炉	1003	994	994	1001	998	996	995	1009	1012	1053	1027	991	1003	1010	1026	1017	1034	1018	1002	1010	1020	1034	1011	1005	
	2号炉	1048	1066	1093	1095	1025	1035	1010	1078	1015	954	1016	1026	1026	1025	992	1002	990	1048	992	1002	1026	1043	1040	1011	
24	1号炉	1010	1028	1070	1046	1001	1010	1022	1015	1007	1011	1018	1062	1031	1024	1059	1014	1034	1038	1013	1012	992	1026	1016	1047	
	2号炉	1048	999	1035	1024	1026	1014	973	1005	871				1049	972	1010	987	989	1001	1024	1006	960	972	1047	1036	8:31~12:48給じん停止
25	1号炉	1065	1014	1000	1011	991	1018	1024	1016	1042	1020	1031	1001	1014	1001	1010	1001			996	1006	1028	1031	1044	1053	15:04~18:30給じん停止
	2号炉	1027	1014	982	1039	1031	1017	1031	1044	1033	1053	1067	1037	1054	1026	1030	1033	1044	1023	985	1015	1026	1047	1034	1037	
26	1号炉	1045	1032	1028	1029	1003	991	1011	1026	1011	1030	1018	1000	1011	1035	1032	1041	1020	1034	1091	1076	1066	1036	1026	1046	
	2号炉	1030	1042	1078	1043	1008	1042	1039	1046	971	996	1038	1017	989	1015	1042	1033	1033	1009	983	995	1063	1043	1012	1002	
27	1号炉	918	966						1008	1071	1030	1047	1041	1014	1007	1001	999	1018	1036	1017	994	1042	1023	1062	1044	1:53~7:28給じん停止
	2号炉	980	984	1066	1064	1012	1025	1009	1036	1059	1084	1059	1058	980	1016	1022	1022	1044	1009	997	1006	1030	1061	1051	1023	
28	1号炉	1018	1005	1022	1002	1022	1032	1047	1068	918				1039	1002	1002	998	995	994	997	991	1013	1022	997	998	8:32~12:58給じん停止
	2号炉	1020	1042	1016	1020	1055	1055	1060	1076	1006	1031	1036	1037	1036	1048	1024	1054	1066	1033	1007	1039	1020	1031	1038	1065	
29	1号炉	1007	990	1004	990	1019	993	1009	988	994	1013	1024	994	1011	1030	1020	1028	1046	1047	1044	1044	1064	1054	1029	1003	
	2号炉	1053	998	982	980	1018	1036	1013	1019	909			1039	1007	1049	990	1005	924	1019	1015	1015	1020	984	969	964	8:31~11:41給じん停止
30	1号炉	1087	1028	1024	1024	1068	1063	1062	1054	1051	1034	1024	1055	1024	1012	1021	1024	1030	997	1010	1050	1044	1048	1048	1004	
	2号炉	995	979	987	1019	977	995	1062	1066	1001	991	1015	1004	976	998	1058	1008	999	1037	1022	1048	1028	1013	1010	1046	
31	1号炉	1002	979	1002	1016	1016	1072	1030	1029	1053	1058	1030	1038	985	982	1038	1016	1089	1096	1112	981		935	1008	1003	19:35~21:17給じん停止
	2号炉	1084	1029	988	982	992	1011	1001	1020	994	1010	992	1027	1027	1028	1016	1064	1051	1044	1041	1028	1069	1037	1046	1025	

燃烧室中の燃烧ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃烧室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1027	1030	1012	1002	1010	1020	1037	1023	1011	1020	1018	987	1034	1032	1055	1036	1026	987	1017	987	1031	1012	1022	1026	
	2号炉	1032	1053	1059	1087	1032	1064	1070	1043	1018	1016	1039	1060	1081	1101	1055	1044	1090	1018	1067	1073	1074	1028	1035	1061	
2	1号炉	1046	1060	1073	1039	1012	1009	1027	1027	1030	1046	998	1022	1018	1018	1079	1019	1031	1019	1043	1025	1004	1012	1031	1046	
	2号炉	1051	1060	1039	1030	1012	1021	1002	1054	1019	1039	1056	1042	1087	1088	1116	1061	1091	1050	1054	1083	1086	1039	1100	1032	
3	1号炉	1021	1025	1012	1034	1037	1030	1011	1040	1045	1088	962			989	1020	1052	999	1023	1018	1013	996	1022	1016	994	10:15~13:35給じん停止
	2号炉	1065	1116	1090	1093	1061	1061	1005	998	1045	1005	1004	1013	1015	1051	1044	1059	1065	1080	1015	1015	1071	1028	991	1063	
4	1号炉	1013	1012	1011	1042	1028	1023	1082	1046	1022	1036	1023	997	1032	1032	978	1021	1057	1061	1016	1045	1031	1055	1014	1098	
	2号炉	1051	1028	1043	1049	1089	1044	1039	984	1032	1109	1072	1054	1052	1057	984	1002	1042	1052	1021	1029	1088	1075	1056	1079	
5	1号炉	990	1019	1009	1069	1007	998	1022	987	1034	1060	1068	1019	1021	1014	1025	1041	1029	1055	1056	986	1051	1013	1081	994	
	2号炉	1071	968	1029	1073	1058	1082	998	1041	1104	1075	1043	1024	1040	1037	1123	1098	1124	1072	1057	1035	1033	1038	1047	1122	
6	1号炉	996	1059	1065	1029	950	1003	1017	1008	900													977	1001	991	8:31~21:00給じん停止
	2号炉	1025	1095	1015	1017	990	1054	1076	1117	1086	1100	1064	1026	1017	1042	1034	1039	1037	1034	1040	1013	1002	1029	1031	1057	
7	1号炉	1010	988	942	994	983	1007	1005	1016	1026	989	902			873	974	974	974	981	999	1011	974	984	1015	997	10:38~13:50給じん停止
	2号炉	1052	1028	1009	1036	1028	1022	1057	1077	990					1035	1035	1024	1033	1021	1004	1047	1018	1003	981	1010	8:34~13:30給じん停止
8	1号炉	907		930	968	971	931	915	926	903	970	991	945	962	967	979	1012	1000	946	972	935	935	938	939	949	24:08~2:33給じん停止
	2号炉	1032	1015	1040	1011	978	965	971	941	932	970	987	1005	960	991	988	1019	1006	1017	1083	1029	944	1008	1022	1020	
9	1号炉	962	954	950	943	938	888	903	925	923	785						951	1026	991	992	1000	984	994	957	993	9:03~15:00給じん停止
	2号炉	1069	992	1036	964	968	1008	981	994	976	1052	1071	1074	1082	1075	1019	1022	1026	1034	1069	1097	1059	1062	1035	974	
10	1号炉	875				953	985	977	989	972	1037	1013	1047	986	989	953	783									24:10~4:12給じん停止 定常運転~立下げ(15:19)
	2号炉	1011	1024	1008	1009	1017	1036	1021	1044	1017	1026	1026	1009	1038	1011	994	984	1036	1026	1051	1054	1024	1022	1007	1030	
11	1号炉																									休炉
	2号炉	1003	1031	1018	1036	1022	1034	1010	1031	997	1026	1051	1042	1079	1024	1030	1059	1055	1075	1037	1056	1065	1047	1036	1030	
12	1号炉																									休炉
	2号炉	1041	1078	1023	1041	1045	1062	1062	1059	1058	1023	1078	1076	1035	1041	1059	1060	1068	988	1046	952	1082	1065	1096	1072	
13	1号炉																									休炉
	2号炉	1052	1052	1003	996	1060	1053	1056	1025	1059	1065	1060	1071	1005	999	1008	1083	1038	1012	1056	1029	1072	1045	1030	1006	
14	1号炉																									休炉
	2号炉	1013	1046	1028	1070	1002	1034	1028	1042	952				999	1038	1030	1045	1034	998	1018	1022	1047	1017	1000	1039	8:31~12:20給じん停止
15	1号炉																									休炉
	2号炉	1003	1004	1018	1005	985	1008	1007	1039	1032	1047	1020	998	990	977	983	982	979	992	922	1018	1026	1044	1069	1027	

2月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考	
16	1号炉																									休炉
	2号炉	1034	1031	1019	1004	1026	1086	1033	1014	1039	1024	1031	1028	1038	1029	1045	1048	1047	1019	998	1026	1043	1009	988		
17	1号炉																									休炉
	2号炉	1030	1005	1020	1015	939	997	998	1054	981	1001	1007	1012	1001	980	995	1028	1006	975	1034	1030	1034	1002	965	1002	
18	1号炉																									休炉
	2号炉	976	1008	947	974	1040	1044	1031	990	1036	1016	1016	990	1014	1019	1023	1010	964	966	986	1016	986	982	939	1032	
19	1号炉																									休炉
	2号炉	1016	1014	990	992	991	991	995	1015	972	996	1041	1007	1030	1044	999	1013	1008	982	957	981	991	985	986	1007	
20	1号炉																									休炉
	2号炉	1019	1014	982	1018	988	987	9596	945	914							976	1024	994	982	1004	1004	1021	1001	1020	8:45~15:34給じん停止
21	1号炉																									休炉
	2号炉	1027	1016	988	927	963	1003	989	989	999	1002	988	957	984	1000	1014	1012	972	982	994	1000	1021	1010	1002	1001	
22	1号炉																									休炉
	2号炉	954	1019	1005	1013	996	1006	1003	982	973	964	967	937	971	994	946	961	980	987	995	959	990	968	945	998	
23	1号炉																									休炉
	2号炉	980	980	946	1002	958	994	965	972	957	975	985	956	966	959	962	941	956	956	993	970	950	963	991	976	
24	1号炉																									休炉
	2号炉	939	975	961	957	961	939	950	963	954	967	973	941	969	966	978	948	976	934	945	926	963	944	947	957	
25	1号炉																									休炉
	2号炉	936	932	943	939	951	958	969	961	942	938	953	971	960	933	977	962	971	943	969	936	938	930	923	935	
26	1号炉																									休炉
	2号炉	972	988	998	994	1003	1009	986	859								998	993	1030	1002	991	1015	988	1013	987	7:06~15:16給じん停止
27	1号炉																									休炉
	2号炉	948	995	998	997	1024	1018	990	998	999	983	1008	1033	1031	1030	1028	997	1018	980	1013	952	955	982	971	969	
28	1号炉																									休炉
	2号炉	972	990	1004	984	1008	1013	1005	1031	1010	984	1005	968	965	945	974	961	987	995	978	1005	988	1002	982	986	