

令和6年度 排ガス中のばい煙濃度等

4月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			維持管理基準: 100ppm以下			管理値: 70ppm以下 排出基準: 250ppm以下			管理値: 20ppm以下			管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.57	0.11	0.29	16	0	0.5	53	18	40.0	0	0	0.0	5	1	2.5
2	0.41	0.00	0.24	9	0	0.5	60	1	34.5	0	0	0.0	5	0	2.5
3	0.49	0.07	0.26	16	0	1.0	40	7	29.5	0	0	0.0	4	1	2.5
4	0.45	0.04	0.26	27	0	2.0	54	3	29.5	0	0	0.0	7	1	3.5
5	0.40	0.11	0.24	14	0	0.5	48	17	32.5	0	0	0.0	6	2	3.5
6	0.50	0.11	0.25	7	0	0.5	53	18	33.5	0	0	0.0	9	2	4.0
7	0.41	0.06	0.24	10	0	0.0	56	9	36.0	0	0	0.0	6	1	3.5
8	0.57	0.11	0.30	10	0	0.5	49	11	33.0	0	0	0.0	9	2	3.5
9	0.44	0.08	0.25	10	0	0.5	57	12	37.5	0	0	0.0	7	2	3.5
10	0.49	0.04	0.24	2	0	0.0	61	5	40.0	0	0	0.0	6	1	3.5
11	0.62	0.08	0.24	1	0	0.0	57	18	39.0	0	0	0.0	6	2	3.5
12	0.48	0.05	0.25	1	0	0.0	58	1	32.0	0	0	0.0	6	0	3.0
13	0.47	0.19	0.30	5	0	0.0	44	27	34.0	0	0	0.0	4	1	3.0
14	0.42	0.18	0.31	12	0	1.0	47	33	38.0	0	0	0.0	5	2	3.0
15	0.46	0.02	0.34	0	0	0.0	53	2	36.0	0	0	0.0	5	0	2.0
16	0.40	0.06	0.31	7	0	1.0	47	2	36.0	0	0	0.0	5	1	2.0
17	0.40	0.22	0.34	0	0	0.0	51	33	39.0	0	0	0.0	7	2	3.0
18	0.35	0.16	0.29	0	0	0.0	45	28	34.0	0	0	0.0	12	2	5.0
19	0.84	0.15	0.38	0	0	0.0	50	14	38.0	0	0	0.0	5	1	2.0
20	0.40	0.13	0.29	0	0	0.0	46	32	37.0	0	0	0.0	5	1	2.0
21	0.37	0.17	0.31	0	0	0.0	44	26	35.0	0	0	0.0	7	2	3.0
22	0.50	0.00	0.33	0	0	0.0	42	0	32.0	0	0	0.0	7	0	3.0
23	0.40	0.02	0.32	0	0	0.0	46	1	33.0	0	0	0.0	3	0	2.0
24	1.63	0.24	0.62	21	0	1.0	39	16	30.0	0	0	0.0	4	2	3.0
25	0.54	0.00	0.30	23	0	2.0	41	0	23.0	0	0	0.0	13	0	3.5
26	1.23	0.00	0.37	31	0	1.5	48	0	33.5	0	0	0.0	5	0	3.5
27	0.69	0.00	0.32	21	0	1.0	278	0	43.0	0	0	0.0	5	0	3.0
28	0.70	0.00	0.47	0	0	0.0	52	0	39.0	0	0	0.0	4	0	2.0
29	0.82	0.34	0.47	8	0	0.0	48	26	33.0	0	0	0.0	5	1	3.0
30	0.57	0.06	0.40	0	0	0.0	47	2	34.0	0	0	0.0	4	0	2.0

令和6年度 排ガス中のばい煙濃度等

5月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.40	0.00	0.43	0	0	0.0	46	0	37.0	0	0	0.0	3	0	2.0
2	0.40	0.00	0.27	0	0	0.0	46	0	35.0	0	0	0.0	3	1	3.0
3	0.44	0.19	0.33	0	0	0.0	47	11	36.0	0	0	0.0	4	1	2.0
4	0.45	0.20	0.38	0	0	0.0	46	20	35.0	0	0	0.0	5	2	3.0
5	0.60	0.00	0.39	0	0	0.0	37	0	29.0	0	0	0.0	6	0	3.0
6	0.64	0.00	0.41	7	0	0.0	41	0	24.0	0	0	0.0	6	0	2.0
7	0.64	0.00	0.38	0	0	0.0	41	0	24.0	0	0	0.0	5	0	2.0
8	0.46	0.00	0.34	0	0	0.0	38	0	29.0	0	0	0.0	3	0	2.0
9	0.42	0.00	0.28	3	0	0.0	40	28	29.0	0	0	0.0	5	0	3.0
10	0.53	0.00	0.28	11	0	1.0	42	0	17.0	0	0	0.0	7	0	3.0
11	0.59	0.00	0.32	17	0	1.0	41	0	15.0	1	0	0.0	13	0	4.5
12	0.71	0.12	0.37	2	0	0.0	44	0	16.0	0	0	0.0	8	2	4.5
13	0.73	0.01	0.35	6	0	0.5	44	0	17.0	0	0	0.0	6	0	3.5
14	0.63	0.01	0.32	1	0	0.0	41	0	16.5	0	0	0.0	5	0	3.5
15	0.66	0.00	0.19	7	0	0.0	40	0	6.5	0	0	0.0	5	0	2.5
16	0.22	0.12	0.17	5	0	1.0	0	0	0.0	0	0	0.0	6	3	5.0
17	0.24	0.00	0.14	9	0	1.0	0	0	0.0	0	0	0.0	5	0	4.0
18	0.20	0.11	0.17	0	0	0.0	0	0	0.0	0	0	0.0	5	3	4.0
19	0.15	0.11	0.15	0	0	0.0	0	0	0.0	0	0	0.0	5	2	4.0
20	0.20	0.11	0.16	1	0	0	0	0	0.0	0	0	0.0	5	3	5.0
21	0.25	0.11	0.18	0	0	0.0	0	0	0.0	0	0	0.0	5	3	4.0
22	0.23	0.00	0.16	17	0	2.0	0	0	0.0	0	0	0.0	4	0	4.0
23	0.25	0.16	0.23	17	0	2.0	0	0	0.0	0	0	0.0	4	2	4.0
24	0.25	0.00	0.18	21	0	1.0	0	0	0.0	0	0	0.0	4	0	4.0
25	0.25	0.13	0.20	5	0	0.0	0	0	0.0	0	0	0.0	4	3	3.0
26	0.25	0.11	0.20	0	0	0.0	0	0	0.0	0	0	0.0	4	2	4.0
27	0.25	0.15	0.23	2	0	0.0	0	0	0.0	0	0	0.0	4	2	4.0
28	0.25	0.13	0.20	0	0	0.0	0	0	0.0	0	0	0.0	4	3	4.0
29	0.25	0.11	0.17	0	0	0.0	0	0	0.0	0	0	0.0	4	3	4.0
30	0.25	0.00	0.14	2	0	0.0	0	0	0.0	0	0	0.0	4	0	3.0
31	0.20	0.11	0.15	2	0	0.0	0	0	0.0	0	0	0.0	4	2	4.0

令和6年度 排ガス中のばい煙濃度等

6月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.24	0.11	0.17	0	0	0.0	0	0	0.0	0	0	0.0	4	3	4.0
2	0.25	0.15	0.20	2	0	0.0	0	0	0.0	0	0	0.0	4	3	4.0
3	0.24	0.11	0.18	11	0	1.0	0	0	0.0	0	0	0.0	4	2	4.0
4	0.25	0.14	0.19	7	0	1.0	0	0	0.0	0	0	0.0	4	3	4.0
5	0.24	0.11	0.19	0	0	0.0	0	0	0.0	0	0	0.0	4	2	4.0
6	0.25	0.00	0.16	0	0	0.0	0	0	0.0	0	0	0.0	4	2	4.0
7	0.64	0.00	0.20	4	0	0.0	40	0	4.0	0	0	0.0	9	0	3.0
8	1.64	0.18	0.57	13	0	0.5	45	0	17.5	0	0	0.0	7	2	4.0
9	1.06	0.00	0.42	7	0	0.5	41	0	16.5	0	0	0.0	8	0	4.5
10	1.06	0.00	0.42	7	0	0.5	41	0	16.5	0	0	0.0	8	0	4.5
11	0.67	0.00	0.36	1	0	0.0	43	0	18.0	12	0	0.5	5	0	3.5
12	0.70	0.00	0.39	2	0	0.0	44	0	18.0	0	0	0.0	6	0	3.5
13	0.77	0.00	0.38	10	0	0.5	44	0	17.0	0	0	0.0	7	0	3.5
14	0.86	0.02	0.44	7	0	0.0	51	0	18.0	0	0	0.0	5	0	3.0
15	0.70	0.00	0.41	2	0	0.0	43	0	16.0	0	0	0.0	5	0	3.0
16	1.11	0.02	0.47	0	0	0.0	42	0	16.5	0	0	0.0	5	0	3.0
17	0.93	0.18	0.47	5	0	0.0	43	0	18.0	0	0	0.0	4	1	3.0
18	0.75	0.00	0.40	5	0	0.0	45	0	15.0	0	0	0.0	5	0	2.5
19	0.25	0.00	0.11	3	0	0.0	0	0	0.0	0	0	0.0	4	0	1.5
20	0.79	0.00	0.35	0	0	0.0	43	0	12.5	0	0	0.0	4	0	2.5
21	0.67	0.16	0.40	1	0	0.0	41	0	17.0	0	0	0.0	5	2	3.0
22	0.70	0.01	0.42	3	0	0.0	42	0	15.5	0	0	0.0	5	0	3.0
23	1.34	0.18	0.53	10	0	0.5	38	0	17.0	0	0	0.0	4	2	3.0
24	0.92	0.18	0.46	0	0	0.0	49	0	17.5	0	0	0.0	6	1	3.0
25	0.79	0.00	0.35	0	0	0.0	43	0	16.5	0	0	0.0	4	0	1.5
26	0.70	0.38	0.58	16	0	1.0	38	26	32.0	0	0	0.0	5	1	2.0
27	0.71	0.00	0.51	7	0	1.0	48	0	27.0	0	0	0.0	4	0	2.0
28	0.83	0.46	0.65	0	0	0.0	48	20	36.0	0	0	0.0	3	1	2.0
29	0.69	0.04	0.58	0	0	0.0	40	2	31.0	0	0	0.0	3	0	1.0
30	0.75	0.40	0.65	0	0	0.0	43	28	34.0	0	0	0.0	4	1	2.0

令和6年度 排ガス中のばい煙濃度等

7月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			維持管理基準: 100ppm以下			管理値: 70ppm以下 排出基準: 250ppm以下			管理値: 20ppm以下			管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.88	0.00	0.67	0	0	0.0	39	0	31.0	0	0	0.0	3	0	1.0
2	0.88	0.39	0.73	0	0	0.0	52	27	38.0	0	0	0.0	3	1	1.0
3	0.89	0.00	0.65	12	0	1.0	39	18	34.0	0	0	0.0	3	1	1.0
4	0.89	0.00	0.65	0	0	0.0	49	0	31.0	0	0	0.0	3	0	1.0
5	0.95	0.43	0.81	1	0	0.0	52	30	40.0	0	0	0.0	3	1	2.0
6	0.91	0.49	0.79	0	0	0.0	47	28	39.0	0	0	0.0	3	1	2.0
7	0.90	0.04	0.72	0	0	0.0	44	0	33.0	0	0	0.0	3	0	2.0
8	0.93	0.09	0.74	0	0	0.0	43	2	35.0	0	0	0.0	3	0	2.0
9	0.96	0.44	0.80	0	0	0.0	54	32	43.0	0	0	0.0	4	1	2.0
10	1.04	0.10	0.75	0	0	0.0	50	3	35.0	0	0	0.0	4	0	3.0
11	0.87	0.00	0.59	2	0	0.0	49	0	32.0	0	0	0.0	4	0	2.0
12	0.94	0.49	0.78	0	0	0.0	45	28	38.0	0	0	0.0	3	1	2.0
13	0.89	0.44	0.77	3	0	0.0	45	28	37.0	0	0	0.0	3	2	2.0
14	0.76	0.04	0.64	0	0	0.0	49	2	35.0	0	0	0.0	4	0	2.0
15	1.59	0.04	0.84	1	0	0.0	52	29	40.0	0	0	0.0	3	2	2.0
16	0.91	0.01	0.65	0	0	0.0	50	0	34.0	0	0	0.0	3	0	2.0
17	1.09	0.43	0.79	4	0	0.0	53	32	41.0	0	0	0.0	4	1	2.0
18	0.99	0.00	0.68	0	0	0.0	44	0	31.0	0	0	0.0	3	0	2.0
19	1.84	0.00	0.53	28	0	1.0	46	33	19.5	0	0	0.0	8	0	2.0
20	0.98	0.08	0.68	0	0	0.0	55	1	21.0	0	0	0.0	9	0	3.5
21	1.09	0.32	0.65	0	0	0.0	53	37	22.0	0	0	0.0	4	2	2.5
22	3.61	0.03	0.78	7	0	0.5	49	1	18.0	0	0	0.0	4	0	2.5
23	2.70	0.00	0.84	6	0	0.0	46	0	36.0	0	0	0.0	4	0	2.5
24	1.38	0.19	0.71	8	0	0.5	42	33	38.0	0	0	0.0	4	1	2.5
25	1.46	0.00	0.66	5	0	0.0	46	0	35.0	0	0	0.0	5	0	2.5
26	1.42	0.00	0.73	3	0	0.0	49	31	38.0	0	0	0.0	4	0	2.0
27	1.11	0.21	0.63	9	0	0.5	52	11	39.0	0	0	0.0	4	1	2.5
28	1.14	0.00	0.62	2	0	0.0	45	0	37.0	0	0	0.0	4	0	2.5
29	1.18	0.23	0.68	1	0	0.0	45	30	39.0	0	0	0.0	6	2	3.5
30	1.34	0.00	0.69	5	0	0.5	41	0	33.0	0	0	0.0	7	0	4.5
31	1.05	0.00	0.33	1	0	0.0	43	0	14.0	0	0	0.0	8	0	3.5

令和6年度 排ガス中のばい煙濃度等

8月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.39	0.00	0.28	0	0	0.0	-	-	-	0	0	0.0	7	0	4.0
2	0.35	0.00	0.25	14	0	1.0	-	-	-	0	0	0.0	7	0	5.0
3	0.35	0.20	0.27	2	0	0.0	-	-	-	0	0	0.0	12	3	5.0
4	0.37	0.23	0.30	5	0	1.0	-	-	-	0	0	0.0	6	3	5.0
5	0.34	0.19	0.28	8	0	1	-	-	-	0	0	0.0	5	3	3.0
6	0.34	0.22	0.28	2	0	0.0	-	-	-	0	0	0.0	3	1	2.0
7	0.35	0.18	0.27	0	0	0.0	-	-	-	0	0	0.0	3	1	2.0
8	0.33	0.00	0.24	1	0	0.0	-	-	-	0	0	0.0	2	0	1.0
9	2.05	0.00	0.42	3	0	0.0	41	0	15.0	0	0	0.0	7	0	2.5
10	0.35	0.18	0.30	3	0	0.0	-	-	-	0	0	0.0	6	2	3.0
11	2.70	0.00	1.19	13	0	0.5	39	0	30.0	0	0	0.0	5	0	4.0
12	1.78	0.21	0.84	19	0	1.0	49	36	43.0	0	0	0.0	5	2	3.0
13	1.71	0.24	0.89	1	0	0.0	59	33	47.0	0	0	0.0	4	1	2.5
14	2.03	0.22	1.03	12	0	0.5	51	30	40.0	0	0	0.0	3	1	2.0
15	3.13	0.00	1.19	0	0	0.0	56	31	42.0	0	0	0.0	3	0	1.5
16	5.14	0.00	1.72	1	0	0.0	58	0	37.0	0	0	0.0	3	0	1.5
17	3.67	0.22	1.67	0	0	0.0	57	34	43.0	0	0	0.0	4	1	2.0
18	2.90	0.15	1.30	4	0	0.0	55	2	36.0	0	0	0.0	5	0	2.5
19	2.61	0.21	1.28	0	0	0.0	56	32	42.0	0	0	0.0	6	1	2.0
20	3.26	0.00	1.28	0	0	0.0	61	33	45.0	0	0	0.0	3	0	1.5
21	4.68	0.00	1.32	17	0	1.0	56	0	35.0	0	0	0.0	5	0	3.0
22	1.93	0.24	0.95	2	0	0.0	48	36	39.0	0	0	0.0	4	2	3.0
23	2.51	0.25	1.17	0	0	0.0	54	33	41.0	0	0	0.0	3	2	2.5
24	2.64	0.25	1.20	0	0	0.0	41	3	32.0	0	0	0.0	3	0	2.0
25	2.98	0.00	1.25	3	0	0.0	52	1	37.0	0	0	0.0	4	0	2.5
26	2.87	0.00	1.34	1	0	0.0	42	31	38.0	0	0	0.0	4	0	2.5
27	2.90	0.00	1.27	0	0	0.0	43	0	34.0	0	0	0.0	3	0	2.0
28	2.84	0.09	1.31	10	0	1.0	38	27	32.0	13	0	0.5	5	1	3.0
29	3.51	0.19	1.61	19	0	1.0	43	26	37.0	0	0	0.0	8	2	3.5
30	2.85	0.18	1.34	14	0	1.0	42	30	36.0	0	0	0.0	5	2	3.0
31	2.96	0.00	1.31	9	0	0.0	48	0	35.0	0	0	0.0	3	0	2.0

令和6年度 排ガス中のばい煙濃度等

9月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	2.71	0.23	1.28	3	0	0.0	48	26	39.0	0	0	0.0	5	2	3.0
2	2.77	0.18	1.31	1	0	0.0	49	34	41.0	0	0	0.0	6	2	3.0
3	3.30	0.00	1.21	25	0	1.0	53	0	18.5	0	0	0.0	6	0	2.5
4	4.12	0.00	1.50	23	0	0.5	49	0	35.0	0	0	0.0	4	0	2.5
5	3.00	0.18	1.42	1	0	0.0	41	29	34.0	0	0	0.0	5	1	3.0
6	4.15	0.00	1.66	0	0	0.0	41	0	32.0	0	0	0.0	3	0	2.0
7	3.87	0.18	1.62	2	0	0.0	51	29	39.0	0	0	0.0	3	1	2.0
8	3.41	0.19	1.67	2	0	0.0	47	29	39.0	0	0	0.0	4	1	2.0
9	3.76	0.18	1.65	0	0	0.0	45	30	40.0	0	0	0.0	4	1	2.5
10	3.25	0.00	1.22	1	0	0.0	46	0	33.0	0	0	0.0	5	0	2.5
11	3.10	0.00	1.26	10	0	0.5	46	26	36.0	0	0	0.0	3	0	3.0
12	3.41	0.89	2.22	15.00	0	1	49	32	42	0	0	0.0	3	2	3.0
13	3.34	0.04	2.54	13	0	1.0	44	1	34.0	0	0	0.0	3	0	3.0
14	3.28	1.83	2.85	3	0	0.0	47	27	38.0	0	0	0.0	3	2	3.0
15	3.04	0.00	2.41	4	0	0.0	47	0	32.0	0	0	0.0	4	0	3.0
16	2.85	1.23	2.25	0	0	0.0	46	12	37.0	0	0	0.0	3	1	3.0
17	2.79	0.00	1.75	0	0	0.0	45	0	31.0	0	0	0.0	3	0	2.0
18	3.79	1.72	2.86	0	0	0.0	50	41	0.0	0	0	0.0	3	2	2.0
19	2.61	1.18	2.13	0	0	0.0	43	29	37.0	0	0	0.0	3	2	2.0
20	3.76	0.27	2.52	0	0	0.0	44	5	36.0	0	0	0.0	3	0	2.0
21	2.56	0.00	1.97	0	0	0.0	47	0	36.0	0	0	0.0	3	0	2.0
22	2.83	1.04	2.42	2	0	0.0	48	30	40.0	0	0	0.0	3	1	2.0
23	2.23	1.50	2.00	0	0	0.0	56	32	45.0	0	0	0.0	4	1	2.0
24	3.17	0.00	1.22	13	0	1.0	54	0	41.0	0	0	0.0	8	0	3.0
25	3.43	0.18	1.47	2	0	0.0	47	3	37.0	0	0	0.0	4	0	3.0
26	3.34	0.18	1.33	8	0	0.5	48	5	35.0	0	0	0.0	4	1	3.0
27	3.50	0.00	1.38	14	0	0.5	51	0	34.0	0	0	0.0	3	0	1.5
28	3.55	0.20	1.33	6	0	0.5	46	32	39.0	0	0	0.0	5	2	3.0
29	3.90	0.00	1.64	0	0	0.0	50	0	37.0	0	0	0.0	4	0	2.5
30	4.12	0.18	1.86	7	0	0.5	56	35	44.0	0	0	0.0	4	1	2.5

令和6年度 排ガス中のばい煙濃度等

[illegible]

令和6年度 排ガス中のばい煙濃度等

11月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.25	0	0.24	0	0	0	-	-	-	-	-	-	2	0	2.0
2															
3															
4															
5															
6															
7															
8															
9	0.62	0.01	0.42	44	1	22.0	60	0	32.0	0	0	0.0	6	0	4.0
10	0.92	0.37	0.72	16	0	1.0	44	28	36.0	0	0	0.0	6	3	4.0
11	0.74	0.03	0.05	2	0	0.0	54	1	39.0	0	0	0.0	5	0	3.0
12	0.64	0.00	0.33	9	0	0.5	45	27	37.0	0	0	0.0	4	0	3.5
13	0.58	0.06	0.35	2	0	0.0	49	32	40.0	0	0	0.0	7	1	3.5
14	0.54	0.00	0.30	3	0	0.0	49	37	43.0	0	0	0.0	5	0	3.0
15	0.57	0.02	0.29	6	0	0.0	48	1	37.0	0	0	0.0	4	0	3.0
16	1.00	0.13	0.46	3	0	0.0	45	30	40.0	0	0	0.0	4	2	3.5
17	0.91	0.18	0.46	16	0	1.0	59	32	41.0	0	0	0.0	7	2	4.0
18	0.88	0.01	0.40	2	0	0.0	56	29	46.0	0	0	0.0	4	0	2.5
19	0.40	0.00	0.26	4	0	0.0	46	0	37.0	0	0	0.0	5	0	3.5
20	0.40	0.00	0.26	4	0	0.0	46	0	37.0	0	0	0.0	5	0	3.5
21	0.70	0.00	0.29	14	0	1.5	43	0	32.0	0	0	0.0	8	0	4.5
22	0.44	0.11	0.27	9	0	0.5	42	23	36.0	0	0	0.0	7	1	4.5
23	0.41	0.03	0.27	13	0	0.5	44	31	38.0	0	0	0.0	7	1	3.5
24	0.62	0.08	0.30	1	0	0.0	41	30	37.0	0	0	0.0	6	1	3.5
25	0.94	0.02	0.42	3	0	0.0	43	33	40.0	0	0	0.0	5	0	2.0
26	0.94	0.10	0.38	0	0	0.0	45	8	35.0	0	0	0.0	6	0	3.5
27	0.78	0.11	0.33	0	0	0.0	46	30	37.0	0	0	0.0	7	2	4.5
28	0.70	0.11	0.31	14	0	0.5	44	31	39.0	0	0	0.0	7	2	4.5
29	0.86	0.11	0.34	1	0	0.0	43	31	39.0	0	0	0.0	8	2	4.5
30	0.72	0.11	0.32	0	0	0.0	13	29	39.0	0	0	0.0	7	2	5.0

令和6年度 排ガス中のばい煙濃度等

12月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値: 20mg/Nm3以下			維持管理基準: 100ppm以下			管理値: 70ppm以下			管理値: 20ppm以下			管理値: 50ppm以下		
	排出基準: 150mg/Nm3以下						排出基準: 250ppm以下						排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.40	0.10	0.27	1	0	0.0	45	12	39.0	0	0	0.0	7	1	5.0
2	0.62	0.11	0.30	0	0	0.0	47	25	39.0	0	0	0.0	7	1	5.0
3	0.62	0.02	0.28	3	0	0.5	44	27	39.0	0	0	0.0	7	0	2.5
4	0.65	0.11	0.31	6	0	0.5	56	26	41.0	1	0	0.0	31	2	1.5
5	0.40	0.05	0.27	2	0	0.5	57	9	39.0	1	0	0.0	7	1	3.0
6	1.13	0.01	0.40	1	0	0.5	50	1	36.0	0	0	0.0	4	0	2.5
7	0.59	0.00	0.24	1	0	0.0	43	0	21.0	0	0	0.0	3	0	1.5
8	0.64	0.00	0.24	3	0	0.0	42	0	19.5	0	0	0.0	4	0	1.5
9	0.93	0.00	0.24	0	0	0.0	59	0	21.5	0	0	0.0	6	0	1.5
10	0.59	0.00	0.22	0	0	0.0	44	0	18.5	0	0	0.0	2	0	1.0
11	0.65	0.00	0.36	6	0	1.0	57	0	40.5	0	0	0.0	4	0	3.5
12	0.81	0.02	0.34	4	0	0.5	61	3	40.5	0	0	0.0	3	0	2.0
13	0.68	0.05	0.30	10	0	0.5	60	14	38.5	0	0	0.0	3	1	2.0
14	0.58	0.00	0.28	11	0	1.0	54	0	37.5	1	0	0.0	4	0	2.0
15	2.41	0.11	0.34	5	0	1.0	55	24	41.0	2	0	0.5	3	2	3.0
16	1.18	0.00	0.36	1	0	0.5	61	0	35.0	0	0	0.0	4	0	2.0
17	1.00	0.11	0.42	1	0	0.5	55	12	35.0	0	0	0.0	3	1	2.0
18	0.75	0.09	0.34	25	0	1.0	47	15	33.0	1	0	0.0	3	1	3.0
19	0.76	0.11	0.31	16	0	1.0	51	14	36.5	1	0	0.0	4	2	3.0
20	0.70	0.01	0.33	1	0	0.5	55	4	37.5	0	0	0.0	3	0	3.0
21	0.53	0.01	0.27	1	0	0.5	55	2	35.5	1	0	0.0	4	0	3.0
22	0.40	0.11	0.27	7	0	1.0	54	24	38.0	1	0	0.0	4	2	3.0
23	0.45	0.11	0.28	1	0	0.5	55	23	37.0	0	0	0.0	4	2	3.0
24	1.19	0.00	0.29	0	0	0.0	51	27	20.5	0	0	0.0	3	0	1.0
25	1.19	0.00	0.29	0	0	0.0	51	27	20.5	0	0	0.0	3	0	1.0
26	0.05	0.00	0.21	1	0	0.0	51	0	20.0	0	0	0.0	4	0	1.5
27	0.45	0.00	0.13	0	0	0.0	44	0	12.0	0	0	0.0	4	0	1.0
28	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
29	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
30	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
31	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0

令和6年度 排ガス中のばい煙濃度等

1月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
2	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
3	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
4	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
5	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
6	0.00	0.00	0.00	0	0	0.0	0	0	0.0	0	0	0.0	0	0	0.0
7	0.15	0.00	0.08	27	0	1.5	50	0	17.5	1	0	0.0	4	0	1.5
8	0.21	0.00	0.08	1	0	0.5	54	0	22.0	1	0	0.0	3	0	1.5
9	2.37	0.09	0.86	30	0	2.5	59	1	32.0	4	0	0.5	4	0	3.0
10	2.01	0.00	0.72	12	0	2.0	58	0	34.0	2	0	0.5	4	0	3.0
11	1.50	0.08	0.67	15	0	1.5	62	19	37.5	1	0	0.0	5	2	3.5
12	1.21	0.11	0.58	20	0	2.5	56	25	39.0	1	0	0.0	6	2	4.0
13	1.32	0.11	0.65	6	0	1.0	59	23	43.5	1	0	0.5	4	2	3.0
14	1.22	0.01	0.54	6	0	0.0	57	3	17.5	1	0	0.0	4	0	3.0
15	1.12	0.05	0.47	14	0	1.5	60	10	37.0	1	0	0.5	5	2	3.0
16	1.70	0.05	0.52	11	0	1.0	54	4	36.0	1	0	0.5	6	0	3.5
17	1.85	0.11	0.68	5	0	0.5	53	24	37.0	1	0	0.0	4	2	3.0
18	0.83	0.11	0.42	12	0	1.0	54	26	37.5	1	0	0.0	4	2	3.0
19	1.03	0.11	0.47	12	0	1.5	55	28	40.0	0	0	0.0	4	2	3.0
20	1.15	0.09	0.52	15	0	1.0	62	22	42.0	0	0	0.0	5	2	2.5
21	0.78	0.06	0.37	11	0	1.0	50	17	40.5	0	0	0.0	4	2	3.0
22	0.62	0.00	0.32	14	0	1.5	51	1	38.5	0	0	0.0	5	0	3.0
23	1.71	0.10	0.54	7	0	0.5	57	2	42.0	0	0	0.0	4	0	2.0
24	1.57	0.00	0.68	8	0	1.0	51	0	39.5	0	0	0.0	2	0	2.0
25	1.59	0.01	0.65	21	0	1.5	49	3	36.0	1	0	0.0	3	0	2.5
26	1.65	0.11	0.60	20	0	3.0	53	26	37.5	1	0	0.0	4	2	2.5
27	1.32	0.00	0.46	7	0	1.0	53	0	34.5	0	0	0.0	4	0	2.5
28	0.80	0.00	0.39	27	0	1.5	59	0	38.0	1	0	0.0	4	0	2.5
29	0.96	0.01	0.39	24	0	2.0	57	1	38.5	1	0	0.0	5	0	2.5
30	1.80	0.11	0.54	25	0	1.0	54	25	39.0	1	0	0.5	5	2	3.5
31	1.38	0.04	0.51	20	0	1.5	57	11	41.5	0	0	0.0	5	1	2.5

令和6年度 排ガス中のばい煙濃度等

2月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			維持管理基準: 100ppm以下			管理値: 70ppm以下 排出基準: 250ppm以下			管理値: 20ppm以下			管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.72	0.11	0.38	18	0	2.0	62	32	46.0	0	0	0.0	4	2	2.5
2	1.14	0.11	0.45	13	0	1.5	62	33	47.0	0	0	0.0	4	1	2.5
3	1.29	0.00	0.59	18	0	3.5	59	0	43.0	1	0	0.0	3	0	2.0
4	1.90	0.11	0.64	10	0	1.0	57	30	45.5	1	0	0.0	3	1	2.0
5	1.49	0.11	0.60	22	0	1.5	61	14	43.0	0	0	0.0	3	1	2.0
6	1.48	0.08	0.63	20	0	1.0	63	19	41.0	0	0	0.0	3	1	2.0
7	4.01	0.00	1.05	10	0	1.5	49	0	29.0	0	0	0.0	3	0	2.0
8	2.10	0.01	0.91	17	0	1.0	54	3	33.5	0	0	0.0	4	0	2.0
9	1.92	0.02	0.61	13	0	2.0	54	6	34.5	0	0	0.0	4	0	2.5
10	3.08	0.02	0.88	4	0	1.0	51	8	33.0	0	0	0.0	3	0	2.5
11	1.87	0.00	0.59	2	0	0.0	54	0	20.0	0	0	0.0	3	0	1.5
12	1.41	0.00	0.51	10	0	1.0	54	0	20.5	0	0	0.0	3	0	1.5
13	1.91	0.00	0.46	20	0	2.0	53	0	22.5	0	0	0.0	3	0	1.5
14	3.21	0.00	0.99	1	0	0.0	52	0	18.5	0	0	0.0	4	0	1.5
15	3.17	0.00	1.08	19	0	0.5	55	0	19.5	0	0	0.0	3	0	1.5
16	1.61	0.00	0.60	6	0	0.0	53	0	19.5	0	0	0.0	3	0	1.5
17	2.22	0.00	0.65	18	0	1.0	49	0	18.5	0	0	0.0	4	0	1.5
18	2.12	0.00	0.77	8	0	0.5	43	0	17.0	0	0	0.0	3	0	1.5
19	2.75	0.00	0.92	4	0	0.0	45	0	19.5	0	0	0.0	3	0	1.0
20	2.38	0.00	0.90	7	0	0.5	51	0	18.0	0	0	0.0	3	0	1.5
21	3.15	0.00	1.15	2	0	0.0	44	0	16.5	0	0	0.0	3	0	1.0
22	3.15	1.20	2.29	2	0	0.0	44	9	33.0	0	0	0.0	3	1	2.0
23	3.23	0.00	1.16	0	0	0.0	43	0	18.0	0	0	0.0	3	0	1.0
24	3.21	0.00	1.14	0	0	0.0	40	0	18.0	0	0	0.0	3	0	1.5
25	3.37	0.00	1.18	0	0	0.0	47	0	19.0	0	0	0.0	3	0	1.5
26	3.11	0.00	0.89	9	0	0.5	58	0	15.0	0	0	0.0	4	0	1.5
27	3.31	0.00	1.01	22	0	1.5	51	0	18.5	0	0	0.0	4	0	1.5
28	3.60	0.00	1.34	0	0	0.0	52	0	21.0	0	0	0.0	4	0	1.5

令和6年度 排ガス中のばい煙濃度等

3月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
	2.58	1.49	1.96	0	0	0.0	51	34	41.0	0	0	0.0	4	2	2.0
2	2.45	0.00	0.94	24	0	3.0	50	0	30.5	1	0	0.0	4	0	3.0
3	2.29	0.11	0.97	10	0	1.0	54	30	42.5	1	0	0.5	3	2	3.0
4	3.13	0.05	1.05	9	0	1.0	63	11	45.5	1	0	0.5	4	1	3.0
5	3.31	0.02	1.22	1	0	0.5	54	3	41.0	1	0	0.5	3	0	3.0
6	3.31	0.02	1.22	1	0	0.5	54	3	41.0	1	0	0.5	3	0	3.0
7	2.62	0.11	1.17	1	0	0.5	55	30	43.0	1	0	0.0	4	2	2.5
8	2.16	0.01	0.82	10	0	1.0	53	0	35.0	1	0	0.0	4	0	2.5
9	1.43	0.00	0.65	1	0	0.5	47	1	35.5	1	0	0.0	4	0	3.0
10	3.91	0.07	1.13	6	0	1.0	58	27	41.0	0	0	0.0	4	2	3.0
11	2.66	0.01	1.15	13	0	1.0	56	1	41.0	0	0	0.0	4	0	3.0
12	2.72	0.01	1.14	22	0	1.0	58	1	38.5	0	0	0.0	4	0	2.5
13	0.22	0.06	0.15	3	1	1.0	51	5	38.0	0	0	0.0	4	1	2.0
14	0.18	0.11	0.15	2	1	1.0	59	24	39.0	1	0	0.0	3	2	2.0
15	0.19	0.11	0.15	1	1	1.0	55	31	43.0	1	0	0.0	2	1	2.0
16	0.15	0.11	0.15	2	1	1.0	58	33	45.0	0	0	0.0	5	1	3.0
17	0.19	0.00	0.14	2	0	1.0	57	0	39.0	0	0	0.0	3	0	2.0
18	0.19	0.08	0.15	2	0	1.0	64	27	43.0	0	0	0.0	3	1	2.0
19	0.17	0.00	0.08	10	0	1.0	58	0	21.5	0	0	0.0	3	0	1.0
20	0.15	0.00	0.08	1	0	0.5	60	0	24.0	0	0	0.0	3	0	1.0
21	0.15	0.11	0.15	6	1	2.0	62	37	49.0	0	0	0.0	3	2	3.0
22	4.65	0.02	2.02	17	0	3.5	58	3	32.0	0	0	0.0	6	1	4.0
23	3.56	0.11	1.50	12	0	1.0	52	29	39.5	1	0	0.0	4	2	3.0
24	3.54	0.00	1.54	9	0	1.0	57	0	42.5	0	0	0.0	4	0	3.0
25	4.66	0.08	1.85	4	0	0.5	56	8	43.5	0	0	0.0	4	1	3.0
26	4.57	0.11	1.59	22	0	4.0	54	5	41.5	0	0	0.0	3	1	3.0
27	3.85	0.09	1.49	10	0	2.0	55	30	43.5	0	0	0.0	3	1	2.5
28	3.85	0.09	1.49	10	0	2.0	55	30	43.5	0	0	0.0	3	1	2.5
29	2.40	0.02	0.92	15	0	2.0	55	1	43.0	1	0	0.0	4	0	2.5
30	2.08	0.01	0.80	31	0	2.5	57	1	39.0	1	0	0.5	4	0	3.0
31	2.93	0.00	1.07	3	0	0.5	56	0	35.5	1	0	0.5	4	0	2.5