

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分のごみの供給停止中。

(単位:℃)

4月		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考
1	1号炉	993	972	956	946	981	965	972	941	985	947	938	981	938	976	950	950	968	955	976	981	988	983	978	967	8:32～13:00給じん停止
	2号炉	979	1002	982	976	998	1018	994	958	877					991	980	1001	978	971	951	965	964	979	969	967	
2	1号炉	982	988	954	961	950	977	954	956	950	958	983	995	942	945	980	977	971	957	942	951	949	925	934	936	
	2号炉	972	981	948	933	957	967	945	963	962	934	1003	979	993	978	980	988	951	966	984	987	1003	994	975	959	
3	1号炉	930	987	1017	998	1000	1000	1008	1029	1015	1030	1024	996	999	997	1000	984	977	1006	982	999	1038	984	949	990	
	2号炉	987	999	957	942	977	961	985	998	997	969	983	975	978	924	985	965	964	994	973	982	973	953	949	1004	
4	1号炉	989	1011	1009	979	1000	1015	991	1008	993	1038	1031	1007	995	935	972	975	980	974	976	1000	985	991	1005	1023	
	2号炉	1000	974	973	981	968	988	978	997	991	1005	991	975	979	981	990	979	982	1004	989	967	981	995	1007	1017	
5	1号炉	1023	1006	990	984	981	970	956	968	966	989	987	1012	980	981	983	988	982	990	996	969	974	968	966	971	
	2号炉	988	959	993	990	967	996	976	1008	986	993	970	993	992	1005	1000	949	965	994	1000	975	969	963	982	968	
6	1号炉	976	952	962	919	941	958	977	967	1016	1014	991	996	990	964	996	1000	984	994	1022	990	973	981	973	949	
	2号炉	991	952	973	941	972	950	931	974	987	978	965	964	982	950	971	973	990	1001	1006	997	959	996	990	922	
7	1号炉	955	959	969	965	962	959	982	1010	915					1023	993	1015	1005	987	1003	991	1030	1039	1025	1037	8:34～13:41給じん停止
	2号炉	961	953	986	974	934	975	969	996	970	936	964	984	936	900	947	903	909	953	949	1008	1030	1037	997	1007	
8	1号炉	1025	1008	1027	1034	1021	948	958	961	941	982	925														10:36～休炉
	2号炉	994	960	1020	1015	1021	1036	964	974	870																8:31～給じん停止 休炉
9	1号炉																									休炉
	2号炉																									休炉
10	1号炉																									休炉
	2号炉																									休炉
11	1号炉																									休炉
	2号炉																									休炉
12	1号炉																									休炉
	2号炉																									休炉
13	1号炉																									休炉
	2号炉																									休炉
14	1号炉																									休炉
	2号炉																									休炉
15	1号炉					1022	1062	1111	1071	1069	1028	1010	1003	1000	997	995	1004	1017	991	1039	905	977	1039	1028	1010	立上げ～定常運転(4:08)
	2号炉										946	998	1007	1006	980	977	1014	998	893		935	1007	982	972	984	立上げ～定常運転(9:18) 17:27～19:42給じん停止

	4月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備考
16	1号炉	1019	1017	986	994	984	985	975	986	994	996	1008	1012	1021	988	994	1002	1044	1019	1017	1014	979	1011	1019	1023	
	2号炉	1011	1014	1028	1023	984	979	966	968	994	980	983	1006	1017	1011	1020	984	1016	999	1020	1009	1004	968	984	1007	
17	1号炉	998	997	1010	1040	1022	1018	1024	1036	1049	1019	1028	1062	991	952	972	1040	1047	1021	1013	1022	986	1065	1014	1066	
	2号炉	970	994	1056	991	1007	986	974	990	988	997	1007	1008	980	999	1015	1016	1021	1007	965	965	982	1001	962	994	
18	1号炉	1051	1016	1027	1026	1033	1030	1030	1030	1029	1032	1003	1028	1025	1031	994	1023	1012	1036	1009	1007	1048	1071	1045	1051	
	2号炉	1034	1022	1055	1033	1016	1032	1057	1049	1046	1039	1017	1004	1004	1005	1048	998	1018	984		956	982	1058	1025	1001	17:50～19:02給じん停止
19	1号炉	1044	1030	1076	1108	1073	1041	1062	1026	1053	1034	1028	1065	1039	1041	1025	1031	1032	1060	1060	1048	1062	1036	1037	1027	
	2号炉	1039	998	997	1010	1007	1021	1004	1050	1018	995	1027	1036	1015	985	1023	1056	1029	1037	1037	989	1018	1045	989	1009	
20	1号炉	1019	1047	1047	1050	1071	1029	1049	1080	1049	914	1001	1051	1049	990	965	1037	1039	1033	1055	1050	1023	1037	1053	1048	
	2号炉	1032	1069	1019	988	973	1002	1037	1000	1016	1018	1013	1003	971	1015	1002	986	1015	1012	1007	1039	1028	875		992	21:15～23:00給じん停止
21	1号炉	1053	1040	1048	1080	1011	1069	1061	1013	902																定常運転～立下げ(8:43～)
	2号炉	1027	1031	1021	1047	1017	1072	1052	1021	1022	1013	1018	990	982	976	1030	1004	1000	982	1041	966	999	948	1029	969	
22	1号炉																									休炉
	2号炉	994	1011	1012	966	916	974	945	1020	1033	1006	967	938	934	926	966	962	958	989	955	965	965	1010	967		22:43～24:01給じん停止
23	1号炉																									休炉
	2号炉	979	914	958	936	969	982	971	1007	885		972	910	1001	947	980	939	985	1005	1003	1000	1001	1036	1049	1007	8:32～10:02給じん停止
24	1号炉																									休炉
	2号炉	1017	1014	997	963	1001	995	1038	1032	1039	1035	1011	1025	994	1011	1026	987	976	1020	1044	1010	1016	1012		997	21:41～23:17給じん停止
25	1号炉																									休炉
	2号炉	974	995	989	960	996	1032	1014	948	943	983	986	1019	1013	1023	1014	979	1023	984	1035	1004	1038	1005	1032	1029	
26	1号炉																									休炉
	2号炉	1054	1050	1036	1029	1005		1043	1005	987	1016	1030	1029	1035	1013	990	1009	995	1027	978	964	1014	1013	1032	992	4:30～6:00給じん停止
27	1号炉																									休炉
	2号炉	1017	984	948	966	1008	998	974	1006	1011	1008	1011	1021	1005	1003	1011	1019	1027	1016	1019	1013		1008	1018	1003	19:13～21:22給じん停止
28	1号炉																									休炉
	2号炉	1037	1023	1006	1027	987	996	994	1011	1021	1016	1002	989	989	980	986	985	980	991	1002	997	1003	998	1016	1015	
29	1号炉																									休炉
	2号炉	993	968	1025	983	1025	986	1001	1031	1011	1019	986	957	976	1024	983	1021	1035	991	1030	1034	1018	993	1041	1015	
30	1号炉																									休炉
	2号炉	1004	989		965	1028	1023	1022	1039	929			994	1044	1030	985	1035	980	993	1036	1029	990	967	1017	1015	1:57～3:27給じん停止 8:35～11:28給じん停止

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉																									休炉
	2号炉	1007	1011	1027	1011	986	1012	1021	1014	1028	1009	991	973	968	967	977	985	985	976	987	991	993	981	996	991	
2	1号炉																									休炉
	2号炉	966	1001	1039	1033	1030	1045	1041	984	967	1021	1021	989	959	981	971	1034	1004	988	1000	1011	977	972	1009	987	
3	1号炉																									休炉
	2号炉	1003	974	973	865	868	980	1010	999	988	977	962	976	1002	974	982	995	986	960	1006	989	1013	985	991	987	
4	1号炉																									休炉
	2号炉	1005	980	1009	1016	999	1015	1015	1022	1026	1001	1011	1007	997	990	1001	1016	1006	996	1012	995	1016	1004	1011	1019	
5	1号炉																									休炉
	2号炉	1017	980	987	972	1024	1018	1013	1015	1010	976	1020	1003	1012	986	989	1006	1004	1000	1022	1015	1021	1024	1025	1018	
6	1号炉																									休炉
	2号炉	1010	1005	997	1015	1035	1026	1005	1011	979	1029	1005	1021	996	991	995	991	985	1019	1014	1035	1013	981	1045	1021	
7	1号炉																									休炉
	2号炉	993	1020	1015	1016	1012	1004	1006	1024	925	890	1025	999	976	1003	1000	1028	1031	1029	1018	1026	1026	1026	1010		8:40～11:07給じん停止
8	1号炉																									休炉
	2号炉	1011	1035	1037	1017	999	1020	1036	1019	1014	1017	971	1024	999	985	999	978	994	992	1008	966	1008	971	990	1022	
9	1号炉																									休炉
	2号炉	987	1034	1003	1025	1001	1001	1013	1002	1006	997	985	1001	989	1035	985	998	1013	997	1019	1009	1019	1031	984	1030	
10	1号炉																									休炉
	2号炉	1032	899		969	989	1001	1023	1000	1018	1004	1011	1006	1019	1026	999	987	1000	982	1013	1011	1002	1021	1032	1024	1:30～3:00給じん停止
11	1号炉																									休炉
	2号炉	1019	1023	1001	1015	1002	1020	1009	1034	989	988	1009	1003	1012	1000	1003	1006	980		1024	1025	1004	982	1000	1003	16:50～18:51給じん停止
12	1号炉																									休炉
	2号炉	996	1010	1018	1023	982	984	995	1002	1008	1005	996	975	975	976	997	981	996	975	982	990	1001	976	981	998	
13	1号炉																									休炉
	2号炉	994	972	1040	1015	990	991	992	1004	990	997	993	974	953	960	968	971	968	975	970	974	972	987	976	980	
14	1号炉																									
	2号炉	978	973	1026	1004	988	1007	983	1011	1007	1005	992	994	1003	998	975	1012	1000	1013	983	1028	992	1007	994	995	
15	1号炉																		931	994	990	939	993	1013	1025	立上げ～給じん開始(17:44)
	2号炉	1009	1021	989	993	1010	1018	1032	1018	865			1008	986	973	953	960	986	1021	976	972	970	983	1018	1000	8:30～11:14給じん停止

	5月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備	考
16	1号炉	1066	982	938	957	989	988	1015	1024	983	937	947	956	950	946	979	971	1007	984	1002	979	988	986	996	986		
	2号炉	984	1025	947	981	978	991	996	991	965	974	999	982	984	951	973	1009	989	996	1004	1029	989	989	981	989		
17	1号炉	1006	990	1010	996	1024	976	935	958	967	1024	986	976	1019	1005	986	966	980	1002	1007	1025	969	968	1004	972		
	2号炉	996	1011	1004	1007	994	1012	966	973	992	979	1004	983	1003	980	996	988	995	989	1021	1001	994	978	942	1028		
18	1号炉	1017	1002	977	1010	982	966	1022	1013	1013	988	967	1004	991	1037	982	968	957	950	999	996	1038	1007	936	1028		
	2号炉	953	999	993	993	973	986	1008	995	988	983	969	969	969	969	957	968	975	983	974	1010	1033	990	964	971		
19	1号炉	965	961	952	1005	985	983	990	9789	972	929	978	944	984	953	972	978	1014	982	952	1003	960	1005	1018	1020		
	2号炉	984	957	977	968	991	993	954	977	985	988	974	957	991	954	984	945	989	977	976	984	991	985	1004	996		
20	1号炉	998	986	1032	1001	989	1030	993	1030	991	1029	990	978	957	934	930	962	973	970	999	958	971	976	985	984		
	2号炉	1017	1005	1002	993	1008	986	977	1006	1006	925	991	982	972	966	962	984	993	969	971	981	997	989	931	962		
21	1号炉	979	975	946	989	954	956	972	993	870			1031	957	952	953	989	992	992	1051	973	992	981	965	977	8:32～11:55給じん停止	
	2号炉	1006	985	985	996	997	985	1005	1012	969	1002	997	964	955	961	990	980	994	979		960	1005	987	995	991	17:57～19:02給じん停止	
22	1号炉	950	962	952	969	965	1003	955	947	998	979	969	944	956	947	958	997	982	969	1000	1013	986	968	940	961		
	2号炉	992	983	992	1005	979	994	984	985	862			1023	974	955	968	992	984	982	995	981	983	981	974	971	8:30～11:18給じん停止	
23	1号炉	974	969	1036	957	1027	983	1025	978	983	1021	1030	938	960	942	959	958	982	976	979	983	976	982	1004	1012		
	2号炉	991	1017	1013	1018	1001	1011	977	1019	979	991	981	992	969	983	977	951	989	982	992	1014	1001	997	995	991		
24	1号炉	1024	1024	992	1018	1009	998	992	1016	1008	994	1028	999	1021	1018	1027	970	1017	970	988	982	972	1013	1026	1018		
	2号炉	1001	993	1007	1002	1015	978	986	990	974	1000	1030	1003	992	976	1005	1002	1001	980	1002	979	988	999	1004	1009		
25	1号炉	1019	1062	1003	1012	1025	1000	1045	1043	1009	1045	1028	1026	986	1012	1039	1057	1012	1009	1018	1014	1038	1027	1037	1017		
	2号炉	997	1025	1022	1040	1022	999	1004	999	997	995	982	999	998	1013	993	1014	1013	1006	988	998	1008	1005	984	993		
26	1号炉	996	1018	1024	1001	1041	1076	1039	990	1056	1037	1067	1030	1061	1052	1068	982	964	961	1043	1040	1073	997	1010	1001		
	2号炉	1007	1001	986	1003	1017	1003	1018	1015	1018	1010	976	967	986	1001	976	1004	965	978	958	999	1009	972	975	974		
27	1号炉	1027	1000	1053	1005	1014	1011	1011	1009	1001				992	992	976	971	984	991	984	991	983	990	970	981	8:31～12:10給じん停止	
	2号炉	962	980	984	1002	1001	1003	1039	993	949	965	978	970	957	940	984	957	980	959			969	968	1011	989	17:50～20:00給じん停止	
28	1号炉	997	1006	989	987	1019	1014	973	958	952	931	971	988	1050	978	904	938	1000	1007	988	984	980	968	1020	1010		
	2号炉	995	995	964	969	977	949	970	961	980	951	981	972	977	968	968	966	955	972	962	974	972	972	981	965		
29	1号炉	985	1045	1051	1033	986	996	1033	999	1000	1020	1016	1023	941	929	922	970	996	927	937	940	935	935	950	963		
	2号炉	966	900	977	950	978	988	988	977																	通常運転～立下げ(8:46)	
30	1号炉	956	954	968	960	971	968	967	982	927	938	938	916	924	933	934	946	938	955	955	939	965	928	971	1012		
	2号炉																									休炉	
31	1号炉	1026	972	993	988	977	960	979	976	982	989	969	974	994	969	995	1036	1052	1013	1014	1000	1034	1019	1043	1005		
	2号炉																									休炉	

燃焼室中の燃焼ガス温度(維持管理基準800℃以上)

令和7年 ※1時間ごとの平均値(二次燃焼室入口温度)。空白部分はごみの供給停止中。

(単位:℃)

6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備 考	
1	1号炉	1020	1014	1038	1026	1058	1006	1007	1008	935	997	1037	1009	1020	1013	1011	1045	1019	1052	1069	1041	1031	1006	1067	1000	
	2号炉																									休炉
2	1号炉	985	1004	971	996	991	1013	994	1027	1018	983	999	938	939	944	938	911	943	957	1006	1016	955	994	953	937	
	2号炉																									休炉
3	1号炉	957	945	925	949	939	951	926	949	933	924	934	909	911	904	932	911	904					1000	920	936	16:54～21:40給じん停止
	2号炉																									休炉
4	1号炉	926	919	923	942	935	944	994	1013	985	935	941	929	933	948	917	932	930	906	941	945	954	970	982	974	
	2号炉																									休炉
5	1号炉	966	948	936	939	940	951	975	991	951	970	976	944	914	988	989	936	944	953	983	974	964	982	975	961	
	2号炉																									休炉
6	1号炉	964	974	985	1002	1008	1012	1002	1011	985	995	1015	986	974	1020	991	965	979	940	926	974	984	928	984	1012	
	2号炉																									休炉
7	1号炉	964	944	992	920	956	940	977	990	973	970	956	1007	992	966	998	1040	1019	1002	954	1020	1017	1018	1042	1028	
	2号炉																									立上げ～定常運転(7:56～)
8	1号炉	1016	1004	1009	1015	979	963	961	1007	967	1032	1039	997	987	1040	1004	1019	1000	1004	995	996	1054	1063	1034	1029	
	2号炉	999	975	970	969	1025	998	977	988	985	1016	983	972	975	943	961	970	983	989	970	996	1010	987	956	963	
9	1号炉	1077	1049	1046	1012	980	1006	1026	1047	983	979	984	967	954	949	938	960	995	973	982	1001	976	1002	968	991	
	2号炉	980	1014	1021	9997	964	992	1002	998	965	934	966	959	946	956	935	985	964	956	969	968	987	960	960	945	
10	1号炉	1081	1034	1000	986	967		960	981	872			1025	952	954	930	954	944	940	945	924	940	926	993	926	4:47～6:00 8:35～11:45 給じん停止
	2号炉	956	947	963	986	985	981	964	972	957	957	988	979	962	960	967	978	963	937	961	954	965	973	972	965	
11	1号炉	938	921	934	956	950	952	932	960	994	932	998	952	992	954	959	1006	955	992	986	989	1000	99+	1021	983	
	2号炉	970	979	969	991	948	974	1003	995	937	960	984	932	965	972	958	969	959	959	947	957	954	971	958	929	
12	1号炉	1007	995	1017	986	1018	969	976	952	991	950	971	945	938	939	906	918	932	954	914	956	968	942	977	954	
	2号炉	952	923	986	948	951	957	967	967	979	953	967	956	934	949	950	960	969	961	969	949	973	951	980	984	
13	1号炉	983	967	920	976	981	952	1030	972	988	945	944	948	919	920	934	935	925	945	964	995	971	964	963	993	
	2号炉	972	948	945	952	985	945	964	989	836			975	925	950	939	959	945	965	990	983	986	955	907	963	8:30～11:23給じん停止
14	1号炉	1022	960	967	953	979	961	959	1003	992	976	991	988	982	1003	993	1049	996	1032	1002	1048	997	990	1002	1018	
	2号炉	944	909	940	937	948	946	960	950	985	982	948	967	947	987	965	998	918	957	962	996	977	958	981	969	
15	1号炉	988	970	1048	1017	1005	1032	1030	984	970	997	1000	1009	1023	999	1018	1037	1007	1023	982	1012	1022	1025	1035	1042	
	2号炉	989	971	976	972	973	971	945	949	954	947	947	980	991	954	976	962	930	982	952	935	958	946	974	958	

	6月	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	備	考
16	1号炉	1020	1026	1038	996	1040	1048	1005	1011	949	992	1008	1013	937	929	944	957	954	947	948	975	995	1030	1001	1020		
	2号炉	965	969	920	958	948	955	960	948	944	943	939	940	926	904	925	944	940	923	930	937	976	941	933	956		
17	1号炉	1004	1033	1007	1012	970	1042	1059	1067	927	808	1005	1058	1008	974	974	974	1005	964	1005	1016	993	1018	1014	1016		
	2号炉	960	932	978	930	938	937	949	975	941	923	937	944	926	910	931	932	940	935	917	963	938	928	966	951		
18	1号炉	977	996	1010	993	1039	1023	1034	1040	1014	1009	1014	1003	996	1013	1044	1004	989	1028	1068	1049	1036	1032	1023	1032		
	2号炉	935	950	960	945	949	927	967	977	953	926	978	943	933	958	944	970	946	939	931	942	972	945	949	936		
19	1号炉	1046	1048	1065	1051	1041	1048	981	1001	1035	1004	981	1061	991	999	986	1015	1031	992	985	981	1033	999	1083	1004		
	2号炉	947	946	959	958	970	964	913	948	952	963	960	967	920	913	934	947	947	922	940	945	943	917	942	924		
20	1号炉	984	1024	994	1026	1003	1024	1063	995	1035	1022	974	992	1009	973	989	1025	1027	1024	1051	1065	1055	1022	1060	1052		
	2号炉	896	860	908	965	944	913	927	932	809				910	939	928	958	951	952	971	898	939	934	921	947	8:33～12:08給じん停止	
21	1号炉	1044	1061	1028	1045	1060	1081	1064	1087	1062	1008	995	1011	1003	1081	1050	1074	1027	1072	1091	1039	1070	1054	1028	1046		
	2号炉	943	929	967	924	958	980	980	935	939	935	945	936	927	941	932	970	973	974	955	970	977	969	955	954		
22	1号炉	1053	1049	1041	1085	1059	1050	1009	1067	1053	1064	1045	1044	1037	1040	1057	1075	1034	1069	1011	1006	996	1018	1029	1037		
	2号炉	926	955	971	967	930	936	931	940	948	938	947	961	963	929	945	962	960	940	944	946	950	953	967	953		
23	1号炉	1029	1013	1072	1072	1018	1017	1006	1020	964	983	999	1005	955	949	990	934	942	970	963	980	1005	978	994	1005		
	2号炉	957	970	982	996	937	938	945	929	944	951	963	962	916	945	951	927	930	927	925	944	932	919	932	936		
24	1号炉	955		962	1023	1018	986	992	860	897				955	974	969	984	982	955	958	961	971	971	974	970	0:57～2:06 8:32～12:15 給じん停止	
	2号炉	948	931	926	934	928	959	922	966	958	940	959	969	961	936	952	930	963	961	935	934	969	958	957	964		
25	1号炉	978	956	941	968	957	961	953	1002	1001	980	953	978	983	971	975	994	920	978	960	955	998	982	983	990		
	2号炉	953	944	957	944	953	958	957	977	955	952	943	963	966	985	970	951	972	952	952	959	978	991	956	927		
26	1号炉	960	967	992	978	981	990	1007	1019	975	974	960	935	920	966	977	956	988	937	949	974	1002	1000	983	1005		
	2号炉		933	957	988	929	964	967	941	950	953	973	947	968	958	944	944	953	924	937	947	961	1001	924	965	23:49～1:17給じん停止	
27	1号炉	1018	970	944	966	970	949	956	993	966	958	973	956	974	961	954	974	985	973	1013	986	999	1005	985	980		
	2号炉	965	947	969	941	932	944	968	949	853			990	941	922	947	946	961	913	973	941	977	962	947	941	8:31～11:44給じん停止	
28	1号炉	977	953	929	925	990	968	971	942	965	959	964	925	942	982	988	970	955	1004	952	987	965	932	957	910		
	2号炉	939	954	951	955	958	976	973	959	965	945	965	969	961	982	960	941	973	953	979	918	974	961	991	925		
29	1号炉	954	940	980	959	973	982	992	973	997	1009	966	968	982	1020	918	955	945	969	940	950	918	961	972	982		
	2号炉	930	977	963	940	941	956	981	975	954	993	948	959	967	948	965	939	954	958	960	953	949	933	974	964		
30	1号炉	965	980	971	975	979	969	958	958	940	937	925	926	999	963	929	925	894	992	960	972	901	912	954	956		
	2号炉	933	957	965	918	969	958	964	937	961	993	954	961	964	979	981	954	936	936	933	938	936	915	893	906		