

令和7年度 排ガス中のばい煙濃度等

4月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素氧化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	3.05	0.07	1.12	19	0	2.0	54	24	38.0	0	0	0.0	3	1	2.0
2	3.22	0.08	1.14	21	0	2.5	57	31	46.0	0	0	0.0	3	1	2.0
3	2.92	0.07	1.04	6	0	1.0	55	34	45.0	0	0	0.0	3	1	2.5
4	2.81	0.07	1.20	8	0	1.5	65	32	47.0	0	0	0.0	3	2	2.0
5	2.00	0.08	0.73	19	0	2.0	62	32	45.5	0	0	0.0	5	1	3.0
6	1.53	0.11	0.71	24	0	3.5	55	33	45.5	0	0	0.0	5	2	3.0
7	16.00	0.01	0.67	17	0	1.5	56	2	40.0	0	0	0.0	5	0	3.5
8	16.70	0.10	0.76	4	0	0.5	57	26	44.0	0	0	0.0	5	2	4.0
9															
10															
11															
12															
13															
14															
15	4.19	0.00	1.30	15	0	2.5	53	0	26.0	0	0	0.0	4	0	2.5
16	4.86	0.12	1.83	18	0	1.5	59	30	45.5	0	0	0.0	4	2	2.5
17	4.83	0.12	1.43	23	0	3.5	61	5	45.0	0	0	0.0	16	0	3.0
18	3.58	0.11	1.39	7	0	1.5	53	18	40.0	0	0	0.0	5	1	2.5
19	3.20	0.00	1.24	28	0	5.0	56	0	38.5	0	0	0.0	18	0	4.0
20	2.71	0.02	1.15	29	0	4.0	59	6	42.5	0	0	0.0	11	1	4.0
21	3.59	0.11	1.36	2	0	0.5	54	3	39.0	0	0	0.0	5	0	3.5
22	5.84	0.41	3.80	21	0	3.0	59	4	42.0	0	0	0.0	3	1	2.0
23	5.28	0.11	3.59	17	0	4.0	51	0.1	35.0	0	0	0.0	3	0	2.0
24	5.97	0.26	4.10	16	1	2.0	54	7	42.0	0	0	0.0	2	0	2.0
25	5.52	1.90	4.31	19	0	3.0	58	28	45.0	0	0	0.0	3	2	2.0
26	4.12	1.59	3.18	18	0	5.0	52	14	43.0	0	0	0.0	3	1	2.0
27	3.90	0.56	2.81	27	0	3.0	60	5	45.0	0	0	0.0	5	1	3.0
28	6.02	1.69	4.13	4	0	0.0	63	38	51.0	0	0	0.0	4	3	3.0
29	5.18	2.65	3.73	1	0	0.0	61	34	52.0	0	0	0.0	4	2	3.0
30	4.73	0.32	3.31	7	0	1.0	62	5	42.0	0	0	0.0	4	1	3.0

令和7年度 排ガス中のばい煙濃度等

5月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	6.51	1.91	4.07	20	0	3.0	60	39	51.0	0	0	0.0	3	2	3.0
2	6.27	0.20	4.07	21	0	8.0	59	2	40.0	0	0	0.0	3	0	2.0
3	6.05	0.78	4.11	2	0	0.0	58	6	46.0	0	0	0.0	3	1	2.0
4	4.86	2.20	4.10	26	0	5.0	58	39	50.0	0	0	0.0	3	2	3.0
5	5.29	0.00	0.00	9	0	3.0	60	0	44.0	0	0	0.0	3	0	2.0
6	5.86	0.13	4.13	8	0	1.0	58	2	44.0	0	0	0.0	3	0	2.0
7	6.90	2.67	4.61	14	0	3.0	58	14	44.0	0	0	0.0	3	1	2.0
8	6.68	2.97	5.47	19	0	2.0	61	37	51.0	0	0	0.0	3	1	2.0
9	5.60	3.59	5.04	10	0	1.0	62	40	52.0	0	0	0.0	3	2	2.0
10	5.27	2.07	4.26	11	0	2.0	54	19	44.0	0	0	0.0	2	1	2.0
11	5.34	0.01	4.26	18	0	1.0	61	0	49.0	0	0	0.0	3	0	2.0
12	5.77	1.72	3.96	7	0	1.0	58	30	48.0	0	0	0.0	3	1	3.0
13	7.48	0.11	5.14	0	0	0.0	61	1	49.0	0	0	0.0	3	0	3.0
14	6.90	3.30	5.08	11	0	1.0	57	39	49.0	0	0	0.0	3	2	3.0
15	7.30	0.14	2.56	24	0	8.5	57	12	37.5	0	0	0.0	4	1	3.0
16	6.48	0.16	2.58	20	0	2.5	58	1	42.5	1	0	0.0	3	0	3.0
17	6.30	0.00	2.63	9	0	2.0	56	0	44.5	2	0	0.5	3	0	3.0
18	6.07	0.16	2.46	41	0	4.5	63	27	46.5	2	0	0.5	4	2	3.0
19	5.71	0.16	2.44	4	0	1.0	61	28	46.5	1	0	0.5	4	2	3.0
20	5.57	0.15	2.06	4	0	1.0	62	5	45.0	1	0	0.5	4	0	3.0
21	5.83	0.00	2.42	5	0	1.0	64	0	42.0	1	0	0.5	4	0	3.0
22	6.81	0.16	2.60	13	0	2.0	60	7	47.0	2	0	0.5	4	1	3.5
23	5.52	0.13	2.30	15	0	2.0	58	35	47.5	1	0	0.0	4	2	3.0
24	5.89	0.13	2.57	13	0	2.0	62	40	48.5	1	0	0.0	3	2	3.0
25	5.89	0.13	2.37	18	0	2.0	59	1	46.5	1	0	0.5	3	0	3.0
26	5.99	0.11	2.56	14	0	2.0	60	37	49.5	0	0	0.0	4	2	3.0
27	5.79	0.05	2.25	5	0	1.0	61	12	46.0	0	0	0.0	3	1	3.0
28	5.73	0.03	2.43	27	0	3.5	62	6	45.5	1	0	0.0	4	1	2.5
29	5.72	0.12	2.50	21	1	5.0	64	25	45.0	1	0	0.0	4	2	3.0
30	0.20	0.11	0.17	2	2	2.0	54	34	42.0	1	0	0.0	3	1	2.0
31	0.20	0.11	0.16	7	2	2.0	51	37	45.0	2	1	1.0	4	1	3.0

令和7年度 排ガス中のばい煙濃度等

6月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.20	0.09	0.15	12	2	3.0	55	31	46.0	1	1	1.0	1	1	1.0
2	0.20	0.11	0.17	5	2	3.0	51	33	44.0	1	0	0.0	5	3	4.0
3	0.15	0.01	0.14	2	0	2.0	53	0	43.0	1	0	0.0	4	0	4.0
4	0.20	0.11	0.17	15	1	3.0	60	27	40.0	1	0	0.0	4	2	4.0
5	0.20	0.11	0.17	15	2	3.0	58	30	43.0	1	0	0.0	4	2	4.0
6	0.31	0.11	0.18	5	2	2.0	52	30	38.0	1	0	0.0	5	3	4.0
7	0.52	0.11	0.31	23	0	3.5	57	7	37.5	0	0	0.0	5	2	4.0
8	0.42	0.13	0.29	9	0	2.0	59	27	42.0	1	0	0.0	5	2	3.0
9	0.48	0.12	0.30	23	0	1.0	56	34	42.5	1	0	0.0	5	1	2.5
10	0.49	0.00	0.30	7	0	0.5	58	1	42.0	0	0	0.0	3	0	2.0
11	2.00	0.01	0.31	12	0	2.5	61	0	22.0	1	0	0.0	4	0	2.5
12	0.51	0.13	0.31	20	0	2.0	61	32	45.5	1	0	0.0	5	1	2.5
13	0.59	0.07	0.31	4	0	1.5	54	6	40.5	1	0	0.0	5	1	2.5
14	0.45	0.16	0.30	13	0	2.5	58	24	42.5	1	0	0.0	6	1	3.0
15	0.40	0.16	0.30	12	0	2.0	56	31	43.5	2	0	0.5	6	2	4.0
16	0.40	0.18	0.32	18	0	2.0	62	2	23.0	1	0	0.5	5	2	3.5
17	0.48	0.02	0.31	9	0	1.5	53	1	30.5	2	0	0.5	4	0	2.5
18	0.43	0.18	0.33	18	0	2.5	58	31	42.5	1	0	0.5	7	2	3.5
19	0.40	0.18	0.32	4	0	1.0	61	36	44.0	1	0	0.0	7	2	3.5
20	0.92	0.03	0.37	24	0	4.5	57	3	37.0	1	0	0.0	5	1	3.0
21	1.04	0.18	0.39	14	0	4.5	61	30	44.0	1	0	0.5	6	1	3.5
22	0.54	0.18	0.33	6	0	1.5	61	37	45.5	2	0	0.5	7	2	3.5
23	0.40	0.03	0.31	9	0	1.0	60	2	43.5	1	0	0.0	4	0	2.5
24	0.65	0.02	0.35	3	0	1.0	52	0	39.0	1	0	0.0	4	0	2.0
25	0.44	0.11	0.31	22	0	3.0	56	6	43.5	1	0	0.5	4	1	2.5
26	0.44	0.11	0.31	22	0	3.0	56	6	43.5	1	0	0.5	4	1	2.5
27	0.56	0.01	0.32	17	0	2.0	60	1	43.5	1	0	0.0	4	0	2.5
28	0.45	0.18	0.33	14	0	2.0	59	34	44.0	1	0	0.0	5	1	3.0
29	0.41	0.18	0.32	15	0	1.5	58	31	42.5	0	0	0.0	4	1	2.5
30	0.40	0.03	0.29	15	0	2.0	58	3	40.0	0	0	0.0	4	0	2.5

令和7年度 排ガス中のばい煙濃度等

7月	ばいじん濃度(mg/Nm3) 管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.45	0.00	0.33	15	0	1.5	52	23	43.5	1	0	0.0	3	1	2.5
2	0.55	0.00	0.22	0	0	0.0	54	0	21.5	0	0	0.0	3	0	1.5
3	0.50	0.00	0.18	1	0	0.0	52	0	19.0	0	0	0.0	5	0	1.5
4	0.44	0.00	0.19	4	0	0.0	53	0	18.5	0	0	0.0	4	0	1.5
5	0.44	0.00	0.19	4	0	0.5	45	0	18.5	0	0	0.0	4	0	1.5
6	0.40	0.00	0.20	9	0	1.0	46	0	20.0	0	0	0.0	3	0	1.5
7	0.44	0.00	0.19	15	0	0.5	52	0	20.0	0	0	0.0	4	0	1.5
8	0.47	0.00	0.20	2	0	0.0	54	0	21.0	0	0	0.0	4	0	1.5
9	0.55	0.00	0.22	2	0	0.0	47	0	21.5	0	0	0.0	3	0	1.0
10	0.50	0.00	0.19	14	0	1.0	46	0	18.5	0	0	0.0	3	0	1.5
11	0.52	0.00	0.21	8	0	0.5	50	0	21.5	0	0	0.0	3	0	1.5
12	0.57	0.00	0.20	9	0	0.5	46	0	17.5	0	0	0.0	4	0	1.5
13	0.60	0.00	0.25	7	0	0.0	45	0	20.5	0	0	0.0	3	0	1.5
14	0.59	0.00	0.22	26	0	1.0	54	0	19.0	0	0	0.0	4	0	1.5
15	0.71	0.00	0.25	11	0	0.5	50	0	19.0	0	0	0.0	4	0	1.5
16	0.80	0.00	0.28	2	0	0.0	53	0	20.5	0	0	0.0	4	0	1.5
17	0.93	0.00	0.32	9	0	0.5	52	0	20.5	0	0	0.0	3	0	1.5
18	1.11	0.00	0.32	1	0	0.0	55	0	22.0	0	0	0.0	3	0	1.5
19	0.58	0.00	0.23	25	0	0.5	48	0	19.0	0	0	0.0	3	0	1.5
20	0.68	0.00	0.30	30	0	2.5	55	0	30.5	5	0	0.5	3	0	2.0
21	0.57	0.01	0.29	6	0	0.5	59	2	32.0	4	0	0.5	4	0	2.0
22	1.41	0.01	0.22	28	0	3.0	61	1	41.5	6	0	2.5	3	0	2.5
23	0.60	0.09	0.38	27	0	2.5	61	9	42.5	7	0	2.5	4	1	2.5
24	0.55	0.02	0.34	6	0	0.5	62	9	38.5	7	0	2.5	13	1	3.0
25	8.83	0.18	0.63	4	0	0.0	60	26	40.0	5	0	2.0	4	1	2.5
26	0.53	0.17	0.34	21	0	1.5	55	17	39.0	5	0	2.0	4	0	3.0
27	0.53	0.18	0.14	5	0	0.5	56	25	41.5	4	0	2.0	4	1	3.0
28	0.64	0.08	0.34	13	0	1.0	58	10	36.5	4	0	0.0	4	1	3.0
29	0.65	0.08	0.38	18	0	1.5	59	1	35.0	4	0	1.5	3	0	2.5
30	0.64	0.19	0.36	3	0	0.0	55	25	39.5	5	0	2.0	4	2	3.0
31	0.41	0.03	0.31	1	0	0.0	64	1	41.5	5	0	2.0	4	0	3.0

令和7年度 排ガス中のばい煙濃度等

8月	ばいじん濃度(mg/Nm3) 管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			一酸化炭素濃度(ppm) 維持管理基準: 100ppm以下			窒素酸化物濃度(ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度(ppm) 管理値: 20ppm以下			塩化水素濃度(ppm) 管理値: 50ppm以下 排出基準: 430ppm以下		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.40	0.10	0.31	4	0	0.5	54	9	38.5	4	0	1.5	3	1	3.0
2	0.40	0.01	0.31	6	0	0.5	58	1	38.0	8	0	2.0	3	0	3.0
3	0.40	0.04	0.31	13	0	1.0	61	3	43.0	7	0	2.5	4	0	3.0
4	0.41	0.05	0.31	10	0	1.5	72	10	42.5	7	0	2.5	3	1	2.5
5	0.28	0.18	0.25	1	0	0.0	62	30	48.0	6	4	5.0	3	1	2.0
6	0.28	0.00	0.22	3	0	1.0	60	0	36.0	6	0	4.0	3	0	2.0
7	0.25	0.17	0.24	4	0	2.0	48	29	37.0	6	2	3.0	3	1	3.0
8	0.25	0.18	0.25	10	0	1.0	47	31	38.0	3	1	2.0	3	2	3.0
9	0.29	0.18	0.25	5	1	2.0	56	35	45.0	3	1	2.0	3	1	3.0
10	0.25	0.18	0.25	23	1	3.0	54	33	45.0	2	0	1.0	3	2	3.0
11	0.25	0.18	0.25	2	0	1.0	55	37	47.0	3	0	2.0	3	2	3.0
12	0.29	0.18	0.25	7	0	1.0	60	40	50.0	3	2	2.0	3	2	3.0
13	0.30	0.02	0.23	2	0	1.0	55	0	37.0	3	0	2.0	3	0	3.0
14	0.28	0.02	0.24	10	0	2.0	53	1	34.0	3	0	2.0	3	0	3.0
15	0.95	0.21	0.34	4	1	1.0	53	29	40.0	4	1	2.0	3	2	3.0
16	0.30	0.19	0.27	16	1	2.0	57	35	44.0	3	1	2.0	3	2	3.0
17	0.30	0.17	0.25	3	0	1.0	58	34	48.0	3	1	2.0	3	2	3.0
18	1.12	0.17	0.37	2	0	0.0	54	18	39.0	4	1	3.0	3	1	1.0
19	2.06	0.27	0.44	19	0	3.0	54	23	39.0	4	2	3.0	4	2	3.0
20	0.30	0.21	0.27	8	1	2.0	51	31	44.0	5	2	3.0	3	2	2.0
21	3.78	0.18	0.50	6	1	2.0	57	31	48.0	4	2	3.0	3	2	3.0
22	0.40	0.24	0.30	13	0	3.0	58	36	49.0	4	1	3.0	3	1	3.0
23	0.53	0.22	0.29	7	0	1.0	61	29	50.0	5	3	4.0	3	2	3.0
24	0.30	0.18	0.26	12	0	2.0	66	43	52.0	4	2	4.0	4	2	4.0
25	0.32	0.04	0.23	14	0	3.0	61	2	35.0	4	1	3.0	4	1	3.0
26	0.39	0.18	0.26	9	0	1.0	56	20	37.0	6	3	4.0	4	2	3.0
27	0.68	0.08	0.32	16	0	3.0	58	4	31.0	6	1	4.0	4	1	3.0
28	0.72	0.80	0.30	5	0	1.0	52	24	39.0	5	2	4.0	3	2	3.0
29	0.46	0.20	0.28	3	0	1.0	59	27	43.0	5	2	3.0	3	2	3.0
30	0.49	0.09	0.29	10	0	1.5	58	5	35.0	4	0	1.5	16	1	6.0
31	0.43	0.18	0.32	5	0	1.0	61	27	44.0	5	0	2.0	5	2	3.0