

令和7年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

4月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	3.05	0.00	1.12	19	0	2.0	54	0	38.0	0	0	0.0	3	0	2.0	7.50	0.00	2.01
2	3.22	0.08	1.14	21	0	2.5	57	31	46.0	0	0	0.0	3	1	2.0	10.50	0.00	2.60
3	2.92	0.07	1.04	6	0	1.0	55	34	45.0	0	0	0.0	3	1	2.5	2.50	0.00	1.28
4	2.81	0.07	1.20	8	0	1.5	65	32	47.0	0	0	0.0	3	2	2.0	4.00	0.00	1.36
5	2.00	0.08	0.73	19	0	2.0	62	32	45.5	0	0	0.0	5	1	3.0	7.50	0.00	1.95
6	1.51	0.11	0.71	24	0	3.5	55	33	45.5	0	0	0.0	5	2	3.0	13.25	0.25	3.55
7	1.60	0.00	0.67	17	0	1.5	56	0	40.0	0	0	0.0	5	0	3.5	9.75	0.00	2.33
8	1.62	0.00	0.76	4	0	0.5	57	0	44.0	0	0	0.0	5	0	4.0	2.25	0.00	0.74
9	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
11	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
12	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
13	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
14	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
15	4.19	0.00	1.30	15	0	2.5	53	0	26.0	0	0	0.0	4	0	2.5	4.75	1.00	2.67
16	4.86	0.12	1.83	18	0	1.5	59	30	45.5	0	0	0.0	4	2	2.5	8.25	0.00	1.48
17	4.83	0.12	1.43	20	0	3.5	61	5	45.0	0	0	0.0	16	0	3.0	8.75	0.00	2.96
18	3.58	0.11	1.39	7	0	1.5	53	22	40.0	0	0	0.0	5	1	2.5	7.25	0.00	1.64
19	3.20	0.13	1.24	26	0	5.0	56	0	38.5	0	0	0.0	18	0	4.0	16.00	0.25	4.88
20	2.67	0.00	1.15	29	0	4.0	59	0	42.5	0	0	0.0	11	0	4.0	16.75	0.00	4.18
21	3.59	0.00	1.36	2	0	0.5	54	0	39.0	0	0	0.0	5	0	3.5	1.25	0.00	0.63
22	5.66	0.00	3.80	21	0	3.0	59	0	42.0	0	0	0.0	3	0	2.0	12.25	0.00	2.77
23	5.28	0.00	3.59	17	0	4.0	51	0	35.0	0	0	0.0	3	0	2.0	9.00	0.00	4.22
24	5.97	0.00	4.10	16	0	2.0	54	0	42.0	0	0	0.0	2	0	2.0	5.75	0.00	1.88
25	5.52	1.90	4.31	19	0	3.0	58	28	45.0	0	0	0.0	3	2	2.0	7.25	0.00	2.18
26	4.12	0.00	3.18	18	0	5.0	52	0	43.0	0	0	0.0	3	0	2.0	11.00	1.50	6.04
27	3.90	0.00	2.81	27	0	3.0	60	0	45.0	0	0	0.0	5	0	3.0	11.00	0.00	3.83
28	6.02	1.69	4.13	4	0	0.0	63	38	51.0	0	0	0.0	4	3	3.0	1.50	0.00	0.35
29	5.18	2.65	3.73	1	0	0.0	61	34	52.0	0	0	0.0	4	2	3.0	0.50	0.00	0.15
30	4.73	0.00	3.31	7	0	1.0	62	0	42.0	0	0	0.0	4	0	3.0	4.00	0.25	1.57

令和7年度 排ガス中のばい煙濃度等（※特に表示が無いものは1時間平均の値）

5月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)			一酸化炭素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			管理値:100ppm以下 維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下			管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	6.51	1.91	4.07	20	0	3.0	60	39	51.0	0	0	0.0	3	2	3.0	0.00	2.39	2.39
2	6.27	0.20	4.07	21	0	8.0	59	2	40.0	0	0	0.0	3	0	2.0	0.00	2.08	2.08
3	6.05	0.78	4.11	2	0	0.0	58	6	46.0	0	0	0.0	3	1	2.0	0.00	0.21	0.21
4	4.86	2.20	4.10	26	0	5.0	58	39	50.0	0	0	0.0	3	2	3.0	0.00	3.54	3.54
5	5.29	0.00	2.07	9	0	3.0	60	0	44.0	0	0	0.0	3	0	2.0	0.00	3.67	3.67
6	5.86	0.13	4.13	8	0	1.0	58	2	44.0	0	0	0.0	3	0	2.0	0.00	1.21	1.21
7	6.90	2.67	4.61	14	0	3.0	58	14	44.0	0	0	0.0	3	1	2.0	0.00	3.09	3.09
8	6.68	2.97	5.47	19	0	2.0	61	37	51.0	0	0	0.0	3	1	2.0	0.00	2.45	2.45
9	5.60	3.59	5.04	10	0	1.0	62	40	52.0	0	0	0.0	3	2	2.0	0.00	0.77	0.77
10	5.27	2.07	4.26	11	0	2.0	54	19	44.0	0	0	0.0	2	1	2.0	0.00	2.36	2.36
11	5.34	0.01	4.26	18	0	1.0	61	0	49.0	0	0	0.0	3	0	2.0	0.00	0.59	0.59
12	5.77	1.72	3.96	7	0	1.0	58	30	48.0	0	0	0.0	3	1	3.0	0.00	1.64	1.64
13	7.48	0.11	5.14	0	0	0.0	61	1	49.0	0	0	0.0	3	0	3.0	0.00	0.07	0.07
14	6.90	3.30	5.08	11	0	1.0	57	39	49.0	0	0	0.0	3	2	3.0	0.00	0.73	0.73
15	7.30	0.14	2.56	24	0	8.5	57	12	37.5	0	0	0.0	4	1	3.0	17.67	1.87	9.77
16	6.48	0.16	2.58	20	0	2.5	58	1	42.5	1	0	0.0	3	0	3.0	3.45	2.05	2.75
17	6.30	0.00	2.63	9	0	2.0	56	0	44.5	2	0	0.5	3	0	3.0	2.27	1.63	1.95
18	6.07	0.16	2.46	41	0	4.5	63	27	46.5	2	0	0.5	4	2	3.0	2.98	5.29	4.14
19	5.71	0.16	2.44	4	0	1.0	61	28	46.5	1	0	0.5	4	2	3.0	1.88	0.83	1.35
20	5.57	0.15	2.06	4	0	1.0	62	5	45.0	1	0	0.5	4	0	3.0	2.00	0.17	1.08
21	5.83	0.00	2.42	5	0	1.0	64	0	42.0	1	0	0.5	4	0	3.0	1.93	0.44	1.19
22	6.81	0.16	2.60	13	0	2.0	60	7	47.0	2	0	0.5	4	1	3.5	2.46	2.08	2.27
23	5.52	0.13	2.30	15	0	2.0	58	35	47.5	1	0	0.0	4	2	3.0	2.33	2.04	2.19
24	5.89	0.13	2.57	13	0	2.0	62	40	48.5	1	0	0.0	3	2	3.0	3.25	0.92	2.08
25	5.89	0.13	2.37	18	0	2.0	59	1	46.5	1	0	0.5	3	0	3.0	2.84	0.78	1.81
26	5.99	0.11	2.56	14	0	2.0	60	37	49.5	0	0	0.0	4	2	3.0	2.20	1.68	1.94
27	5.79	0.05	2.25	5	0	1.0	61	12	46.0	0	0	0.0	3	1	3.0	1.60	0.50	1.05
28	5.73	0.03	2.43	27	0	3.5	62	6	45.5	1	0	0.0	4	1	2.5	4.17	2.83	3.50
29	5.72	0.12	2.50	21	1	5.0	64	25	45.0	1	0	0.0	4	2	3.0	2.21	3.25	2.73
30	0.20	0.11	0.17	2	2	2.0	54	34	42.0	1	0	0.0	3	1	2.0	2.00	0.00	2.00
31	0.20	0.11	0.16	7	2	2.0	51	37	45.0	2	1	1.0	4	1	3.0	2.46	0.00	2.46

令和7年度 排ガス中のばい煙濃度等（※特に表示が無いものは1時間平均の値）

6月	ばいじん濃度(mg/Nm3) 管理値: 20mg/Nm3以下 排出基準: 150mg/Nm3以下			一酸化炭素濃度 (ppm) 管理値: 100ppm以下 維持管理基準: 100ppm以下			窒素酸化物濃度 (ppm) 管理値: 70ppm以下 排出基準: 250ppm以下			硫黄酸化物濃度 (ppm) 管理値: 20ppm以下			塩化水素濃度 (ppm) 管理値: 50ppm以下 排出基準: 430ppm以下			一酸化炭素濃度 (ppm) 管理値: 30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.20	0.09	0.15	12	2	3.0	55	31	46.0	1	1	1.0	1	1	1.0	3.03	0.00	3.03
2	0.20	0.11	0.17	5	2	3.0	51	33	44.0	1	0	0.0	5	3	4.0	2.85	0.00	2.85
3	0.15	0.01	0.14	2	0	2.0	53	0	43.0	1	0	0.0	4	0	4.0	2.06	0.00	2.06
4	0.20	0.11	0.17	15	1	3.0	60	27	40.0	1	0	0.0	4	2	4.0	2.86	0.00	2.86
5	0.20	0.11	0.17	15	2	3.0	58	30	43.0	1	0	0.0	4	2	4.0	0.09	0.00	0.09
6	0.31	0.11	0.18	5	2	2.0	52	30	38.0	1	0	0.0	5	3	4.0	2.18	0.00	2.18
7	0.52	0.11	0.31	23	0	3.5	57	7	37.5	0	0	0.0	5	2	4.0	2.03	3.75	2.89
8	0.42	0.13	0.29	9	0	2.0	59	27	42.0	1	0	0.0	5	2	3.0	2.43	1.04	1.73
9	0.48	0.12	0.30	23	0	1.0	56	34	42.5	1	0	0.0	5	1	2.5	1.80	3.16	2.48
10	0.49	0.00	0.30	7	0	0.5	58	1	42.0	0	0	0.0	3	0	2.0	1.37	0.42	0.89
11	2.00	0.01	0.31	12	0	2.5	61	0	22.0	1	0	0.0	4	0	2.5	3.47	0.49	1.98
12	0.51	0.13	0.31	20	0	2.0	61	32	45.5	1	0	0.0	5	1	2.5	2.23	2.22	2.22
13	0.59	0.07	0.31	4	0	1.5	54	6	40.5	1	0	0.0	5	1	2.5	1.44	0.72	1.08
14	0.45	0.16	0.30	13	0	2.5	58	24	42.5	1	0	0.0	6	1	3.0	2.57	1.85	2.21
15	0.40	0.16	0.30	12	0	2.0	56	31	43.5	2	0	0.5	6	2	4.0	3.47	0.84	2.16
16	0.40	0.18	0.32	18	0	2.0	62	2.0	23.0	1	0	0.5	5	2	3.5	3.83	0.00	1.92
17	0.48	0.02	0.31	9	0	1.5	53	1.0	30.5	2	0	0.5	4	0	2.5	2.10	0.50	1.30
18	0.43	0.18	0.33	18	0	2.5	58	31.0	42.5	1	0	0.5	7	2	3.5	3.96	0.65	2.30
19	0.40	0.18	0.32	4	0	1.0	61	36.0	44.0	1	0	0.0	7	2	3.5	2.00	0.73	1.36
20	0.92	0.03	0.37	24	0	4.5	57	3.0	37.0	1	0	0.0	5	1	3.0	5.29	3.89	4.59
21	1.04	0.18	0.39	14	0	4.5	61	30	44.0	1	0	0.5	6	1	3.5	3.83	3.83	3.83
22	0.54	0.18	0.33	6	0	1.5	61	37	45.5	2	0	0.5	7	2	3.5	2.46	1.63	2.04
23	0.40	0.03	0.31	9	0	1.0	60	2	43.5	1	0	0.0	4	0	2.5	2.38	0.08	1.23
24	0.65	0.02	0.35	3	0	1.0	52	0	39.0	1	0	0.0	4	0	2.0	1.89	0.38	1.13
25	0.44	0.11	0.31	22	0	3.0	56	6	43.5	1	0	0.5	4	1	2.5	4.92	1.76	3.34
26	0.44	0.11	0.31	22	0	3.0	56	6	43.5	1	0	0.5	4	1	2.5	3.94	1.75	2.84
27	0.56	0.01	0.32	17	0	2.0	60	1	43.5	1	0	0.0	4	0	2.5	2.56	0.87	1.72
28	0.45	0.18	0.33	14	0	2.0	59	34	44.0	1	0	0.0	5	1	3.0	2.83	0.65	1.74
29	0.41	0.18	0.32	15	0	1.5	58	31	42.5	0	0	0.0	4	1	2.5	1.98	0.00	0.99
30	0.40	0.03	0.29	15	0	2.0	58	3	40.0	0	0	0.0	4	0	2.5	2.59	0.50	1.55

令和7年度 排ガス中のばい煙濃度等（※特に表示が無いものは1時間平均の値）

7月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.45	0.00	0.33	15	0	1.5	52	23	43.5	1	0	0.0	3	1	2.5	5.25	0.46	1.90
2	0.55	0.27	0.43	0	0	0.0	54	29	43.0	0	0	0.0	3	2	3.0	0.00	0.00	0.00
3	0.50	0.00	0.36	1	0	0.0	52	1	38.0	0	0	0.0	5	0	3.0	0.25	0.04	0.04
4	0.44	0.01	0.38	4	0	0.0	53	1	37.0	0	0	0.0	4	0	3.0	1.75	0.35	0.35
5	0.44	0.11	0.37	4	0	1.0	45	11	37.0	0	0	0.0	4	1	3.0	2.25	0.48	0.48
6	0.40	0.25	0.39	9	0	2.0	46	33	40.0	0	0	0.0	3	2	3.0	5.00	1.56	1.56
7	0.44	0.10	0.38	15	0	1.0	52	6	40.0	0	0	0.0	4	1	3.0	8.00	2.10	2.10
8	0.47	0.20	0.40	2	0	0.0	54	18	42.0	0	0	0.0	4	1	3.0	0.75	0.13	0.13
9	0.55	0.26	0.44	2	0	0.0	47	37	43.0	0	0	0.0	3	1	2.0	0.75	0.12	0.12
10	0.50	0.00	0.38	14	0	2.0	46	0	37.0	0	0	0.0	3	0	3.0	2.75	0.96	0.96
11	0.52	0.25	0.42	8	0	1.0	50	36	43.0	0	0	0.0	3	1	3.0	2.75	0.96	0.96
12	0.57	0.02	0.40	9	0	1.0	46	2	35.0	0	0	0.0	4	0	3.0	3.00	0.81	0.81
13	0.60	0.31	0.50	7	0	0.0	45	38	41.0	0	0	0.0	3	2	3.0	2.25	0.51	0.51
14	0.59	0.01	0.44	26	0	2.0	54	1	38.0	0	0	0.0	4	0	3.0	11.00	2.07	2.07
15	0.71	0.03	0.49	11	0	1.0	50	2	38.0	0	0	0.0	4	0	3.0	3.00	0.76	0.76
16	0.80	0.34	0.56	2	0	0.0	53	35	41.0	0	0	0.0	4	2	3.0	1.00	0.21	0.21
17	0.93	0.44	0.64	9	0	1.0	52	35	41.0	0	0	0.0	3	2	3.0	2.50	0.50	0.50
18	1.11	0.44	0.63	1	0	0.0	55	36	44.0	0	0	0.0	3	2	3.0	0.25	0.04	0.04
19	0.58	0.18	0.46	25	0	1.0	48	14	38.0	0	0	0.0	3	1	3.0	6.25	0.31	0.31
20	0.68	0.31	0.50	15	0	1.0	55	39	45.0	0	0	0.0	3	2	3.0	8.50	1.40	3.76
21	0.57	0.01	0.29	6	0	0.5	59	2	32.0	4	0	0.5	4	0	2.0	7.50	0.91	0.63
22	1.41	0.01	0.22	28	0	3.0	61	1	41.5	6	0	2.5	3	0	2.5	11.00	1.82	2.48
23	0.60	0.09	0.38	27	0	2.5	61	9	42.5	7	0	2.5	4	1	2.5	12.25	1.08	2.88
24	0.55	0.02	0.34	6	0	0.5	62	9	38.5	7	0	2.5	13	1	3.0	3.00	0.28	0.64
25	8.83	0.18	0.63	4	0	0.0	60	26	40.0	5	0	2.0	4	1	2.5	1.50	0.52	0.34
26	0.53	0.17	0.34	21	0	1.5	55	17	39.0	5	0	2.0	4	0	3.0	6.00	1.06	0.83
27	0.53	0.18	0.34	5	0	0.5	56	25	41.5	4	0	2.0	4	1	3.0	2.50	1.01	0.62
28	0.64	0.08	0.34	13	0	1.0	58	10	36.5	4	0	0.0	4	1	3.0	5.00	2.03	1.10
29	0.65	0.08	0.38	18	0	1.5	59	1	35.0	4	0	1.5	3	0	2.5	7.75	2.69	1.62
30	0.64	0.19	0.36	3	0	0.0	55	25	39.5	5	0	2.0	4	2	3.0	1.25	0.00	0.00
31	0.41	0.03	0.31	1	0	0.0	64	1	41.5	5	0	2.0	4	0	3.0	0.25	0.04	0.04

令和7年度 排ガス中のばい煙濃度等（※特に表示が無いものは1時間平均の値）

8月	ばいじん濃度(mg/Nm3)			一酸化炭素濃度(ppm)			窒素酸化物濃度(ppm)			硫黄酸化物濃度(ppm)			塩化水素濃度(ppm)			一酸化炭素濃度(ppm)		
	管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			管理値:100ppm以下 維持管理基準:100ppm以下			管理値:70ppm以下 排出基準:250ppm以下			管理値:20ppm以下			管理値:50ppm以下 排出基準:430ppm以下			管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.40	0.10	0.31	4	0	0.5	54	9	38.5	4	0	1.5	3	1	3.0	2.25	0.00	0.36
2	0.40	0.01	0.31	6	0	0.5	58	1	38.0	8	0	2.0	3	0	3.0	4.00	0.00	0.50
3	0.40	0.04	0.31	13	0	1.0	61	3	43.0	7	0	2.5	4	0	3.0	4.50	0.00	0.82
4	0.41	0.05	0.31	10	0	1.5	72	10	42.5	7	0	2.5	3	1	2.5	4.50	0.00	1.93
5	0.28	0.18	0.25	1	0	0.0	62	30	48.0	6	4	5.0	3	1	2.0	0.50	0.00	0.17
6	0.28	0.00	0.22	3	0	1.0	60	0	36.0	6	0	4.0	3	0	2.0	1.75	0.00	0.96
7	0.25	0.17	0.24	4	0	2.0	48	29	37.0	6	2	3.0	3	1	3.0	2.75	0.50	1.66
8	0.25	0.18	0.25	10	0	1.0	47	31	38.0	3	1	2.0	3	2	3.0	3.25	0.25	1.00
9	0.29	0.18	0.25	5	1	2.0	56	35	45.0	3	1	2.0	3	1	3.0	4.25	1.00	1.91
10	0.25	0.18	0.25	23	1	3.0	54	33	45.0	2	0	1.0	3	2	3.0	9.50	1.00	2.67
11	0.25	0.18	0.25	2	0	1.0	55	37	47.0	3	0	2.0	3	2	3.0	2.00	0.50	1.13
12	0.29	0.18	0.25	7	0	1.0	60	40	50.0	3	2	2.0	3	2	3.0	3.50	0.50	1.46
13	0.30	0.02	0.23	2	0	1.0	55	0	37.0	3	0	2.0	3	0	3.0	1.00	0.00	0.47
14	0.28	0.02	0.24	10	0	2.0	53	1	34.0	3	0	2.0	3	0	3.0	6.00	0.50	2.20
15	0.95	0.21	0.34	4	1	1.0	53	29	40.0	4	1	2.0	3	2	3.0	1.75	1.00	1.17
16	0.30	0.19	0.27	16	1	2.0	57	35	44.0	3	1	2.0	3	2	3.0	4.75	1.00	1.36
17	0.30	0.17	0.25	3	0	1.0	58	34	48.0	3	1	2.0	3	2	3.0	5.25	0.00	1.55
18	1.12	0.17	0.37	2	0	0.0	54	18	39.0	4	1	3.0	3	1	1.0	1.25	0.00	0.57
19	2.06	0.27	0.44	19	0	3.0	54	23	39.0	4	2	3.0	4	2	3.0	13.00	0.00	2.94
20	0.30	0.21	0.27	8	1	2.0	51	31	44.0	5	2	3.0	3	2	2.0	3.50	1.00	2.00
21	3.78	0.18	0.50	6	1	2.0	57	31	48.0	4	2	3.0	3	2	3.0	4.00	1.00	2.04
22	0.40	0.24	0.30	13	0	3.0	58	36	49.0	4	1	3.0	3	1	3.0	7.00	0.00	2.54
23	0.53	0.22	0.29	7	0	1.0	61	29	50.0	5	3	4.0	3	2	3.0	2.50	0.00	0.85
24	0.30	0.18	0.26	12	0	2.0	66	43	52.0	4	2	4.0	4	2	4.0	6.50	0.00	1.63
25	0.32	0.04	0.23	14	0	3.0	61	2	35.0	4	1	3.0	4	1	3.0	9.25	0.00	4.32
26	0.39	0.18	0.26	9	0	1.0	56	20	37.0	6	3	4.0	4	2	3.0	3.00	0.00	0.83
27	0.68	0.08	0.32	16	0	3.0	58	4	31.0	6	1	4.0	4	1	3.0	9.00	0.00	3.49
28	0.72	0.80	0.30	5	0	1.0	52	24	39.0	5	2	4.0	3	2	3.0	3.50	0.25	1.45
29	0.46	0.20	0.28	3	0	1.0	59	27	43.0	5	2	3.0	3	2	3.0	1.25	0.00	0.54
30	0.49	0.09	0.29	10	0	1.5	58	5	35.0	4	0	1.5	16	1	6.0	3.25	0.00	1.48
31	0.43	0.18	0.32	5	0	1.0	61	27	44.0	5	0	2.0	5	2	3.0	3.50	0.00	0.91

令和7年度 排ガス中のばい煙濃度等（※特に表示が無いものは1時間平均の値）

9月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.40	0.05	0.30	25	0	1.5	55	3	37.5	5	0	2.0	6	0	3.5	8.00	0.00	1.25
2	0.44	0.18	0.33	8	0	0.5	52	25	40.0	4	0	2.0	6	2	3.5	2.25	0.00	0.40
3	0.59	0.17	0.33	29	0	2.0	58	31	44.0	6	0	1.5	4	2	3.5	12.00	0.00	1.98
4	0.48	0.18	0.32	4	0	0.5	58	27	43.5	4	0	1.5	4	2	3.0	4.75	0.00	0.67
5	0.44	0.04	0.31	5	0	1.0	59	2	44.0	4	0	1.5	4	0	3.0	3.00	0.00	0.57
6	0.45	0.17	0.32	3	0	0.5	63	32	45.5	4	0	1.5	4	1	3.0	1.75	0.00	0.46
7	0.50	0.00	0.33	9	0	1.5	61	0	46.5	5	0	2.0	5	0	3.0	4.00	0.00	1.26
8	0.51	0.03	0.32	11	0	1.0	61	3	46.5	4	0	1.5	4	0	3.0	5.00	0.00	0.88
9	0.44	0.12	0.32	5	0	0.5	61	17	45.5	4	0	1.5	4	2	3.0	2.50	0.00	0.70
10	0.42	0.01	0.31	5	0	1.0	53	0	37.0	6	0	1.5	6	0	3.5	3.75	0.00	0.99
11	0.40	0.18	0.32	16	0	1.5	59	24	40.0	3	0	1.0	9	2	4.0	10.50	0.00	1.88
12	0.57	0.03	0.31	10	0	0.5	56	2	40.5	3	0	1.0	6	0	3.0	2.75	0.00	0.57
13	0.42	0.11	0.31	5	0	0.5	52	10	38.0	3	0	1.5	7	2	3.5	2.25	0.00	0.40
14	0.43	0.09	0.31	24	0	2.0	60	4	44.0	4	0	1.5	5	1	3.5	10.75	0.00	2.03
15	0.42	0.13	0.31	7	0	0.5	55	0	43.5	3	0	1.5	7	1	3.5	10.00	0.00	1.36
16	0.42	0.13	0.31	7	0	0.5	55	0	43.5	3	0	1.5	7	1	3.5	4.25	0.00	0.51
17	0.40	0.03	0.35	7	0	0.0	57	1	45.0	0	0	0.0	11	0	3.0	2.25	0.00	0.50
18	0.46	0.23	0.39	12	0	1.0	56	35	48.0	0	0	0.0	4	2	3.0	6.00	0.00	1.41
19	0.66	0.27	0.43	0	0	0.0	60	37	49.0	0	0	0.0	6	2	3.0	0.00	0.00	0.00
20	0.45	0.00	0.19	0	0	0.0	56	0	21.5	0	0	0.0	3	0	1.5	0.00	0.00	0.00
21	0.77	0.24	0.42	8	0	1.0	58	35	49.0	0	0	0.0	4	2	3.0	3.75	0.00	0.76
22	0.82	0.00	0.43	1	0	0.0	58	0	44.0	0	0	0.0	3	0	3.0	2.00	0.00	0.11
23	0.83	0.01	0.43	6	0	0.0	61	0	40.0	0	0	0.0	4	0	2.0	2.00	0.00	0.38
24	0.55	0.33	0.46	7	0	1.0	63	31	47.0	0	0	0.0	3	2	3.0	2.50	0.00	1.26
25	0.83	0.26	0.55	15	0	2.0	56	30	44.0	0	0	0.0	4	2	3.0	6.75	0.00	2.20
26	0.73	0.03	0.39	18	0	3.0	59	2	36.0	0	0	0.0	5	0	3.5	11.00	0.00	2.43
27	0.63	0.23	0.38	5	0	0.5	54	28	45.5	1	0	0.0	4	2	3.5	6.75	0.00	0.68
28	0.73	0.03	0.38	21	0	2.5	61	2	46.0	1	0	0.0	6	0	3.0	10.75	0.00	2.26
29	0.74	0.14	0.42	20	0	1.5	62	26	50.5	0	0	0.0	4	2	3.0	7.25	0.00	1.62
30	0.72	0.00	0.36	21	0	3.0	62	0	45.0	1	0	0.0	3	0	3.0	10.00	0.00	2.51

令和7年度 排ガス中のばい煙濃度等 (※特に表示が無いものは1時間平均の値)

10月	ばいじん濃度(mg/Nm3) 管理値:20mg/Nm3以下 排出基準:150mg/Nm3以下			一酸化炭素濃度(ppm) 管理値:100ppm以下 維持管理基準:100ppm以下			窒素酸化物濃度(ppm) 管理値:70ppm以下 排出基準:250ppm以下			硫黄酸化物濃度(ppm) 管理値:20ppm以下			塩化水素濃度(ppm) 管理値:50ppm以下 排出基準:430ppm以下			一酸化炭素濃度(ppm) 管理値:30ppm以下 (4時間平均)		
	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均	最大	最小	平均
1	0.73	0.05	0.36	15	0	1.0	59	2	43.5	0	0	0.0	6	0	3.0	5.50	0.00	1.25
2	0.69	0.05	0.38	4	0	0.5	55	15	41.0	2	0	0.0	3	1	3.0	2.00	0.00	0.81
3	0.68	0.05	0.38	3	0	1.0	59	3	46.5	1	0	0.0	6	0	2.5	2.00	0.00	0.87
4	0.79	0.12	0.36	29	0	2.0	63	0	45.0	1	0	0.0	5	0	2.5	7.75	0.00	1.78
5	0.93	0.16	0.44	28	0	2.5	62	36	52.0	1	0	0.0	3	1	2.5	9.50	0.00	2.92
6	0.73	0.01	0.39	27	0	4.5	58	1	43.0	0	0	0.0	3	0	2.5	12.00	0.00	4.45
7	0.95	0.00	0.45	62	0	1.0	62	16	44.5	0	0	0.0	7	2	3.0	3.75	0.00	1.49
8	0.73	0.18	0.41	16	0	2.0	62	30	47.5	2	0	0.0	4	2	3.0	8.25	0.00	1.90
9	0.65	0.06	0.37	31	0	2.0	61	2	46.5	0	0	0.0	9	1	3.0	13.25	0.00	1.86
10	0.80	0.14	0.39	17	0	1.5	61	35	49.5	0	0	0.0	5	2	3.0	5.25	0.00	1.29
11	0.58	0.12	0.35	16	0	1.5	66	12	45.0	0	0	0.0	7	2	4.0	7.75	0.00	1.63
12	0.55	0.07	0.34	5	0	1.0	66	6	46.0	0	0	0.0	7	1	3.5	2.25	0.00	0.93
13	0.66	0.02	0.32	7	0	0.5	61	1	43.0	0	0	0.0	10	0	3.0	2.75	0.00	0.47
14	0.55	0.01	0.34	12	0	1.0	56	1	44.0	0	0	0.0	5	0	3.0	8.00	0.00	1.10
15	0.59	0.00	0.35	18	0	2.5	61	0	48.5	1	0	0.0	4	0	3.0	8.00	0.00	2.54
16	0.63	0.03	0.34	19	0	3.0	61	0	46.5	2	0	0.0	5	0	3.0	9.50	0.00	3.01
17	1.05	0.07	0.42	2	0	0.0	61	17	48.5	0	0	0.0	4	1	3.0	1.00	0.00	0.15
18	0.76	0.00	0.34	15	0	2.0	66	0	47.0	1	0	0.0	5	0	3.0	8.75	0.00	1.93
19	0.55	0.04	0.09	10	0	1.0	63	7	45.0	0	0	0.0	6	1	3.5	5.25	0.00	0.75
20	0.81	0.10	0.31	7	0	1.0	59	9	41.0	0	0	0.0	6	1	3.0	3.25	0.00	1.16
21	0.85	0.00	0.32	9	0	1.5	64	0	42.0	0	0	0.0	3	0	2.0	5.25	0.00	1.77
22	0.52	0.12	0.30	10	0	2.0	61	36	49.0	1	0	0.0	3	0	2.0	4.50	0.00	1.60
23	0.71	0.00	0.33	14	0	2.0	58	0	43.0	0	0	0.0	4	1	2.0	6.25	0.00	2.17
24	0.50	0.15	0.33	18	0	1.5	60	1	24.0	0	0	0.0	3	1	1.5	7.00	0.00	1.48
25	0.55	0.09	0.34	22	0	2.0	62	25	46.0	0	0	0.0	3	0	1.5	6.00	0.00	1.82
26	2.04	0.00	0.49	39	0	3.5	59	0	44.0	0	0	0.0	11	0	2.0	23.00	0.00	2.75
27	0.74	0.01	0.38	10	0	0.5	63	0	46.5	0	0	0.0	3	0	2.0	4.75	0.00	0.84
28	0.66	0.01	0.35	15	0	1.0	59	2	37.5	0	0	0.0	3	0	2.5	4.00	0.00	0.69
29	0.77	0.12	0.39	30	0	2.0	55	22	43.0	0	0	0.0	5	1	3.0	12.50	0.00	2.29
30	1.30	0.11	0.45	4	0	1.0	59	0	43.0	0	0	0.0	5	1	2.5	2.50	0.00	1.07
31	0.86	0.11	0.36	3	0	0.5	55	31	41.5	0	0	0.0	5	1	2.5	2.00	0.00	0.68

令和7年度 排ガス中のばい煙濃度等（※特に表示が無いものは1時間平均の値）

[illegible]